

県営第一工業用水道 水質試験結果表

2019年4月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	5.4	9.6	0.8	6.7						10.0	1	
2	雪	4.6	8.9	0.9	6.7						9.7	1	
3	晴	5.4	8.4	0.6	6.7	20.2	26.9	54.0	9.1	0.10	9.7	1	
4	晴	8.8	8.4	0.4	6.7						9.6	0	
5	晴	13.2	9.1	0.4	6.7						9.7	0	
6	晴	13.3	10.1	0.3	6.7						9.7	0	
7	曇	12.2	10.5	0.3	6.7						9.8	0	
8	晴	12.0	10.7	0.4	6.7						10.0	0	
9	晴	10.2	11.0	0.5	6.7						10.1	0	
10	雨	7.8	10.8	1.3	6.6						10.3	4	
11	曇	9.2	10.3	1.0	6.6						9.4	2	
12	晴	9.6	10.1	0.5	6.6						9.3	0	
13	晴	10.9	10.2	0.4	6.6						9.5	0	
14	曇	12.6	10.6	0.3	6.6						9.6	0	
15	晴	11.7	10.9	0.7	6.6	21.1	26.7	64.0	8.3	0.10	9.7	1	
16	晴	12.5	11.1	0.5	6.6						10.0	0	
17	晴	15.5	11.6	0.5	6.6						10.1	2	
18	晴	17.4	12.3	0.5	6.6						10.4	0	
19	曇	13.9	12.9	0.5	6.6						10.5	0	
20	晴	13.2	12.6	0.4	6.6						10.7	0	
21	晴	16.9	13.0	0.3	6.6						11.0	0	
22	晴	17.5	13.5	0.4	6.6						11.0	0	
23	晴	19.6	14.2	0.5	6.6						11.7	1	
24	雨	19.7	15.0	0.5	6.5						13.3	1	
25	雨	17.1	15.0	1.2	6.5	23.6	36.7	95.0	11.4	0.10	13.4	3	
26	雨	14.4	14.6	0.7	6.5						12.0	1	
27	雨	9.7	13.9	0.6	6.5						11.4	0	
28	曇	10.5	13.0	0.4	6.5						11.0	0	
29	曇	13.4	12.5	0.5	6.6						11.0	1	
30	曇	16.6	12.6	0.8	6.6						11.2	1	
最大	——	19.7	15.0	1.3	6.7	23.6	36.7	95.0	11.4	0.10	13.4	4	——
最小	——	4.6	8.4	0.3	6.5	20.2	26.7	54.0	8.3	0.10	9.3	0	
平均	——	12.5	11.6	0.6	6.6	21.6	30.1	71.0	9.6	0.10	10.5	1	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定