

県営第一工業用水道 水質試験結果表

2019年5月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	雨	15.6	13.1	0.7	6.5						10.8	1	
2	曇	16.5	13.4	0.6	6.5						10.6	1	
3	晴	16.9	13.8	0.5	6.5						10.5	0	
4	晴	17.2	14.4	0.4	6.5						10.7	0	
5	晴	20.0	14.9	0.5	6.5						10.9	0	
6	晴	18.1	15.4	0.5	6.5						11.2	1	
7	晴	13.2	15.3	0.9	6.5						11.2	1	
8	晴	15.8	15.0	0.7	6.5	24.2	30.4	62.5	9.6	0.10	11.7	2	
9	曇	18.6	15.2	0.6	6.5						12.3	0	
10	晴	19.1	15.7	0.5	6.5						14.4	0	
11	晴	19.3	16.3	0.4	6.4						16.9	0	
12	晴	18.6	16.7	0.3	6.4						17.6	0	
13	晴	21.7	17.5	0.8	6.4						17.8	3	
14	曇	20.2	17.9	0.9	6.4						17.7	3	
15	晴	20.2	17.8	0.9	6.4	25.2	40.1	106.0	14.3	0.10	16.2	2	
16	晴	21.9	18.6	0.8	6.5						15.3	5	
17	晴	23.3	18.8	0.9	6.5						14.5	1	
18	曇	23.4	18.8	0.7	6.4						15.2	1	
19	晴	23.9	18.6	0.5	6.4						15.2	0	
20	晴	23.0	18.7	0.6	6.4						15.3	1	
21	曇	19.3	18.5	1.5	6.4						14.8	4	
22	晴	18.6	18.2	1.1	6.4						12.8	4	
23	晴	21.3	18.1	0.8	6.4						13.5	1	
24	晴	22.7	18.5	0.5	6.4	27.9	39.8	100.5	14.7	0.10	16.4	1	
25	晴	25.4	19.0	0.4	6.4						18.0	0	
26	晴	25.8	19.6	0.2	6.4						18.6	0	
27	晴	27.3	20.0	0.3	6.4						18.8	0	
28	曇	20.8	19.8	0.4	6.4						19.7	0	
29	晴	19.6	19.5	1.1	6.4						18.0	2	
30	晴	21.6	19.3	1.0	6.4						15.7	1	
31	曇	20.2	19.4	0.6	6.4						17.8	0	
最大	——	27.3	20.0	1.5	6.5	27.9	40.1	106.0	14.7	0.10	19.7	5	——
最小	——	13.2	13.1	0.2	6.4	24.2	30.4	62.5	9.6	0.10	10.5	0	
平均	——	20.3	17.3	0.7	6.4	25.8	36.8	89.7	12.9	0.10	14.8	1	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値
 測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定