

県営第一工業用水道 水質試験結果表

2019年7月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	25.6	20.8	1.0	6.3						12.4	1	
2	曇	25.7	20.7	0.9	6.3						12.3	1	
3	曇	25.9	20.9	0.8	6.5	25.2	31.0	81.0	9.4	0.10	12.5	1	
4	曇	25.2	21.0	1.0	6.6						12.6	2	
5	曇	25.6	21.2	0.7	6.6						12.2	1	
6	曇	25.3	21.3	0.5	6.6						12.5	1	
7	曇	24.5	21.4	0.6	6.6						12.3	1	
8	曇	26.2	21.5	0.7	6.6						12.5	1	
9	雨	24.1	21.5	0.8	6.6						13.0	1	
10	晴	26.7	21.5	0.7	6.6						13.2	1	
11	雨	22.8	21.6	0.8	6.6						13.9	2	
12	曇	24.4	21.4	0.8	6.6	27.0	36.1	89.5	11.7	0.10	14.7	1	
13	曇	24.6	21.5	0.4	6.6						14.5	0	
14	曇	23.4	21.5	0.3	6.6						16.1	0	
15	曇	23.6	21.3	0.4	6.5						15.0	0	
16	曇	25.8	21.2	0.6	6.6						14.2	1	
17	晴	27.5	21.8	0.6	6.6						14.4	0	
18	雨	24.4	22.2	0.8	6.6						17.1	3	
19	雨	26.0	22.0	1.5	6.5						15.5	3	
20	雨	25.7	21.5	0.7	6.5						13.4	1	
21	曇	27.6	21.2	0.5	6.5						13.1	0	
22	雨	28.1	21.4	0.8	6.5						13.0	2	
23	曇	27.7	21.9	2.3	6.5						12.7	7	
24	晴	29.1	22.4	1.2	6.5						12.6	3	
25	晴	30.4	23.0	0.8	6.6	27.6	31.1	79.5	9.3	0.10	12.8	1	
26	晴	31.8	23.6	1.1	6.6						13.2	2	
27	曇	27.1	23.8	1.0	6.6						15.0	4	
28	曇	29.4	23.5	2.0	6.5						13.1	6	
29	晴	31.1	23.2	0.8	6.5						12.2	1	
30	晴	30.9	23.4	1.2	6.5						12.1	2	
31	晴	31.5	23.7	1.0	6.5						11.7	3	
最大	——	31.8	23.8	2.3	6.6	27.6	36.1	89.5	11.7	0.10	17.1	7	——
最小	——	22.8	20.7	0.3	6.3	25.2	31.0	79.5	9.3	0.10	11.7	0	
平均	——	26.7	21.9	0.9	6.5	26.6	32.7	83.3	10.1	0.10	13.4	2	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値
 測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定