

県営第一工業用水道 水質試験結果表

2019年8月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	30.5	24.0	0.8	6.5						12.0	1	
2	晴	30.8	24.2	0.7	6.5						12.1	1	
3	晴	31.1	24.6	0.6	6.5						12.4	2	
4	晴	31.2	25.0	0.5	6.4						13.0	0	
5	晴	31.8	25.4	0.5	6.4						13.3	1	
6	晴	32.7	25.8	0.6	6.4						14.3	1	
7	晴	32.3	26.2	0.6	6.5						16.3	1	
8	晴	32.2	26.5	0.5	6.5						18.1	0	
9	晴	31.8	26.7	0.4	6.5	33.3	44.8	114.5	16.7	0.10	19.8	0	
10	晴	30.9	26.8	0.2	6.5						20.7	0	
11	晴	31.3	26.7	0.1	6.5						21.1	0	
12	晴	31.8	26.7	0.1	6.5						18.7	0	
13	晴	31.5	26.8	0.2	6.5	32.3	38.9	110.0	14.2	0.10	17.5	0	
14	晴	32.5	26.8	0.2	6.5						17.1	0	
15	曇	32.4	26.5	0.2	6.5						16.6	0	
16	曇	29.9	26.1	0.5	6.4						16.4	0	
17	晴	29.6	25.8	0.4	6.4						14.1	0	
18	晴	29.5	25.8	0.3	6.4						14.0	0	
19	曇	28.5	25.7	0.5	6.4						14.2	0	
20	雨	27.2	25.3	0.9	6.4						14.5	2	
21	曇	28.0	25.0	0.7	6.4						13.8	1	
22	曇	27.6	24.8	1.3	6.4						13.2	3	
23	曇	26.5	24.5	1.1	6.4	27.5	30.5	77.5	8.8	0.10	13.0	2	
24	曇	25.8	24.1	0.7	6.4						11.9	1	
25	晴	25.2	23.8	0.5	6.4						12.3	0	
26	晴	25.2	23.6	0.7	6.4						12.4	1	
27	曇	24.5	23.5	0.7	6.4						12.7	1	
28	雨	25.3	23.2	0.9	6.4						12.3	1	
29	曇	26.5	23.0	0.9	6.4						11.7	2	
30	曇	24.9	22.8	0.8	6.4						11.4	1	
31	晴	26.2	22.5	0.9	6.4						11.4	1	
最大	——	32.7	26.8	1.3	6.5	33.3	44.8	114.5	16.7	0.10	21.1	3	——
最小	——	24.5	22.5	0.1	6.4	27.5	30.5	77.5	8.8	0.10	11.4	0	
平均	——	29.2	25.1	0.6	6.4	31.0	38.1	100.7	13.2	0.10	14.6	1	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値  
 測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
 他項目は日野川地区水道管理事務所にて測定