

県営第一工業用水道 水質試験結果表

2019年9月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	25.6	22.6	0.6	6.4						11.6	1	
2	雨	25.7	22.5	0.9	6.4						11.8	2	
3	晴	27.7	22.7	0.9	6.4						12.0	1	
4	曇	27.3	23.1	0.9	6.4	27.8	35.2	78.0	8.8	0.10	12.2	9	
5	曇	28.3	23.1	2.6	6.3						11.5	12	
6	晴	28.9	23.3	0.8	6.3						11.7	1	
7	晴	29.0	23.4	0.6	6.3						12.0	1	
8	晴	30.0	23.8	0.5	6.3						12.2	0	
9	晴	29.4	24.3	1.1	6.3						12.4	5	
10	晴	29.5	24.8	1.3	6.4						12.7	4	
11	晴	28.0	25.0	0.8	6.3						13.5	1	
12	晴	24.7	24.6	0.6	6.3						15.0	1	
13	曇	23.7	23.8	0.5	6.3	29.5	38.2	96.0	12.0	0.10	15.2	1	
14	曇	25.1	23.4	0.4	6.3						16.1	0	
15	晴	26.4	23.5	0.3	6.3						16.5	0	
16	晴	26.0	23.8	0.3	6.4						17.6	0	
17	晴	25.6	23.8	0.5	6.4						18.2	0	
18	晴	24.4	23.5	0.5	6.4						18.5	0	
19	晴	21.5	23.1	0.5	6.4						18.5	0	
20	曇	20.6	22.5	0.6	6.3						18.4	0	
21	雨	19.5	22.1	0.5	6.3						18.6	0	
22	曇	21.8	21.7	0.5	6.3						17.9	0	
23	曇	26.3	21.9	0.5	6.3						17.0	0	
24	雨	21.9	22.1	0.6	6.3						16.5	1	
25	晴	21.8	22.0	0.6	6.3	30.2	44.2	100.5	12.3	0.10	16.1	1	
26	晴	22.7	21.9	0.6	6.3						15.7	1	
27	晴	24.6	22.2	0.6	6.3						16.0	1	
28	曇	24.1	22.4	0.6	6.4						17.0	0	
29	曇	25.2	22.5	0.9	6.4						17.6	2	
30	晴	25.0	22.6	0.7	6.4						16.3	1	
最大	——	30.0	25.0	2.6	6.4	30.2	44.2	100.5	12.3	0.10	18.6	12	——
最小	——	19.5	21.7	0.3	6.3	27.8	35.2	78.0	8.8	0.10	11.5	0	
平均	——	25.3	23.1	0.7	6.3	29.2	39.2	91.5	11.0	0.10	15.2	2	

標準値
 測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定

20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値