

県営第一工業用水道 水質試験結果表

2019年10月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	24.7	22.7	0.7	6.4						17.0	1	
2	曇	25.3	22.9	0.8	6.4						17.7	1	
3	曇	26.2	22.9	0.7	6.4						18.3	1	
4	雨	21.3	22.5	1.4	6.3	31.2	42.4	110.0	14.6	0.10	18.8	3	
5	曇	21.7	21.9	0.9	6.3						16.5	1	
6	曇	20.2	21.6	0.7	6.3						15.4	1	
7	晴	20.3	21.2	0.8	6.3						15.2	1	
8	雨	19.9	21.0	1.1	6.3						15.1	2	
9	晴	17.0	20.4	1.1	6.3						14.4	2	
10	晴	19.3	19.7	1.0	6.4						14.3	1	
11	曇	22.6	20.0	0.9	6.4						14.5	1	
12	雨	20.9	20.2	1.2	6.3						14.7	4	
13	曇	18.1	19.9	2.5	6.3						12.3	5	
14	曇	17.3	19.2	1.3	6.3						11.7	2	
15	晴	16.2	18.6	1.2	6.3	24.1	27.1	73.0	8.2	0.10	11.7	2	
16	晴	14.6	18.0	0.7	6.3						11.9	1	
17	晴	16.6	17.7	0.6	6.3						12.3	1	
18	曇	17.8	17.7	0.6	6.3						12.4	1	
19	曇	19.5	17.9	0.7	6.3						12.4	1	
20	晴	18.9	18.1	0.6	6.3						11.9	1	
21	曇	17.7	18.0	0.7	6.3						12.0	1	
22	晴	18.9	17.9	0.8	6.3						12.1	1	
23	晴	18.3	17.9	0.6	6.3	24.0	34.2	80.0	8.5	0.10	12.1	1	
24	雨	18.8	18.0	0.6	6.3						12.2	1	
25	雨	17.2	17.9	1.0	6.3						12.3	2	
26	曇	17.8	17.5	0.9	6.3						10.8	2	
27	曇	15.8	17.3	0.5	6.3						10.9	0	
28	晴	15.5	17.1	0.8	6.3						11.3	1	
29	雨	14.9	16.8	0.8	6.3						11.5	1	
30	曇	16.3	16.5	0.9	6.3						11.7	1	
31	晴	15.6	16.5	0.9	6.3						11.9	2	
最大	——	26.2	22.9	2.5	6.4	31.2	42.4	110.0	14.6	0.10	18.8	5	——
最小	——	14.6	16.5	0.5	6.3	24.0	27.1	73.0	8.2	0.10	10.8	0	
平均	——	18.9	19.2	0.9	6.3	26.4	34.6	87.7	10.4	0.10	13.5	1	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
 他項目は日野川地区水道管理事務所にて測定