

県営第一工業用水道 水質試験結果表

2019年11月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	15.3	16.4	0.9	6.3						11.9	1	
2	晴	12.8	16.2	0.6	6.3						11.9	1	
3	晴	13.9	16.0	0.4	6.3						11.9	0	
4	曇	13.2	15.8	0.4	6.3						11.9	0	
5	晴	11.5	15.6	0.5	6.3						12.1	0	
6	晴	12.0	15.2	0.4	6.4	26.4	31.1	76.0	8.6	0.10	12.1	0	
7	晴	13.8	15.1	0.4	6.4						12.4	0	
8	晴	11.8	15.2	1.0	6.4						12.6	9	
9	晴	10.7	14.9	0.3	6.4						12.9	0	
10	晴	10.9	14.8	0.2	6.4						13.0	0	
11	晴	13.3	14.7	0.4	6.4						13.1	0	
12	晴	13.8	14.7	0.7	6.6						13.0	1	
13	晴	13.4	14.8	0.3	6.8						13.0	1	
14	曇	12.0	14.8	0.4	6.8						13.2	2	
15	晴	10.0	14.3	0.4	6.8	26.2	35.3	80.5	10.4	0.10	12.7	0	
16	晴	10.7	13.9	0.2	6.8						12.8	0	
17	晴	11.8	13.8	0.2	6.8						12.8	0	
18	晴	15.6	14.0	0.3	6.8						12.9	0	
19	曇	11.9	14.2	0.5	6.8						12.8	0	
20	曇	8.6	13.8	0.4	6.8						12.4	0	
21	晴	7.9	13.2	0.3	6.8						12.4	1	
22	晴	9.1	12.7	0.3	6.8						12.5	0	
23	晴	11.8	12.7	0.3	6.8						12.7	0	
24	曇	14.3	13.1	0.2	6.8						12.7	0	
25	曇	11.9	13.4	0.4	6.8	27.0	35.7	74.5	9.9	0.10	13.0	1	
26	曇	10.0	13.3	0.3	6.8						12.9	0	
27	曇	11.6	13.2	0.3	6.8						13.1	0	
28	曇	8.1	13.0	0.3	6.8						12.7	0	
29	晴	6.0	12.3	0.4	6.8						12.9	0	
30	晴	6.0	11.9	0.3	6.8						13.8	0	
最大	———	15.6	16.4	1.0	6.8	27.0	35.7	80.5	10.4	0.10	13.8	9	———
最小	———	6.0	11.9	0.2	6.3	26.2	31.1	74.5	8.6	0.10	11.9	0	
平均	———	11.5	14.2	0.4	6.6	26.5	34.0	77.0	9.6	0.10	12.7	1	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定