

県営第一工業用水道 水質試験結果表

2019年12月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	9.0	11.7	0.2	6.9						13.7	0	
2	曇	12.5	11.9	0.5	6.9						13.9	1	
3	曇	8.6	12.0	0.8	6.8						12.7	1	
4	雨	7.5	11.7	0.7	6.8	23.5	31.9	77.5	10.2	0.10	12.3	1	
5	雨	6.5	11.2	0.6	6.8						11.4	0	
6	雨	4.8	10.8	0.4	6.8						11.0	0	
7	曇	5.7	10.6	0.2	6.8						11.0	0	
8	晴	7.0	10.6	0.2	6.8						11.3	0	
9	晴	6.4	10.6	0.3	6.8						11.7	0	
10	晴	8.5	10.6	0.3	6.8						11.7	0	
11	晴	8.4	10.7	0.3	6.8						12.1	0	
12	曇	7.9	10.8	0.3	6.8						12.0	0	
13	晴	6.6	10.7	0.3	6.8						12.2	0	
14	晴	6.8	10.5	0.2	6.8						12.1	0	
15	晴	6.9	10.2	0.3	6.8						12.0	0	
16	晴	5.8	10.1	0.3	6.8	23.8	31.4	78.5	9.7	0.10	12.1	0	
17	曇	11.6	10.2	0.3	6.8						12.2	0	
18	雨	11.2	10.6	0.4	6.8						12.3	0	
19	晴	8.2	10.8	0.5	6.8						11.7	2	
20	雨	8.4	10.8	0.4	6.8						11.8	0	
21	曇	8.1	10.6	0.5	6.8						11.7	0	
22	曇	6.8	10.5	0.2	6.8						11.4	0	
23	晴	8.0	10.5	0.3	6.8						11.4	0	
24	晴	6.3	10.4	0.6	6.8						11.2	1	
25	晴	6.0	10.2	0.5	6.8	22.2	27.5	75.5	9.1	0.10	11.0	1	
26	雨	7.6	10.1	0.4	6.8						11.2	0	
27	雨	7.5	10.1	0.7	6.8						11.2	1	
28	晴	4.9	9.9	0.4	6.8						10.7	0	
29	晴	6.4	9.7	0.3	6.8						10.8	0	
30	雨	8.8	9.7	0.3	6.8						11.0	0	
31	曇	6.7	10.0	0.3	6.8						11.2	0	
最大	——	12.5	12.0	0.8	6.9	23.8	31.9	78.5	10.2	0.10	13.9	2	——
最小	——	4.8	9.7	0.2	6.8	22.2	27.5	75.5	9.1	0.10	10.7	0	
平均	——	7.6	10.6	0.4	6.8	23.2	30.3	77.2	9.7	0.10	11.7	0	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定