

県営第一工業用水道 水質試験結果表

2020年1月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	4.4	9.9	0.3	6.8						11.3	0	
2	曇	6.0	9.6	0.3	6.8						11.5	0	
3	曇	7.1	9.4	0.4	6.8						11.1	0	
4	曇	6.8	9.5	0.4	6.8						10.6	0	
5	曇	5.8	9.5	0.4	6.8						10.6	0	
6	晴	4.7	9.4	0.5	6.8						10.5	0	
7	曇	4.9	9.3	0.5	6.8						11.0	1	
8	曇	11.1	9.4	0.6	6.8						10.9	0	
9	晴	8.6	9.7	0.6	6.8						11.1	0	
10	晴	7.0	9.9	0.5	6.8	20.6	28.1	66.0	9.7	0.10	10.8	1	
11	晴	6.5	9.7	0.4	6.8						10.8	0	
12	曇	7.4	9.7	0.3	6.8						11.0	0	
13	曇	7.1	9.6	0.4	6.8						10.9	0	
14	晴	7.7	9.5	0.6	6.8						10.8	0	
15	曇	5.4	9.6	0.5	6.8	21.7	28.8	69.5	9.6	0.10	11.2	0	
16	曇	5.6	9.6	0.5	6.8						11.9	0	
17	曇	6.6	9.6	1.5	6.9						12.6	20	1時間36分
18	晴	5.9	8.8	1.5	7.1						10.4	9	
19	晴	6.3	8.5	1.3	7.1						10.3	6	
20	雨	6.7	8.8	2.1	7.0						10.5	8	
21	晴	4.9	9.2	1.3	6.9						12.5	3	
22	晴	5.0	8.6	1.6	7.2						12.5	6	
23	曇	8.5	8.5	4.2	7.2	22.4	26.7	63.0	8.2	0.14	9.5	10	
24	曇	9.3	9.3	1.5	6.9						11.4	4	
25	晴	5.6	9.3	0.7	6.9						11.6	1	
26	曇	7.3	9.4	0.5	6.9						12.0	0	
27	曇	5.9	9.4	0.6	6.9						12.0	0	
28	晴	8.6	9.3	2.0	7.1						12.6	11	
29	雨	9.7	9.4	3.9	7.2						9.7	9	
30	雨	7.5	9.5	3.6	6.9						11.4	7	
31	曇	3.9	9.3	1.8	6.8						10.3	3	
最大	——	11.1	9.9	4.2	7.2	22.4	28.8	69.5	9.7	0.14	12.6	20	——
最小	——	3.9	8.5	0.3	6.8	20.6	26.7	63.0	8.2	0.10	9.5	0	
平均	——	6.7	9.4	1.1	6.9	21.6	27.9	66.2	9.2	0.11	11.1	3	1時間36分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定