

県営第一工業用水道 水質試験結果表

2020年2月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	3.8	9.1	0.8	6.8						10.4	1	
2	曇	5.2	8.9	0.5	6.8						10.8	0	
3	晴	6.2	8.9	0.6	6.8						11.1	2	
4	晴	6.2	9.1	0.9	6.9						11.9	4	
5	雨	3.8	8.2	2.8	7.1						11.0	17	1時間54分
6	曇	-0.1	6.2	3.7	7.3						10.1	9	
7	曇	1.9	7.2	1.3	7.0	21.4	28.9	70.0	10.1	0.10	11.1	3	
8	曇	4.1	7.8	0.6	6.9						11.9	1	
9	曇	1.8	7.7	0.5	6.9						12.4	0	
10	雪	2.5	7.1	1.6	7.1						12.7	10	
11	晴	4.2	6.3	2.5	7.6						9.5	8	
12	曇	7.3	7.0	1.0	7.1						10.8	1	
13	曇	11.5	8.1	1.7	6.9						11.9	4	
14	曇	10.1	8.7	1.6	7.2	22.0	31.0	75.0	10.7	0.10	11.8	6	
15	曇	9.8	8.7	1.5	7.2						9.4	3	
16	雨	10.5	9.0	1.6	6.9						10.4	10	
17	曇	5.7	9.2	4.2	6.8						10.5	8	
18	曇	3.2	8.8	1.7	6.8						10.3	3	
19	晴	5.6	8.5	1.0	6.8						10.6	3	
20	曇	6.9	8.6	0.8	6.8						11.1	2	
21	晴	6.5	8.7	1.6	7.2	21.3	29.9	67.0	13.6	0.10	11.4	6	
22	雨	8.3	8.0	2.6	7.4						8.3	9	
23	曇	6.5	7.9	3.7	7.3						8.9	9	
24	晴	7.9	8.1	2.3	7.3						8.7	5	
25	曇	7.8	8.0	2.1	7.3						8.5	4	
26	晴	8.7	8.7	2.0	7.1						9.5	4	
27	晴	4.9	8.5	1.1	7.0						10.3	1	
28	晴	5.5	8.5	1.2	7.1						10.7	4	
29	晴	8.7	8.0	1.5	7.5						8.7	2	
最大	———	11.5	9.2	4.2	7.6	22.0	31.0	75.0	13.6	0.10	12.7	17	———
最小	———	-0.1	6.2	0.5	6.8	21.3	28.9	67.0	10.1	0.10	8.3	0	
平均	———	6.0	8.2	1.7	7.1	21.6	29.9	70.7	11.5	0.10	10.5	5	1時間54分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
 他項目は日野川地区水道管理事務所にて測定