

県営第一工業用水道 水質試験結果表

2020年3月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	9.2	9.0	1.1	7.2						9.5	2	
2	晴	9.4	9.1	1.0	7.1						10.2	1	
3	曇	8.2	9.3	1.4	7.0						10.4	5	
4	曇	7.7	8.9	1.7	7.2	23.3	31.1	70.0	9.4	0.10	11.1	6	
5	曇	6.2	8.9	3.6	7.0						10.3	8	
6	曇	5.8	8.9	1.3	7.1						11.1	2	
7	晴	6.4	7.9	1.5	7.5						8.9	2	
8	雨	9.3	8.9	3.1	7.2						9.2	11	
9	晴	11.3	9.6	1.6	7.0						10.4	3	
10	雨	11.9	9.9	1.2	7.0						10.7	2	
11	曇	9.2	10.1	2.0	6.9						10.5	4	
12	晴	7.2	9.9	1.0	6.9						10.1	1	
13	晴	9.6	9.9	1.4	7.0	20.8	27.8	63.5	8.8	0.10	10.4	6	
14	曇	8.6	9.4	1.9	7.3						8.3	4	
15	晴	6.5	9.1	1.5	7.2						8.6	2	
16	雨	4.0	8.1	3.6	7.2						8.8	8	
17	曇	6.6	7.7	1.7	7.2						9.4	4	
18	晴	11.0	9.3	3.7	6.9						10.9	13	
19	晴	14.6	10.1	2.0	7.0						10.3	5	
20	曇	9.6	9.8	2.2	7.2						9.3	4	
21	晴	10.8	9.8	1.4	7.2						9.2	2	
22	曇	11.0	9.9	1.3	7.2						9.4	3	
23	晴	8.8	10.2	1.6	7.2						9.5	3	
24	晴	7.0	9.9	1.1	7.1						10.3	2	
25	晴	6.8	9.7	0.9	7.0	22.7	28.7	64.0	8.8	0.10	10.6	1	
26	晴	12.3	10.3	0.9	7.0						11.0	2	
27	雨	14.3	10.7	1.9	7.2						9.3	7	
28	曇	10.6	10.8	3.2	6.9						10.4	7	
29	曇	7.2	10.5	1.4	6.9						10.6	2	
30	曇	9.6	10.3	0.9	6.9						10.6	1	
31	晴	12.9	10.4	0.8	6.9						10.6	1	
最大	——	14.6	10.8	3.7	7.5	23.3	31.1	70.0	9.4	0.10	11.1	13	——
最小	——	4.0	7.7	0.8	6.9	20.8	27.8	63.5	8.8	0.10	8.3	1	
平均	——	9.1	9.6	1.7	7.1	22.3	29.2	65.8	9.0	0.10	10.0	4	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定