

県営第一工業用水道 水質試験結果表

2020年6月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	25.2	19.1	1.3	6.7						15.5	2	
2	晴	24.7	20.9	2.0	6.9						15.1	4	
3	晴	24.6	21.1	2.1	6.9	29.9	34.0	88.5	10.5	0.10	12.7	3	
4	晴	26.0	20.6	1.7	6.7						13.9	3	
5	晴	26.7	21.4	1.5	6.7						14.2	2	
6	曇	23.2	21.6	1.5	6.8						14.3	3	
7	晴	21.8	21.3	1.7	6.8						13.5	2	
8	晴	24.6	21.8	2.0	6.8						13.9	4	
9	晴	27.8	22.1	1.7	6.7						17.3	4	
10	晴	28.0	22.7	1.8	6.7						17.1	3	
11	雨	26.0	22.5	2.4	6.8						13.8	5	
12	曇	25.8	21.8	2.2	6.8						15.0	4	
13	雨	23.1	21.5	1.7	6.7						15.0	3	
14	雨	24.3	20.9	1.8	6.7						14.3	11	0時間46分
15	曇	24.6	20.6	3.9	6.8	19.4	24.2	68.5	9.0	0.10	9.8	197	24時間00分
16	晴	23.2	20.5	4.5	7.2						8.8	34	7時間13分
17	晴	23.4	20.7	3.6	7.0						10.3	7	
18	曇	21.4	20.8	2.2	6.9						12.1	5	
19	曇	20.6	20.2	2.2	6.8						12.3	3	
20	曇	21.8	19.9	1.7	6.8						11.5	4	
21	晴	24.1	20.0	1.4	6.8						11.6	2	
22	曇	23.9	20.2	2.1	6.9						11.3	4	
23	晴	25.3	20.9	2.3	7.1						11.9	9	
24	晴	27.7	21.7	2.9	7.2						9.7	5	
25	晴	26.3	21.6	2.0	6.9	26.2	27.8	66.5	7.8	0.20	10.6	4	
26	雨	25.2	21.1	1.7	6.8						11.3	3	
27	曇	27.2	21.2	1.2	6.7						11.4	2	
28	曇	24.1	21.2	1.5	6.6						11.3	3	
29	晴	25.1	21.1	1.2	6.7						11.0	2	
30	雨	24.7	21.0	1.8	6.7						10.9	8	
最大	———	28.0	22.7	4.5	7.2	29.9	34.0	88.5	10.5	0.20	17.3	197	———
最小	———	20.6	19.1	1.2	6.6	19.4	24.2	66.5	7.8	0.10	8.8	2	
平均	———	24.7	21.1	2.1	6.8	25.2	28.7	74.5	9.1	0.13	12.7	12	31時間59分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定