

県営第一工業用水道 水質試験結果表

2020年9月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	29.9	26.6	2.2	7.2						10.5	4	
2	晴	31.4	26.3	3.4	7.3	29.0	29.4	67.0	6.6	0.10	10.4	9	
3	曇	32.4	25.6	2.5	7.3						10.6	5	
4	曇	28.3	25.0	2.4	7.3						10.5	4	
5	晴	29.2	25.4	2.2	7.3						10.6	5	
6	晴	30.1	26.1	2.0	7.3						10.8	4	
7	曇	31.3	24.9	2.3	7.3						10.7	5	
8	晴	31.1	24.9	3.1	7.2						10.7	6	
9	晴	26.2	24.5	2.3	7.1						11.9	4	
10	雨	25.0	23.9	2.9	7.1						11.4	8	
11	晴	25.8	23.9	3.5	7.1						11.1	9	
12	晴	28.5	24.7	3.6	7.0						11.3	10	
13	雨	24.7	24.5	2.2	7.1						11.7	5	
14	曇	22.6	22.9	2.9	7.2						10.6	6	
15	晴	22.8	22.8	2.8	7.2						10.9	5	
16	晴	25.1	23.3	2.2	7.1	31.8	31.2	69.0	7.1	0.10	11.2	5	
17	曇	26.7	23.6	2.1	7.1						11.3	10	
18	雨	22.8	22.8	4.7	6.7						11.5	13	
19	晴	22.8	22.4	1.9	6.7						11.8	4	
20	曇	22.0	22.0	1.5	6.8						11.6	3	
21	晴	21.8	22.1	1.5	7.0						11.5	3	
22	晴	21.6	21.6	1.7	7.1						11.6	3	
23	晴	23.7	22.2	1.9	7.1						11.5	3	
24	曇	24.9	22.7	1.9	7.2						11.3	3	
25	雨	21.7	22.0	3.7	6.9	31.0	31.3	64.0	7.2	0.10	10.7	37	5時間21分
26	雨	21.6	21.1	3.7	6.6						10.7	21	2時間37分
27	曇	20.9	20.7	2.5	6.6						10.4	6	
28	晴	20.3	20.2	1.8	6.7						10.7	6	
29	晴	20.4	20.0	1.7	6.7						10.8	4	
30	晴	20.9	19.9	1.6	6.8						11.1	3	
最大	———	32.4	26.6	4.7	7.3	31.8	31.3	69.0	7.2	0.10	11.9	37	———
最小	———	20.3	19.9	1.5	6.6	29.0	29.4	64.0	6.6	0.10	10.4	3	
平均	———	25.2	23.3	2.5	7.0	30.6	30.6	66.7	7.0	0.10	11.0	7	7時間58分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定