

県営第一工業用水道 水質試験結果表

2020年10月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	20.9	20.1	1.5	6.7						11.1	2	
2	晴	20.4	20.0	1.1	6.8						11.1	3	
3	曇	21.2	19.8	1.0	6.9						11.1	1	
4	曇	22.2	19.7	1.1	6.9						11.2	2	
5	曇	19.6	19.7	1.4	6.9						11.1	3	
6	曇	17.3	18.9	1.4	6.9						11.1	2	
7	晴	17.8	18.8	1.0	6.9	29.1	31.7	70.5	7.5	0.10	11.5	2	
8	雨	16.3	18.6	1.0	6.9						11.4	2	
9	曇	17.0	18.0	1.1	6.8						11.2	3	
10	曇	20.6	18.2	1.1	6.8						11.3	3	
11	曇	21.4	18.8	1.0	6.8						11.3	2	
12	晴	21.7	19.3	0.9	6.8						11.3	2	
13	晴	20.3	19.7	1.2	7.0						11.6	2	
14	晴	18.9	19.1	1.2	7.2						10.7	2	
15	晴	17.7	18.7	1.1	7.1	30.4	30.5	59.5	7.0	0.10	10.9	2	
16	晴	16.2	17.9	0.7	7.1						10.8	1	
17	曇	14.1	17.4	0.6	7.2						10.8	1	
18	晴	14.3	16.6	0.6	7.2						10.8	0	
19	曇	14.5	16.8	0.7	7.0						11.3	1	
20	晴	15.5	17.0	0.8	7.0						11.3	2	
21	晴	16.7	17.4	1.3	7.0						11.9	2	
22	曇	18.6	17.6	1.1	6.9	30.7	33.1	71.0	8.1	0.10	11.9	4	
23	雨	16.2	17.6	2.4	6.8						11.8	5	
24	曇	12.7	16.9	1.5	6.7						10.8	3	
25	曇	12.9	16.4	1.8	6.7						10.6	4	
26	晴	14.0	15.8	1.0	6.7						10.3	2	
27	晴	13.1	15.6	0.8	6.8						10.8	2	
28	曇	13.1	15.3	0.8	6.8						11.1	2	
29	晴	13.4	15.4	1.1	7.0						11.3	8	
30	晴	12.3	14.7	1.0	7.1						10.6	2	
31	晴	10.9	14.2	0.7	7.1						10.6	2	
最大	——	22.2	20.1	2.4	7.2	30.7	33.1	71.0	8.1	0.10	11.9	8	——
最小	——	10.9	14.2	0.6	6.7	29.1	30.5	59.5	7.0	0.10	10.3	0	
平均	——	16.8	17.7	1.1	6.9	30.1	31.8	67.0	7.5	0.10	11.1	2	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
水温、濁度、pH（3項目ともに日平均）は配水池管理棟
他項目は日野川地区水道管理事務所にて測定