

県営第一工業用水道 水質試験結果表

2020年11月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	14.4	14.4	0.6	7.0						10.8	1	
2	雨	15.2	15.0	1.1	7.0						11.0	4	
3	晴	13.4	15.2	2.2	6.8						10.9	5	
4	晴	10.0	14.6	1.2	6.8	28.0	31.0	72.0	7.7	0.10	11.3	3	
5	晴	11.0	14.3	0.7	6.8						11.3	1	
6	曇	13.1	14.2	0.5	6.8						11.5	2	
7	曇	15.9	14.5	1.2	6.9						11.5	15	
8	曇	15.6	14.9	0.5	6.8						11.3	1	
9	晴	11.1	14.6	0.5	6.8						11.6	1	
10	曇	9.5	14.1	0.7	6.8						11.7	2	
11	晴	9.4	13.8	0.6	6.8						11.8	1	
12	晴	10.4	13.5	0.6	6.8						11.8	1	
13	晴	12.4	13.6	0.5	6.8	27.6	31.1	75.0	8.1	0.10	11.6	1	
14	晴	11.0	13.7	0.5	6.9						11.0	0	
15	晴	13.1	13.2	0.5	7.0						10.8	1	
16	晴	14.6	14.0	0.6	6.9						11.2	1	
17	晴	12.9	14.0	0.8	6.9						11.5	2	
18	晴	16.3	14.3	0.7	6.8						12.0	2	
19	晴	20.4	15.3	0.8	7.0						12.5	5	
20	曇	19.0	15.9	1.4	7.0						11.4	6	
21	曇	12.0	15.1	1.4	6.8						12.2	3	
22	晴	13.2	14.4	0.6	6.8						12.3	1	
23	曇	12.4	14.6	0.7	6.7						12.3	1	
24	晴	9.6	14.0	0.7	6.7						12.1	1	
25	晴	10.6	13.6	0.7	6.7	28.1	31.8	72.0	8.7	0.10	11.9	1	
26	曇	10.9	13.4	0.5	6.7						12.1	0	
27	晴	12.2	13.4	0.6	7.0						12.3	2	
28	雨	9.0	13.0	3.4	6.9						10.8	12	
29	晴	9.3	12.6	1.2	6.8						11.2	3	
30	曇	9.4	12.6	1.2	6.7						11.5	4	
最大	———	20.4	15.9	3.4	7.0	28.1	31.8	75.0	8.7	0.10	12.5	15	———
最小	———	9.0	12.6	0.5	6.7	27.6	31.0	72.0	7.7	0.10	10.8	0	
平均	———	12.6	14.1	0.9	6.8	27.9	31.3	73.0	8.2	0.10	11.6	3	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定