

県営第一工業用水道 水質試験結果表

2021年2月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	5.1	6.8	0.5	6.6						10.8	0	
2	曇	6.1	7.0	1.1	6.6						10.5	3	
3	雪	2.5	7.1	0.9	6.6						9.9	2	
4	雪	2.9	6.9	0.6	6.6						10.1	0	
5	曇	5.0	6.8	0.4	6.6	18.4	25.5	66.5	11.7	0.10	10.6	0	
6	晴	7.8	7.2	0.3	6.6						10.7	1	
7	曇	7.0	7.4	0.3	6.6						10.6	0	
8	雪	2.9	7.6	0.4	6.6						10.6	0	
9	雪	1.7	7.4	0.5	6.6						10.7	0	
10	曇	4.6	7.3	0.3	6.6						11.1	1	
11	晴	6.3	7.5	0.3	6.5						11.6	0	
12	曇	7.2	7.7	0.3	6.5						11.5	0	
13	晴	9.9	7.9	0.2	6.5						11.9	0	
14	晴	11.3	7.9	0.4	6.6						10.8	0	
15	雨	10.5	8.1	3.0	6.6	18.5	23.9	67.5	9.7	0.10	9.9	43	0時間13分
16	雨	5.4	7.9	4.2	6.6						8.3	34	12時間26分
17	雪	0.1	7.5	2.4	6.6						8.7	5	
18	雪	0.2	6.8	1.2	6.6						8.9	2	
19	曇	2.2	6.3	0.7	6.6						9.5	2	
20	晴	5.8	6.4	0.8	6.6						9.7	2	
21	晴	9.8	6.6	1.0	6.6						9.6	2	
22	晴	11.5	7.2	0.7	6.6						9.5	1	
23	曇	6.6	7.7	0.6	6.6						9.4	1	
24	曇	3.5	7.7	0.5	6.6						9.3	0	
25	晴	4.2	7.3	0.4	6.6	18.3	23.8	56.5	9.3	0.10	9.5	0	
26	雨	6.2	7.3	0.4	6.6						9.8	0	
27	晴	4.2	7.3	0.2	6.6						10.2	0	
28	晴	6.5	7.2	0.2	6.6						10.4	0	
最大	———	11.5	8.1	4.2	6.6	18.5	25.5	67.5	11.7	0.10	11.9	43	———
最小	———	0.1	6.3	0.2	6.5	18.3	23.8	56.5	9.3	0.10	8.3	0	
平均	———	5.6	7.3	0.8	6.6	18.4	24.4	63.5	10.2	0.10	10.1	4	12時間39分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定