

県営第一工業用水道 水質試験結果表

2021年3月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	12.5	7.5	0.4	6.6						10.2	0	
2	雨	8.9	8.2	0.8	6.6						10.3	3	
3	晴	4.6	8.1	1.3	6.6	17.3	22.4	56.5	8.8	0.10	9.1	3	
4	晴	8.8	8.0	0.7	6.6						9.1	1	
5	曇	10.3	8.2	0.8	6.6						9.3	4	
6	雨	8.6	8.4	1.0	6.6						9.2	2	
7	晴	6.3	8.4	0.7	6.6						8.9	1	
8	曇	6.5	8.3	0.9	6.6						8.8	2	
9	晴	7.2	8.2	0.6	6.6						9.2	0	
10	晴	7.5	8.5	0.5	6.6						9.5	2	
11	晴	7.7	8.6	0.3	6.5						9.7	0	
12	曇	10.3	8.8	0.3	6.5						10.0	0	
13	雨	9.5	8.9	1.0	6.5						9.9	3	
14	曇	8.2	8.9	1.4	6.6						9.1	3	
15	晴	8.4	8.9	1.2	6.6	18.4	23.1	56.0	8.1	0.10	8.8	2	1時間29分
16	曇	9.6	8.8	1.1	6.6						8.9	1	1時間25分
17	晴	7.8	9.0	0.6	6.6						9.1	0	
18	晴	7.1	9.1	0.4	6.6						9.4	1	
19	晴	8.8	9.2	0.3	6.6						9.2	0	
20	晴	12.0	9.3	0.4	6.6						9.0	0	
21	雨	12.3	9.7	0.9	6.6						9.1	1	
22	雨	8.0	9.7	1.6	6.6						9.0	3	
23	晴	8.6	9.6	0.9	6.6						9.1	1	
24	晴	12.4	9.6	0.7	6.6						9.1	2	
25	曇	12.0	9.9	0.4	6.5	19.7	24.3	54.5	8.4	0.10	9.5	0	0時間51分
26	曇	10.0	10.0	0.3	6.5						9.7	0	
27	晴	12.3	10.1	0.3	6.5						9.8	2	
28	雨	15.4	10.3	0.4	6.5						9.6	0	
29	晴	16.6	10.8	1.5	6.5						9.2	4	
30	晴	14.9	11.1	0.7	6.5						9.2	2	
31	晴	11.7	11.1	0.6	6.5						9.1	1	
最大	——	16.6	11.1	1.6	6.6	19.7	24.3	56.5	8.8	0.10	10.3	4	——
最小	——	4.6	7.5	0.3	6.5	17.3	22.4	54.5	8.1	0.10	8.8	0	
平均	——	9.8	9.1	0.7	6.6	18.5	23.3	55.7	8.4	0.10	9.3	1	3時間45分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定