

県営第一工業用水道 水質試験結果表

2021年4月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	11.9	11.2	0.5	6.5						9.5	1	
2	晴	16.6	11.4	0.4	6.5						9.9	0	
3	晴	17.7	11.8	0.4	6.5						9.7	0	
4	雨	15.8	12.2	0.5	6.5						9.5	0	
5	曇	10.1	12.1	1.2	6.5						9.0	2	
6	晴	10.1	11.8	0.8	6.5						9.5	1	
7	晴	11.7	11.8	0.5	6.5	20.2	26.0	51.0	8.8	0.10	10.0	1	
8	晴	11.4	11.9	0.4	6.5						10.4	1	
9	晴	8.4	11.7	1.1	6.9						11.0	3	
10	晴	7.9	10.3	1.5	7.2						7.9	2	
11	晴	10.9	11.5	1.2	6.9						8.5	2	
12	晴	15.6	12.5	1.1	6.8						9.1	2	
13	雨	17.3	12.6	1.0	6.7						9.8	1	
14	曇	10.8	12.5	1.1	6.6						10.3	2	
15	晴	9.6	12.1	0.8	6.5	21.4	28.7	55.0	9.0	0.10	10.6	3	
16	曇	14.6	12.4	0.7	6.5						11.2	1	
17	雨	13.3	12.7	0.6	6.4						13.0	2	
18	雨	9.6	12.5	1.5	6.4						11.8	3	
19	晴	11.8	12.0	1.3	6.4						10.9	2	
20	晴	14.0	12.0	0.8	6.4						11.0	1	
21	晴	14.7	12.5	0.7	6.4	21.3	28.7	70.5	10.1	0.10	11.2	1	
22	晴	14.2	12.8	0.6	6.4						11.5	1	
23	晴	15.1	14.0	1.6	6.8						11.9	6	
24	晴	17.6	14.7	2.5	7.0						9.1	5	
25	晴	14.4	15.1	2.5	6.8						9.6	5	
26	晴	11.3	13.3	2.1	6.7						10.1	4	
27	晴	14.8	13.5	2.1	6.7						10.7	4	
28	雨	16.3	14.0	2.1	6.6						11.5	4	
29	雨	14.0	13.9	2.3	6.4						12.4	5	
30	曇	14.5	13.6	1.2	6.4						11.3	2	
最大	——	17.7	15.1	2.5	7.2	21.4	28.7	70.5	10.1	0.10	13.0	6	——
最小	——	7.9	10.3	0.4	6.4	20.2	26.0	51.0	8.8	0.10	7.9	0	
平均	——	13.2	12.5	1.2	6.6	21.0	27.8	58.8	9.3	0.10	10.4	2	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
他項目は日野川地区水道管理事務所にて測定