

県営第一工業用水道 水質試験結果表

2021年6月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	22.0	17.1	1.1	6.4						10.3	2	
2	曇	24.0	17.6	0.9	6.4	23.4	27.8	71.0	9.3	0.10	10.7	1	
3	晴	24.5	17.9	0.8	6.4						11.2	1	
4	雨	20.3	18.0	0.8	6.3						11.3	2	
5	晴	21.2	17.9	0.9	6.3						10.7	2	
6	曇	23.1	18.1	1.7	6.6						9.8	9	
7	晴	25.4	19.2	1.8	6.6						9.9	4	
8	晴	23.0	19.1	1.4	6.6						10.3	2	
9	晴	22.6	19.4	1.5	6.6						10.7	2	
10	晴	27.2	20.4	1.4	6.6						11.0	3	
11	晴	26.5	20.6	1.4	6.5						11.7	10	
12	曇	26.4	20.5	1.2	6.5						12.4	1	
13	雨	23.9	20.2	1.3	6.5						12.1	2	
14	曇	24.4	20.6	1.5	6.5						12.1	2	
15	曇	25.1	21.1	1.6	6.5						12.3	3	
16	曇	23.2	20.8	2.2	6.4	27.8	32.8	73.5	9.9	0.13	12.5	22	1時間02分
17	晴	23.1	20.4	3.9	6.3						12.6	27	6時間59分
18	曇	23.4	20.2	1.3	6.3						12.9	3	
19	雨	21.3	20.0	2.0	6.3						13.0	7	
20	曇	22.0	19.7	1.5	6.3						12.4	3	
21	晴	24.0	19.7	1.5	6.3						12.2	3	
22	曇	22.8	19.9	1.5	6.3						12.7	2	
23	曇	23.0	20.0	1.3	6.3	28.3	36.9	88.5	11.6	0.10	14.5	3	
24	晴	24.3	20.6	1.3	6.3						16.3	5	
25	曇	24.4	21.0	1.3	6.3						15.6	4	
26	晴	24.8	20.8	3.3	6.2						17.3	12	
27	曇	24.0	20.9	1.0	6.3						15.1	2	
28	晴	25.1	21.2	1.3	6.3						14.2	3	
29	曇	23.6	21.2	1.4	6.3						14.5	3	
30	曇	26.0	21.2	1.5	6.3						14.5	3	
最大	——	27.2	21.2	3.9	6.6	28.3	36.9	88.5	11.6	0.13	17.3	27	——
最小	——	20.3	17.1	0.8	6.2	23.4	27.8	71.0	9.3	0.10	9.8	1	
平均	——	23.8	19.8	1.5	6.4	26.5	32.5	77.7	10.3	0.11	12.6	5	8時間01分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定