

県営第一工業用水道 水質試験結果表

2021年12月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	8.8	11.5	1.2	6.6						11.2	2	
2	曇	6.0	11.3	0.8	6.6						11.3	0	
3	曇	8.2	10.9	0.6	6.6	20.9	27.7	70.5	10.1	0.10	10.7	0	
4	雨	6.8	10.9	2.4	6.6						10.7	36	1時間27分
5	曇	6.0	10.5	6.7	6.7						9.4	23	4時間12分
6	雨	7.5	10.5	2.6	6.7						9.8	4	
7	雨	10.4	10.9	1.7	6.7						10.0	3	
8	曇	11.1	11.1	2.0	6.6						9.8	2	
9	晴	8.8	11.1	1.1	6.6						9.5	1	
10	晴	9.1	11.0	0.8	6.6						9.7	0	
11	晴	9.7	11.0	0.5	6.6						9.8	0	
12	曇	10.7	11.1	0.5	6.6						10.1	1	
13	雨	5.8	11.1	0.8	6.6						10.3	2	
14	晴	5.0	10.6	1.1	6.6						10.1	6	
15	曇	6.6	10.3	0.5	6.5	21.8	26.5	68.5	8.5	0.10	10.1	0	
16	曇	9.2	10.2	0.5	6.5						10.4	0	
17	曇	7.1	10.5	0.8	6.5						10.5	1	
18	雪	1.2	10.0	0.8	6.4						10.1	1	
19	雪	1.7	9.2	0.5	6.4						10.3	0	
20	曇	2.9	8.7	0.6	6.4						10.8	0	
21	曇	4.8	8.5	0.6	6.4						10.5	0	
22	曇	4.7	8.7	0.6	6.4	19.6	25.9	62.0	9.9	0.10	10.3	0	
23	晴	4.2	8.8	0.5	6.4						10.1	0	
24	晴	8.7	8.9	0.4	6.4						10.0	0	
25	雨	4.9	9.2	0.4	6.4						10.2	0	
26	雪	0.1	8.9	0.3	6.4						10.0	0	
27	雪	0.8	8.2	0.2	6.4						10.3	0	
28	雪	2.2	7.6	0.3	6.4						10.5	0	
29	晴	3.4	7.4	0.3	6.4						11.0	0	
30	雨	4.7	7.5	0.3	6.4						10.8	0	
31	雪	0.9	7.3	0.3	6.4						11.1	0	
最大	——	11.1	11.5	6.7	6.7	21.8	27.7	70.5	10.1	0.10	11.3	36	——
最小	——	0.1	7.3	0.2	6.4	19.6	25.9	62.0	8.5	0.10	9.4	0	
平均	——	5.9	9.8	1.0	6.5	20.8	26.7	67.0	9.5	0.10	10.3	3	5時間39分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
 他項目は日野川地区水道管理事務所にて測定