

県営第一工業用水道 水質試験結果表

2022年1月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	雪	0.7	7.1	0.2	6.4						11.4	0	
2	晴	1.7	7.0	0.2	6.4						11.6	0	
3	曇	3.1	7.1	0.2	6.4						11.7	0	
4	曇	3.5	7.3	0.3	6.4						11.6	0	
5	雪	1.7	7.3	0.4	6.4						11.4	1	
6	曇	2.0	7.5	0.4	6.4						11.4	0	
7	曇	3.3	7.6	0.6	6.4	20.9	34.5	66.0	11.5	0.10	11.7	8	
8	曇	4.1	7.1	1.2	6.6						10.3	1	
9	曇	4.2	6.8	1.3	6.6						10.1	1	
10	晴	4.5	7.3	0.8	6.5						10.6	0	
11	雨	4.2	7.3	2.0	6.5						10.8	6	
12	雪	1.8	7.3	2.0	6.3						10.9	4	
13	雪	1.5	7.0	0.9	6.4	19.3	27.4	57.0	11.6	0.10	11.0	2	
14	曇	1.4	6.6	0.6	6.4						11.7	0	
15	曇	2.2	6.6	0.5	6.4						12.5	0	
16	晴	2.7	6.8	0.4	6.4						12.4	0	
17	雨	3.1	6.7	1.1	6.3						12.8	3	
18	雪	1.1	6.4	1.4	6.4						11.9	33	3時間27分
19	雪	1.4	6.4	1.1	6.4						12.2	3	0時間05分
20	雪	1.1	6.0	1.1	6.4						12.3	3	
21	雪	0.8	5.5	1.0	6.5						12.8	2	
22	曇	1.8	5.4	1.6	6.6						11.9	2	
23	曇	1.2	5.4	1.2	6.5						11.9	1	
24	曇	3.1	5.9	1.3	6.5	21.7	30.8	74.0	14.6	0.10	12.3	1	
25	晴	2.1	6.0	1.3	6.5						12.5	1	
26	曇	3.4	6.4	1.0	6.4						12.7	2	
27	晴	3.7	6.7	1.5	6.4						12.9	3	
28	曇	2.8	6.9	0.7	6.4						13.0	0	
29	雨	3.9	7.0	0.7	6.4						12.9	0	
30	晴	3.0	7.0	0.4	6.4						13.1	0	
31	曇	2.4	7.0	0.5	6.4						12.8	1	
最大	——	4.5	7.6	2.0	6.6	21.7	34.5	74.0	14.6	0.10	13.1	33	——
最小	——	0.7	5.4	0.2	6.3	19.3	27.4	57.0	11.5	0.10	10.1	0	
平均	——	2.5	6.7	0.9	6.4	20.6	30.9	65.7	12.6	0.10	11.9	3	3時間32分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定