

県営第一工業用水道 水質試験結果表

2022年2月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	p H	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	3.7	7.2	0.6	6.4						13.3		1
2	曇	2.9	7.2	0.8	6.4						14.2		1
3	曇	3.2	7.0	0.9	6.4						14.3	0	
4	曇	2.9	7.0	0.7	6.4	21.6	32.3	80.5	15.6	0.10	14.1	0	
5	雪	1.1	6.6	0.6	6.4						14.0	0	
6	雪	0.9	6.1	0.6	6.4						14.3	1	
7	晴	1.8	6.1	0.8	6.4						14.5	1	
8	曇	3.2	6.0	1.4	6.5						13.4	2	
9	晴	3.1	6.3	1.3	6.6						12.7	1	
10	曇	3.6	6.4	1.2	6.6						13.3	1	
11	晴	3.0	6.6	0.8	6.6						13.3	0	
12	晴	3.5	6.6	0.7	6.5						13.7	0	
13	曇	3.5	6.8	0.5	6.5						13.8	0	
14	曇	5.2	7.0	0.6	6.5						13.7	1	
15	曇	5.1	7.1	1.2	6.4						13.6	2	
16	雪	1.3	6.6	1.2	6.4	22.2	34.4	86.5	17.1	0.10	15.1	2	
17	曇	0.3	5.7	0.9	6.4						15.3	1	
18	曇	2.6	5.2	1.5	6.5						13.7	1	
19	曇	1.9	5.5	1.2	6.4						13.9	1	
20	曇	2.3	5.8	0.8	6.4						14.6	0	
21	曇	0.9	5.6	0.7	6.4						14.9	0	
22	雪	1.2	5.3	1.0	6.4						14.7	1	
23	雪	0.9	5.4	1.2	6.4						15.8	4	
24	雪	1.3	5.7	1.2	6.4	23.5	37.7	92.0	18.5	0.10	16.5	1	
25	雪	2.9	5.4	2.9	6.7						16.9	23	3時間08分
26	晴	5.2	5.6	2.1	6.7						12.3	3	
27	雨	5.2	5.7	2.0	6.6						12.9	3	
28	曇	5.5	5.9	1.5	6.4						13.2	2	
最大	——	5.5	7.2	2.9	6.7	23.5	37.7	92.0	18.5	0.10	16.9	23	——
最小	——	0.3	5.2	0.5	6.4	21.6	32.3	80.5	15.6	0.10	12.3	0	
平均	——	2.8	6.2	1.1	6.5	22.4	34.8	86.3	17.1	0.10	14.1	2	3時間08分

標準値 20以下 6.5～8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場

水温、濁度、p H（3項目ともに日平均）は配水池管理棟

他項目は日野川地区水道管理事務所にて測定