

県営第一工業用水道 水質試験結果表

2022年3月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	4.1	5.9	1.0	6.4						14.2	1	
2	曇	5.1	6.1	1.3	6.5	22.3	33.4	81.0	16.2	0.10	15.0	4	
3	曇	5.9	6.0	1.6	6.5						12.6	2	
4	晴	5.4	6.3	0.9	6.4						13.4	1	
5	晴	6.9	6.6	0.6	6.4						13.6	0	
6	雪	3.4	6.7	0.6	6.4						13.4	0	
7	曇	4.1	6.5	0.9	6.5						13.7	3	
8	晴	3.8	6.2	1.4	6.6						11.9	3	
9	晴	5.1	6.6	1.0	6.5						14.1	2	
10	晴	6.8	6.6	1.0	6.5						12.6	2	
11	晴	9.7	7.2	1.4	6.6						14.2	7	
12	晴	12.3	7.4	2.8	6.6						10.9	6	
13	曇	14.9	7.9	3.3	6.4						11.8	6	
14	雨	13.4	8.3	4.1	6.4						11.5	9	
15	曇	12.4	8.5	3.8	6.4						10.2	7	
16	晴	10.6	8.5	2.9	6.4						9.8	15	
17	曇	8.8	8.5	1.5	6.3	16.8	22.1	64.0	9.4	0.10	9.7	2	
18	雨	7.4	8.4	1.1	6.3						9.8	1	
19	曇	7.2	8.3	1.8	6.3						9.5	2	
20	曇	7.4	8.1	3.3	6.3						9.4	7	
21	晴	7.7	8.0	2.8	6.4						9.3	7	
22	雨	6.5	8.1	2.1	6.4						9.4	4	
23	曇	6.5	7.9	1.2	6.3	17.7	23.8	46.5	9.5	0.10	9.9	1	
24	曇	8.5	8.1	1.2	6.3						10.1	3	
25	晴	11.5	8.3	2.1	6.4						9.2	2	
26	雨	16.0	8.8	2.9	6.5						8.7	50	3時間07分
27	曇	11.8	9.4	1.4	6.4						8.4	81	24時間00分
28	晴	9.3	9.3	5.0	6.5						8.2	33	13時間08分
29	曇	10.8	9.2	4.3	6.5						8.1	15	
30	晴	14.9	9.9	0.5	6.5						8.1	13	
31	雨	10.9	10.1	3.8	6.6						8.0	14	
最大	——	16.0	10.1	5.0	6.6	22.3	33.4	81.0	16.2	0.10	15.0	81	——
最小	——	3.4	5.9	0.5	6.3	16.8	22.1	46.5	9.4	0.10	8.0	0	
平均	——	8.7	7.8	2.1	6.4	18.9	26.4	63.8	11.7	0.10	10.9	10	40時間15分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定