

県営第一工業用水道 水質試験結果表

2022年6月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	21.5	19.3	1.1	6.5						22.4	3	
2	晴	23.5	19.6	1.5	6.5						18.8	2	
3	晴	22.2	20.0	1.0	6.5	36.9	53.9	148.5	25.9	0.10	27.2	2	
4	晴	20.4	19.9	1.4	6.4						18.0	2	
5	曇	22.7	19.9	1.0	6.4						20.1	3	
6	雨	18.9	19.7	1.7	6.4						18.6	3	
7	雨	17.9	19.2	1.6	6.4						18.0	3	
8	雨	19.1	18.7	1.0	6.4						16.3	1	
9	晴	20.9	19.2	1.4	6.5						18.2	6	
10	晴	23.6	19.8	1.7	6.4						14.5	3	
11	曇	22.8	19.8	1.2	6.4						17.5	2	
12	曇	20.4	19.8	0.9	6.4						18.6	1	
13	晴	20.9	19.7	0.8	6.4						21.9	2	
14	曇	20.7	19.7	1.9	6.5						19.9	8	
15	曇	21.2	19.4	2.4	6.4	27.8	34.3	72.0	12.5	0.10	14.7	4	
16	曇	23.8	19.9	1.9	6.5						17.4	3	
17	晴	25.8	20.6	1.7	6.5						19.8	2	
18	曇	25.7	20.5	0.6	6.5						25.7	1	
19	晴	27.3	20.9	0.3	6.5						24.3	0	
20	晴	27.0	21.8	0.8	6.6						21.2	1	
21	曇	26.6	22.0	1.3	6.6						21.3	2	
22	曇	26.3	21.9	1.0	6.5	34.7	43.7	110.5	19.7	0.10	21.0	2	
23	晴	29.9	22.6	1.2	6.4						24.4	5	
24	晴	30.4	23.5	1.3	6.5						23.8	2	
25	晴	29.5	23.3	5.0	6.3						20.0	38	9時間19分
26	曇	30.0	23.3	1.8	6.4						18.2	3	
27	曇	30.2	23.8	1.7	6.4						16.1	3	
28	晴	31.8	24.1	1.7	6.5						17.9	3	
29	晴	32.2	24.5	1.1	6.5						27.5	2	
30	晴	31.1	25.3	1.2	6.6						35.2	2	
最大	——	32.2	25.3	5.0	6.6	36.9	53.9	148.5	25.9	0.10	35.2	38	——
最小	——	17.9	18.7	0.3	6.3	27.8	34.3	72.0	12.5	0.10	14.5	0	
平均	——	24.8	21.1	1.4	6.5	33.1	44.0	110.3	19.4	0.10	20.6	4	9時間19分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定