

県営第一工業用水道 水質試験結果表

2023年4月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	12.8	11.5	4.7	6.5						10.9	7	
2	晴	12.0	11.7	4.8	6.5						10.7	11	
3	晴	11.9	12.0	4.2	6.5						10.7	6	
4	晴	14.1	12.2	3.9	6.5						10.9	4	
5	曇	16.9	12.8	3.9	6.5						11.1	6	
6	曇	18.1	13.0	4.2	6.5	20.7	24.8	69.5	9.4	0.10	11.1	8	
7	雨	15.0	13.4	4.9	6.5						10.9	144	4時間44分
8	雨	9.5	12.8	7.6	6.5						10.2	40	3時間02分
9	晴	9.7	12.1	5.5	6.5						10.4	7	
10	晴	13.7	12.2	4.0	6.5						10.9	5	
11	晴	18.8	13.0	3.6	6.5						11.4	6	
12	雨	14.0	13.3	3.9	6.4	22.0	24.4	71.5	10.1	0.10	11.7	5	
13	晴	13.1	12.9	5.4	6.4						11.8	12	
14	曇	16.6	13.3	4.0	6.4						12.1	7	
15	雨	14.6	13.6	4.2	6.4						12.3	11	
16	雨	14.1	13.6	7.5	6.4						11.0	45	7時間15分
17	曇	11.6	13.4	6.8	6.4						10.8	54	2時間10分
18	曇	12.3	12.9	5.1	6.4						11.6	7	
19	晴	17.9	13.4	4.3	6.4						11.6	6	
20	晴	20.7	14.4	3.7	6.4						11.8	4	
21	曇	16.4	15.2	3.8	6.4						12.0	8	
22	晴	12.5	14.4	3.4	6.4						12.1	3	
23	晴	12.0	14.0	3.3	6.4						12.4	3	
24	曇	11.7	13.8	2.8	6.4						12.8	4	
25	曇	12.1	13.1	3.3	6.4						13.4	4	
26	雨	13.4	13.3	4.1	6.4	23.6	30.6	78.0	11.7	0.10	13.3	48	6時間34分
27	晴	13.7	13.4	7.0	6.4						11.9	15	0時間26分
28	晴	17.4	14.0	4.3	6.4						12.4	6	
29	晴	18.5	14.7	3.7	6.4						12.7	4	
30	曇	16.2	15.1	5.5	6.4						9.6	250	16時間32分
最大	——	20.7	15.2	7.6	6.5	23.6	30.6	78.0	11.7	0.10	13.4	250	——
最小	——	9.5	11.5	2.8	6.4	20.7	24.4	69.5	9.4	0.10	9.6	3	
平均	——	14.4	13.3	4.6	6.4	22.1	26.6	73.0	10.4	0.10	11.6	25	40時間43分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
他項目は日野川地区水道管理事務所にて測定