

県営第一工業用水道 水質試験結果表

2024年5月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	14.4	16.6	5.1	6.4						13.8	6	
2	晴	14.9	16.0	4.3	6.3						14.6	4	
3	晴	17.7	16.5	3.0	6.3						17.4	8	
4	晴	20.2	17.5	2.3	6.3						18.3	5	
5	晴	23.7	18.1	2.0	6.3						19.4	3	
6	雨	22.2	18.0	2.0	6.3						19.4	2	
7	雨	18.0	17.4	6.7	6.4						14.6	23	1時間34分
8	雨	13.5	16.7	6.1	6.4	25.4	32.1	75.0	10.3	0.10	14.1	9	
9	曇	12.3	15.8	4.8	6.4						14.4	5	
10	晴	17.4	16.3	3.8	6.3						16.5	4	
11	晴	21.7	17.3	4.3	6.3						15.2	5	
12	曇	20.2	17.6	2.6	6.3						15.5	3	
13	雨	15.0	16.8	5.0	6.4						12.5	58	13時間34分
14	晴	16.6	16.2	7.7	6.6						12.4	26	3時間19分
15	曇	19.8	17.2	6.1	6.5	25.9	30.3	74.0	9.0	0.10	13.3	7	
16	晴	17.4	17.1	5.6	6.4						13.9	6	
17	晴	18.9	17.1	5.4	6.4						13.8	7	
18	晴	20.8	17.6	3.5	6.4						14.4	8	
19	曇	19.7	18.0	2.9	6.3						15.4	8	
20	曇	20.0	18.0	5.0	6.4						14.1	7	
21	雨	17.5	18.2	4.8	6.4						14.7	5	
22	晴	20.8	18.1	4.3	6.3	28.9	35.1	83.5	11.2	0.10	15.3	4	
23	曇	23.0	18.8	4.4	6.4						14.9	5	
24	曇	20.9	19.2	3.8	6.3						15.1	4	
25	晴	18.1	19.0	2.8	6.3						15.7	10	
26	晴	22.3	19.0	2.2	6.3						18.6	3	
27	曇	24.6	19.7	3.1	6.3						18.0	4	
28	雨	15.8	18.9	5.0	6.4						14.2	178	12時間03分
29	曇	17.2	17.4	2.3	6.4						11.5	205	24時間00分
30	晴	21.3	17.5	7.5	6.5						11.8	29	7時間39分
31	曇	18.9	17.9	7.8	6.5						12.2	10	
最大	——	24.6	19.7	7.8	6.6	28.9	35.1	83.5	11.2	0.10	19.4	205	——
最小	——	12.3	15.8	2.0	6.3	25.4	30.3	74.0	9.0	0.10	11.5	2	
平均	——	18.9	17.6	4.4	6.4	26.7	32.5	77.5	10.2	0.10	15.0	21	62時間09分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定