

県営第一工業用水道 水質試験結果表

2025年2月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	5.1	6.0	2.5	6.7						11.5	3	
2	曇	5.8	6.7	1.7	6.7						11.3	2	
3	曇	5.1	6.7	2.8	6.7						11.1	7	
4	雪	0.8	5.3	4.1	6.8						11.4	13	
5	雪	-0.9	3.6	4.6	6.8						11.2	5	
6	雪	-0.4	3.3	4.3	6.8						12.3	6	
7	曇	-0.1	3.4	4.7	6.8	20.7	26.9	63.5	13.2	0.10	12.1	10	
8	雪	-0.3	3.4	4.0	6.8						12.3	5	
9	曇	1.0	3.7	3.5	6.8						12.5	6	
10	曇	1.5	3.9	3.9	6.8						12.8	5	
11	曇	1.2	3.9	4.8	6.8						14.1	31	1時間33分
12	晴	1.0	4.0	4.1	6.8	21.7	28.6	67.0	14.7	0.10	13.0	6	
13	曇	2.1	4.5	5.5	6.8						13.7	7	
14	曇	2.6	4.7	4.3	6.8						13.2	7	
15	晴	3.1	5.2	3.2	6.8						12.9	5	
16	晴	4.7	5.6	2.8	6.7						12.9	4	
17	曇	2.1	5.4	6.1	6.7						12.2	13	
18	晴	0.4	4.8	6.1	6.7						12.4	9	
19	曇	0.0	4.6	4.4	6.7	18.9	26.4	64.0	14.1	0.10	12.5	6	
20	曇	0.4	4.5	4.4	6.7						12.7	7	
21	晴	0.7	4.9	4.0	6.7						12.7	6	
22	雪	0.4	4.6	4.2	6.7						12.5	6	
23	雪	0.1	4.3	2.0	6.7						13.5	3	
24	雪	1.0	4.5	2.4	6.7						13.7	4	
25	曇	2.9	4.9	3.4	6.7						13.2	7	
26	雨	3.9	5.1	5.5	6.7						12.8	8	
27	晴	4.6	5.4	5.3	6.7						12.8	10	
28	曇	5.4	5.6	5.0	6.7						12.5	11	
最大	——	5.8	6.7	6.1	6.8	21.7	28.6	67.0	14.7	0.10	14.1	31	——
最小	——	-0.9	3.3	1.7	6.7	18.9	26.4	63.5	13.2	0.10	11.1	2	
平均	——	1.9	4.7	4.1	6.7	20.4	27.3	64.8	14.0	0.10	12.6	8	1時間33分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
水温、濁度、pH（3項目ともに日平均）は配水池管理棟
他項目は日野川地区水道管理事務所にて測定