

県営第一工業用水道 水質試験結果表

2025年5月分

日	天候	気温 [℃]	水温 [℃]	日平均濁度 [mg/L]	p H	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	19.6	14.0	6.6	6.7						10.8	9	
2	曇	16.3	14.4	6.9	6.7						11.3	33	1時間43分
3	晴	16.1	13.8	5.7	6.7						10.9	34	5時間50分
4	曇	15.5	14.8	4.6	6.7						11.4	7	
5	晴	15.8	14.4	4.4	6.7						11.3	8	
6	雨	14.6	14.5	4.2	6.7						11.6	8	
7	晴	14.1	14.2	6.7	6.7						10.9	52	8時間35分
8	晴	15.8	14.5	5.2	6.6	20.9	25.3	62.0	8.4	0.10	10.9	14	
9	曇	17.4	14.9	4.4	6.6						11.3	6	
10	曇	20.4	15.2	5.3	6.6						11.1	8	
11	曇	17.2	15.6	4.2	6.6						11.3	5	
12	曇	16.8	15.5	5.6	6.6						11.3	12	
13	晴	18.8	15.7	5.4	6.6						11.5	7	
14	曇	21.2	16.4	4.3	6.5	22.6	27.8	62.0	9.1	0.10	12.1	6	
15	晴	22.4	17.0	4.1	6.5						12.7	5	
16	曇	23.3	17.6	3.9	6.4						13.0	19	1時間09分
17	雨	22.0	17.9	3.8	6.4						13.1	5	
18	晴	21.3	18.3	3.5	6.4						12.8	4	
19	晴	22.8	18.4	3.7	6.4						13.2	6	
20	晴	25.9	19.0	3.8	6.4						14.1	32	
21	晴	27.2	19.9	3.4	6.3	24.9	31.5	81.5	11.5	0.10	14.5	4	
22	曇	22.7	20.0	3.4	6.3						14.9	4	
23	晴	19.4	19.2	3.4	6.3						14.8	4	
24	雨	18.0	18.6	3.2	6.3						14.9	4	
25	雨	16.6	17.8	5.1	6.4						12.9	7	
26	曇	16.0	17.1	4.9	6.4						12.9	6	
27	晴	19.1	17.4	4.2	6.3						13.9	4	
28	晴	21.5	18.6	3.6	6.3						14.7	4	
29	曇	21.2	18.8	3.3	6.3						17.2	3	
30	晴	20.8	18.7	3.5	6.4						14.5	3	
31	曇	17.7	18.4	2.5	6.3						15.1	13	
最大	——	27.2	20.0	6.9	6.7	24.9	31.5	81.5	11.5	0.10	17.2	52	——
最小	——	14.1	13.8	2.5	6.3	20.9	25.3	62.0	8.4	0.10	10.8	3	
平均	——	19.3	16.8	4.4	6.5	22.8	28.2	68.5	9.7	0.10	12.8	11	17時間17分

標準値 20以下 6.5～8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
水温、濁度、p H（3項目ともに日平均）は配水池管理棟
他項目は日野川地区水道管理事務所にて測定