

県営第一工業用水道 水質試験結果表

2025年8月分

日	天候	気温 [℃]	水温 [℃]	日平均濁度 [mg/L]	p H	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	31.2	28.3	2.2	7.0						46.8	2	
2	曇	30.1	28.0	1.7	6.5						26.1	8	
3	曇	30.7	27.8	1.5	6.4						22.2	2	
4	晴	32.9	27.9	2.5	6.3						17.3	5	
5	晴	31.0	28.2	2.6	6.4						18.4	3	
6	曇	30.3	27.2	3.8	6.4	28.8	32.3	78.0	9.7	0.10	14.9	7	
7	雨	28.5	26.9	3.6	6.3						15.7	7	
8	晴	27.8	26.9	4.8	6.3						15.6	8	
9	曇	27.4	26.5	1.8	6.4						25.1	17	
10	雨	26.2	26.1	1.4	6.4						17.9	2	
11	曇	26.8	25.4	4.6	6.4						14.8	74	11時間32分
12	雨	26.3	25.2	3.5	6.4						14.2	46	18時間38分
13	曇	28.3	25.0	6.9	6.4	28.0	30.4	72.5	8.4	0.10	14.3	13	
14	曇	29.6	25.7	2.9	6.4						14.8	12	
15	曇	28.8	26.1	1.8	6.3						15.6	3	
16	晴	29.7	26.8	1.9	6.3						16.1	6	
17	晴	29.9	27.2	1.5	6.4						18.3	8	
18	晴	29.8	27.5	2.8	6.5						25.3	6	
19	晴	30.3	27.8	3.1	6.6						28.6	27	
20	晴	30.3	28.5	2.4	6.7	46.1	47.3	151.0	25.8	0.10	32.0	3	
21	晴	30.2	29.8	2.3	6.7						26.8	3	
22	晴	30.8	29.9	2.2	6.7						33.5	3	
23	晴	30.6	30.2	1.5	6.8						28.8	6	
24	曇	30.8	30.4	1.2	7.0						28.8	4	
25	晴	31.0	30.4	2.7	7.1						24.7	6	
26		30.5	30.5	2.8	7.3						28.7	4	
27	曇	27.5	29.0	2.8	6.9						29.5	4	
28	晴	26.3	27.3	2.9	6.4						25.6	4	
29	晴	28.3	27.5	2.4	6.6						27.7	4	
30	晴	29.1	27.7	1.8	6.6						26.4	24	
31	晴	29.6	28.0	1.5	6.7						38.8	3	
最大	——	32.9	30.5	6.9	7.3	46.1	47.3	151.0	25.8	0.10	46.8	74	——
最小	——	26.2	25.0	1.2	6.3	28.0	30.4	72.5	8.4	0.10	14.2	2	
平均	——	29.4	27.7	2.6	6.6	34.3	36.7	100.5	14.6	0.10	23.7	10	30時間10分

標準値 20以下 6.5～8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
水温、濁度、p H（3項目ともに日平均）は配水池管理棟
他項目は日野川地区水道管理事務所にて測定