

県営第一工業用水道 水質試験結果表

2025年9月分

日	天候	気温 [℃]	水温 [℃]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	31.3	28.3	2.5	6.9						41.1	11	
2	晴	30.2	28.4	3.4	7.2						—	37	1時間34分
3	晴	28.0	27.4	6.1	6.3	28.3	37.8	105.5	14.4	0.10	17.3	31	7時間42分
4	晴	28.1	27.1	3.1	6.4						22.3	5	
5	曇	27.3	26.9	3.7	6.4						17.7	16	
6	晴	26.8	26.4	2.8	6.3						16.3	11	
7	晴	28.5	26.4	1.6	6.5						24.6	4	
8	雨	27.6	26.8	4.1	6.4						21.9	10	
9	晴	28.3	26.5	5.6	6.3						16.4	10	
10	曇	27.7	26.7	3.3	6.4	40.5	43.3	118.5	18.6	0.10	24.8	5	
11	曇	26.1	26.2	4.9	6.3						16.2	7	
12	晴	26.7	25.8	3.4	6.3						16.9	5	
13	曇	28.5	25.7	1.9	6.4						22.9	14	
14	雨	26.8	25.7	1.6	6.4						21.3	3	
15	曇	25.5	25.7	2.8	6.2						16.3	8	
16	晴	26.4	25.7	3.4	6.3						16.8	13	
17	晴	28.4	26.4	2.8	6.3	36.3	38.4	95.5	12.7	0.10	19.2	4	
18	曇	24.3	25.9	3.6	6.3						19.3	13	
19	曇	23.4	24.7	4.1	6.3						16.5	8	
20	曇	25.8	24.7	1.8	6.4						21.8	7	
21	晴	23.2	24.3	12.3	6.2						15.7	105	18時間00分
22	晴	21.4	23.2	6.6	6.4						16.3	24	9時間34分
23	曇	23.0	23.1	4.6	6.3						16.8	7	
24	晴	23.0	23.0	4.3	6.3						17.6	45	2時間04分
25	曇	23.0	23.0	3.7	6.3						18.9	5	
26	晴	24.5	23.4	3.5	6.3						17.7	5	
27	曇	22.2	23.3	2.3	6.3						22.2	11	
28	晴	23.6	22.9	1.9	6.4						22.1	4	
29	曇	23.1	23.2	5.2	6.3						17.8	42	9時間54分
30	晴	22.1	22.5	6.3	6.3						15.5	24	9時間45分
最大	——	31.3	28.4	12.3	7.2	40.5	43.3	118.5	18.6	0.10	41.1	105	——
最小	——	21.4	22.5	1.6	6.2	28.3	37.8	95.5	12.7	0.10	15.5	3	
平均	——	25.8	25.3	3.9	6.4	35.0	39.8	106.5	15.2	0.10	19.7	16	58時間33分

標準値 20以下 6.5～8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定