

## 水質試験結果表(取水分)

2011年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	月	29.7	23.0	4.4	7.4	29.7	33.0	55.2	9.4	0.32	0.01	79.1
2	火	30.5	22.4	5.1	7.4	30.5	33.6	49.6	8.1	0.35	ND	78.6
3	水	32.6	23.0	4.4	7.3	28.6	31.0	41.6	7.7	0.31	0.01	77.2
4	木	31.8	23.5	3.9	7.3	28.7	31.4	48.8	7.9	0.28	0.01	77.6
5	金	30.9	24.0	3.1	7.2	28.8	33.2	47.2	7.2	0.26	ND	80.8
6	土	32.9	24.5	3.1	7.4	31.9	38.2	48.8	9.4	0.25	0.01	85.3
7	日	32.1	25.2	2.4	7.4	28.0	35.8	56.8	10.4	0.26	ND	89.5
8	月	34.2	25.8	2.9	7.3	30.5	34.0	56.8	10.1	0.28	ND	87.2
9	火	33.0	25.2	2.8	7.2	30.6	31.2	50.8	10.2	0.25	0.01	85.4
10	水	32.9	25.5	3.3	7.2	30.5	32.0	52.0	8.4	0.30	ND	85.9
11	木	29.4	25.8	2.4	7.2	31.8	33.4	52.0	9.6	0.25	0.02	89.3
12	金	29.7	24.3	3.0	7.2	28.0	29.7	48.4	8.9	0.24	ND	80.4
13	土	32.2	25.0	1.9	7.5	30.0	32.2	48.0	8.7	0.20	0.01	85.4
14	日	33.1	25.8	2.4	7.4	29.7	31.8	48.4	10.9	0.23	0.01	86.9
15	月	30.0	26.0	2.4	7.3	30.5	32.2	54.8	11.1	0.26	0.01	86.6
16	火	31.4	25.3	2.8	7.2	31.0	32.2	48.0	7.8	0.27	0.01	85.2
17	水	30.3	25.0	2.8	7.2	32.5	32.8	49.2	8.5	0.26	0.01	85.4
18	木	30.4	24.9	57.5	7.1	18.2	32.2	108.4	8.5	1.79	0.07	59.4
19	金	25.0	24.2	26.2	7.3	18.8	21.5	72.8	8.2	0.91	0.04	57.0
20	土	25.6	22.0	10.3	7.4	23.6	26.9	61.2	9.4	0.67	0.03	68.8
21	日	23.4	22.0	4.9	7.4	25.7	27.3	46.8	10.0	0.31	0.02	75.9
22	月	25.8	21.7	5.1	7.4	27.4	28.9	54.0	10.2	0.36	0.02	77.2
23	火	27.5	22.2	4.6	7.4	27.5	29.9	55.2	9.3	0.35	0.01	78.4
24	水	27.2	21.2	11.1	7.3	22.0	28.5	55.2	10.0	0.59	0.04	66.6
25	木	27.9	21.8	4.9	7.4	26.0	29.7	53.2	8.5	0.33	0.02	73.7
26	金	26.6	22.0	10.0	7.3	22.8	25.5	48.0	7.1	0.51	0.02	66.7
27	土	30.5	22.2	3.8	7.4	25.4	26.9	49.6	7.3	0.29	0.01	73.8
28	日	31.7	23.0	4.2	7.4	28.0	28.5	52.4	8.5	0.37	0.01	79.0
29	月	32.6	24.0	3.7	7.4	30.6	31.8	54.0	9.9	0.33	0.01	84.0
30	火	32.4	23.3	3.7	7.4	28.3	28.5	48.8	7.9	0.32	0.01	76.0
31	水	31.2	23.1	3.1	7.3	27.2	29.3	50.0	8.6	0.29	0.01	74.6
最大値		34.2	26.0	57.5	7.5	32.5	38.2	108.4	11.1	1.79	0.07	89.5
最小値		23.4	21.2	1.9	7.1	18.2	21.5	41.6	7.1	0.20	ND	57.0
平均値		30.1	23.8	6.7	7.3	27.8	30.7	53.7	9.0	0.39	0.01	78.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2011年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	29.7	23.2	0.5	7.3	28.8	31.6	48.0	11.3	0.02	ND	80.9
2	火	30.5	22.7	0.7	7.3	30.0	31.2	46.4	10.4	0.04	ND	80.9
3	水	32.6	23.0	0.6	7.3	26.8	30.2	37.6	8.3	0.02	ND	79.0
4	木	31.8	23.8	0.5	7.2	28.4	30.4	41.2	9.2	0.03	ND	80.6
5	金	30.9	24.2	0.9	7.2	27.5	31.0	42.0	10.0	0.04	ND	81.8
6	土	32.9	24.7	0.3	7.4	32.9	37.0	48.4	11.3	0.02	ND	85.5
7	日	32.1	25.8	0.3	7.4	26.4	33.6	44.0	11.6	0.02	ND	89.4
8	月	34.2	26.4	0.2	7.3	28.5	32.4	51.2	10.6	0.01	ND	89.4
9	火	33.0	25.8	0.5	7.2	31.9	32.8	46.8	12.2	0.02	ND	88.6
10	水	32.9	25.9	0.4	7.2	30.0	32.4	48.0	10.4	0.02	ND	86.9
11	木	29.4	26.1	0.4	7.2	32.1	33.0	47.2	11.3	0.03	ND	90.5
12	金	29.7	24.8	0.6	7.2	27.6	28.5	45.6	11.3	0.03	ND	81.1
13	土	32.2	25.1	0.3	7.4	28.5	31.8	49.2	10.1	0.03	ND	85.3
14	日	33.1	26.0	0.4	7.5	27.3	30.2	44.0	12.3	0.03	ND	86.8
15	月	30.0	26.7	0.3	7.3	28.8	31.6	45.6	11.9	0.02	ND	88.2
16	火	31.4	25.8	0.4	7.3	31.7	33.8	42.0	11.2	0.02	ND	87.8
17	水	30.3	25.4	0.3	7.3	30.8	31.6	48.4	10.1	0.02	ND	86.6
18	木	30.4	25.1	0.8	7.1	22.6	25.1	42.4	11.0	0.02	ND	74.9
19	金	25.0	24.3	1.3	7.0	20.3	26.9	42.4	10.6	0.10	0.01	75.3
20	土	25.6	22.5	1.9	7.0	22.6	24.9	46.0	11.9	0.08	0.01	71.0
21	日	23.4	22.0	1.0	7.2	23.7	27.7	45.6	11.5	0.04	0.01	78.4
22	月	25.8	21.6	0.7	7.2	24.4	28.9	49.6	11.5	0.02	ND	79.8
23	火	27.5	22.0	0.4	7.2	26.0	30.6	45.2	12.0	0.04	ND	83.3
24	水	27.2	21.4	1.4	7.0	17.6	27.3	40.4	12.4	0.04	ND	68.7
25	木	27.9	22.0	0.4	7.2	24.6	27.7	48.0	12.8	0.02	ND	75.6
26	金	26.6	22.3	0.8	7.0	19.2	22.9	40.0	11.0	0.03	ND	69.2
27	土	30.5	22.5	0.3	7.3	23.1	27.9	42.0	10.4	0.02	ND	76.4
28	日	31.7	23.2	0.2	7.3	25.4	28.9	44.4	11.0	0.02	ND	80.9
29	月	32.6	24.1	0.2	7.2	27.7	32.0	50.0	10.7	0.01	ND	86.1
30	火	32.4	23.8	0.4	7.2	28.8	28.1	45.2	11.5	0.01	ND	78.0
31	水	31.2	23.5	0.6	7.2	25.2	27.3	41.2	12.0	0.03	ND	76.0
最大値		34.2	26.7	1.9	7.5	32.9	37.0	51.2	12.8	0.10	0.01	90.5
最小値		23.4	21.4	0.2	7.0	17.6	22.9	37.6	8.3	0.01	ND	68.7
平均値		30.1	24.1	0.6	7.2	26.7	30.0	45.1	11.1	0.03	ND	81.4

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 濁度およびpH以外の基準については参考値とする。  
 本試験結果はJIS.K.0101(工業用水試験法)による。