

### 水質試験結果表(取水分)

2011年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	土	22.8	18.8	6.7	7.3	25.9	28.3	58.8	10.9	0.42	0.03	92.2
2	日	15.6	18.1	6.0	7.4	27.9	29.1	71.6	13.2	0.38	0.03	95.2
3	月	19.9	17.1	4.5	7.4	28.2	32.4	64.8	15.0	0.32	0.02	97.2
4	火	19.2	16.9	4.4	7.4	27.4	29.5	61.6	13.1	0.30	0.01	98.7
5	水	17.1	17.0	4.5	7.4	28.6	32.8	73.2	15.4	0.29	0.02	111.4
6	木	26.0	16.6	2.6	7.4	24.7	27.3	43.6	9.6	0.21	ND	70.6
7	金	22.2	17.0	2.3	7.4	26.3	26.5	43.2	10.2	0.22	ND	75.7
8	土	19.1	16.2	1.8	7.6	27.7	27.9	47.6	8.9	0.17	ND	77.4
9	日	21.1	16.5	1.2	7.6	27.1	31.4	44.0	11.0	0.15	ND	77.3
10	月	23.3	17.0	1.1	7.6	26.8	28.3	51.6	12.1	0.16	ND	77.4
11	火	24.0	17.1	1.5	7.5	26.4	29.9	52.0	10.4	0.18	0.01	78.0
12	水	21.0	16.7	1.8	7.5	24.3	26.5	42.4	11.8	0.15	ND	72.5
13	木	18.3	16.6	1.8	7.4	25.9	25.7	40.8	10.9	0.16	ND	69.6
14	金	23.1	16.2	1.6	7.5	25.0	25.5	41.2	8.5	0.12	ND	69.9
15	土	20.9	17.5	2.5	7.5	25.7	24.9	43.2	9.3	0.21	0.01	67.5
16	日	23.8	17.5	4.7	7.5	27.4	25.7	43.6	10.7	0.27	0.02	68.4
17	月	18.7	17.0	4.4	7.4	28.0	25.5	52.8	12.9	0.26	0.01	68.9
18	火	22.4	16.6	1.8	7.5	28.9	28.1	58.0	11.7	0.17	0.01	84.5
19	水	18.7	16.1	1.7	7.5	29.7	32.4	53.6	10.9	0.16	0.01	86.4
20	木	22.4	15.9	1.7	7.5	30.3	32.2	52.8	9.8	0.17	ND	84.6
21	金	23.2	16.5	1.6	7.5	31.0	33.8	56.8	10.7	0.15	ND	90.8
22	土	22.1	18.0	1.0	7.7	33.3	38.0	64.0	11.2	0.14	0.01	96.5
23	日	24.5	17.9	2.0	7.6	29.0	32.0	50.4	13.1	0.15	0.01	80.7
24	月	23.7	17.6	1.6	7.5	29.1	32.0	56.4	13.3	0.15	0.01	82.8
25	火	18.8	17.2	1.4	7.5	29.3	28.9	43.2	10.4	0.15	0.01	77.4
26	水	14.0	15.8	1.7	7.5	28.6	29.9	52.0	11.7	0.17	0.01	76.7
27	木	20.6	14.8	1.2	7.5	28.6	28.9	42.4	8.7	0.12	ND	75.8
28	金	19.9	14.6	0.9	7.5	28.8	29.3	40.0	9.5	0.12	ND	75.7
29	土	20.8	15.2	1.0	7.5	27.2	27.9	46.8	10.0	0.11	0.01	76.3
30	日	17.0	16.0	0.9	7.6	27.0	28.1	45.6	10.9	0.10	0.01	76.4
31	月	23.0	15.8	1.2	7.6	28.1	30.2	52.4	12.4	0.10	ND	78.6
最大値		26.0	18.8	6.7	7.7	33.3	38.0	73.2	15.4	0.42	0.03	111.4
最小値		14.0	14.6	0.9	7.3	24.3	24.9	40.0	8.5	0.10	ND	67.5
平均値		20.9	16.7	2.4	7.5	27.8	29.3	51.3	11.2	0.19	0.01	81.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2011年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	土	22.8	19.0	1.1	7.2	25.3	31.4	61.6	13.9	0.05	ND	100.6
2	日	15.6	18.1	0.5	7.2	25.7	31.8	53.2	16.0	0.03	ND	97.5
3	月	19.9	17.3	0.9	7.2	24.4	31.4	61.6	17.2	0.04	ND	103.2
4	火	19.2	17.0	1.0	7.2	26.4	32.4	58.8	14.9	0.04	ND	102.1
5	水	17.1	17.0	0.7	7.3	27.3	32.8	66.4	17.2	0.04	ND	108.2
6	木	26.0	16.5	0.4	7.3	23.4	25.3	40.0	11.4	0.03	ND	72.4
7	金	22.2	17.1	0.6	7.3	26.1	27.5	42.0	11.8	0.06	ND	77.0
8	土	19.1	16.3	1.2	7.5	27.3	29.3	49.6	13.6	0.08	ND	79.1
9	日	21.1	16.8	0.5	7.5	26.5	28.5	46.0	14.2	0.05	ND	78.5
10	月	23.3	17.1	0.2	7.5	25.4	28.7	48.0	14.6	0.04	ND	78.3
11	火	24.0	17.2	0.4	7.4	26.9	29.1	47.2	13.2	0.05	ND	80.1
12	水	21.0	16.9	0.9	7.4	26.3	27.3	38.0	12.9	0.07	ND	74.0
13	木	18.3	16.9	1.5	7.4	25.8	25.7	39.2	13.2	0.09	ND	70.9
14	金	23.1	16.4	1.3	7.4	25.1	25.5	42.4	10.4	0.07	ND	70.3
15	土	20.9	17.6	0.9	7.4	25.7	24.9	42.4	10.4	0.06	ND	69.3
16	日	23.8	17.8	1.1	7.2	27.5	26.5	40.4	11.3	0.05	0.01	71.6
17	月	18.7	17.5	1.3	7.1	24.1	24.3	40.8	13.5	0.05	ND	67.8
18	火	22.4	16.5	0.9	7.4	28.6	28.9	52.4	13.8	0.07	ND	83.3
19	水	18.7	16.2	1.2	7.4	29.6	30.6	54.4	13.0	0.09	0.01	85.8
20	木	22.4	16.0	1.0	7.4	31.5	32.6	52.8	12.9	0.09	ND	85.5
21	金	23.2	16.7	1.0	7.5	32.3	34.0	52.0	14.4	0.11	ND	92.4
22	土	22.1	18.1	0.7	7.6	33.0	37.6	62.8	12.6	0.09	ND	97.6
23	日	24.5	18.0	1.2	7.5	28.7	32.0	52.0	14.3	0.06	0.01	86.2
24	月	23.7	17.9	1.0	7.5	28.7	33.8	56.0	14.5	0.07	0.01	84.7
25	火	18.8	17.1	1.2	7.5	29.2	28.9	46.8	12.6	0.08	ND	78.8
26	水	14.0	15.8	1.2	7.4	29.4	29.3	46.0	12.1	0.08	ND	77.9
27	木	20.6	14.9	1.1	7.5	27.8	28.9	43.2	11.7	0.08	ND	76.4
28	金	19.9	14.7	0.7	7.5	29.1	29.1	40.0	11.4	0.08	ND	76.8
29	土	20.8	15.2	0.9	7.6	27.9	29.3	43.2	10.4	0.07	ND	76.9
30	日	17.0	16.0	0.7	7.6	28.0	27.9	43.2	13.0	0.06	ND	77.2
31	月	23.0	15.9	0.8	7.6	27.0	33.0	48.8	12.9	0.06	ND	80.2
最大値		26.0	19.0	1.5	7.6	33.0	37.6	66.4	17.2	0.11	0.01	108.2
最小値		14.0	14.7	0.2	7.1	23.4	24.3	38.0	10.4	0.03	ND	67.8
平均値		20.9	16.8	0.9	7.4	27.4	29.6	48.7	13.2	0.06	ND	82.6

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所