

水質試験結果表(取水分)

2012年4月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	5.5	8.2	54.7	7.4	14.8	20.1	108.0	12.3	1.68	0.08	65.1
2	月	9.0	8.1	17.0	7.5	17.9	27.1	68.4	15.9	0.79	0.06	77.0
3	火	13.1	9.8	12.4	7.4	19.9	24.5	82.4	15.5	0.71	0.05	86.0
4	水	11.3	8.8	60.4	7.4	16.5	22.3	112.4	18.1	1.76	0.09	72.8
5	木	8.8	8.3	21.7	7.3	18.6	24.7	82.0	16.4	0.85	0.04	88.5
6	金	6.8	8.5	12.3	7.6	19.9	26.9	77.2	13.1	0.58	0.09	95.8
7	土	4.6	8.5	7.3	7.6	22.3	27.1	78.4	17.3	0.51	0.02	97.2
8	日	9.2	8.7	5.7	7.5	23.0	28.1	68.4	18.0	0.44	0.02	96.2
9	月	13.8	9.7	6.2	7.6	23.8	29.1	72.8	17.1	0.39	0.02	94.1
10	火	16.1	9.6	5.5	7.5	23.0	26.7	63.2	16.9	0.37	0.02	92.9
11	水	12.6	11.0	6.7	7.4	22.9	27.3	76.0	17.8	0.44	0.02	92.1
12	木	15.6	10.2	48.3	7.4	16.3	23.3	101.2	13.4	1.72	0.09	73.0
13	金	18.6	11.5	26.5	7.4	17.4	21.1	77.6	14.0	1.18	0.04	74.8
14	土	12.6	11.2	14.9	7.6	20.0	22.9	74.0	13.3	0.88	0.06	79.3
15	日	15.2	11.0	12.4	7.6	20.2	23.1	66.0	17.2	0.70	0.08	78.6
16	月	18.3	11.2	10.2	7.5	20.7	24.1	65.6	15.1	0.61	0.06	80.2
17	火	14.1	11.0	11.6	7.4	20.0	24.3	69.6	15.5	0.65	0.04	81.2
18	水	16.2	11.0	11.4	7.4	20.8	24.5	69.6	17.1	0.64	0.56	84.3
19	木	18.3	11.5	8.9	7.5	21.0	24.5	66.4	15.3	0.54	0.03	81.4
20	金	17.4	12.0	17.8	7.4	21.4	24.9	80.0	14.5	1.29	0.06	81.3
21	土	20.5	11.9	7.5	7.5	22.6	25.3	58.0	13.4	0.51	0.02	82.4
22	日	14.9	12.9	11.2	7.6	22.2	25.1	58.0	16.3	0.76	0.03	77.3
23	月	15.6	11.9	15.3	7.5	19.6	24.1	56.8	15.3	0.70	0.04	72.3
24	火	17.4	11.9	15.2	7.5	18.7	22.5	56.0	12.1	0.70	0.08	70.5
25	水	21.9	12.2	11.1	7.4	19.2	23.5	56.0	12.2	0.57	0.07	74.2
26	木	19.9	13.7	12.8	7.4	19.7	24.3	56.0	16.1	0.72	0.08	75.7
27	金	20.9	12.2	15.8	7.4	19.4	22.1	54.8	14.6	0.68	0.09	72.1
28	土	19.6	12.9	10.4	7.6	21.9	21.5	56.0	13.9	0.51	0.04	71.5
29	日	25.3	13.6	10.0	7.6	20.7	22.7	56.0	15.4	0.54	0.04	74.7
30	月	21.0	14.3	9.0	7.6	20.6	24.1	56.8	14.2	0.53	0.04	74.0
最大値		25.3	14.3	60.4	7.6	23.8	29.1	112.4	18.1	1.76	0.56	97.2
最小値		4.6	8.1	5.5	7.3	14.8	20.1	54.8	12.1	0.37	0.02	65.1
平均値		15.1	10.9	16.3	7.5	20.2	24.4	70.8	15.2	0.77	0.07	80.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2012年4月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	日	5.5	8.9	4.8	7.1	11.8	21.3	58.0	17.1	0.18	0.03	77.2
2	月	9.0	7.5	1.6	7.3	14.9	22.7	51.6	18.4	0.04	ND	83.9
3	火	13.1	9.6	1.5	7.4	19.1	24.7	65.6	17.2	0.04	ND	92.5
4	水	11.3	9.0	2.1	7.4	16.3	23.7	56.4	20.1	0.05	ND	88.0
5	木	8.8	8.0	2.2	7.2	16.1	24.1	62.0	18.5	0.08	ND	96.9
6	金	6.8	8.1	2.3	7.5	19.6	27.7	57.2	15.3	0.06	ND	103.9
7	土	4.6	8.8	1.3	7.5	22.7	27.5	77.2	19.0	0.12	0.01	103.0
8	日	9.2	8.4	1.1	7.5	21.7	28.1	63.6	19.0	0.06	ND	102.7
9	月	13.8	9.2	2.4	7.5	24.4	28.7	66.4	19.2	0.08	ND	102.1
10	火	16.1	9.5	1.1	7.3	22.5	28.1	67.2	19.4	0.05	ND	98.0
11	水	12.6	11.0	1.4	7.2	21.7	28.3	68.0	20.3	0.06	ND	99.9
12	木	15.6	10.4	4.6	7.0	14.1	24.3	60.0	16.4	0.16	0.02	84.0
13	金	18.6	11.7	2.3	7.4	16.5	22.9	52.4	18.5	0.08	ND	84.5
14	土	12.6	11.4	1.5	7.5	19.2	23.3	56.0	17.8	0.07	ND	88.1
15	日	15.2	11.2	1.2	7.5	20.9	24.9	57.2	21.1	0.05	ND	90.0
16	月	18.3	11.1	1.3	7.5	19.6	25.1	54.4	17.2	0.04	ND	89.1
17	火	14.1	11.2	1.8	7.2	18.6	25.5	53.6	17.3	0.06	ND	87.9
18	水	16.2	11.1	1.7	7.3	18.3	25.1	58.4	19.2	0.06	ND	89.0
19	木	18.3	12.0	1.3	7.2	18.5	24.7	52.4	17.2	0.06	ND	87.3
20	金	17.4	12.2	1.5	7.2	20.1	24.5	44.0	18.1	0.05	ND	84.4
21	土	20.5	12.0	2.1	7.3	20.8	25.9	48.4	16.8	0.11	0.01	84.4
22	日	14.9	12.9	0.8	7.3	20.8	26.3	40.8	19.3	0.05	ND	87.1
23	月	15.6	12.0	2.0	7.2	18.7	22.9	48.8	18.1	0.09	ND	81.5
24	火	17.4	12.0	2.5	7.1	15.7	22.7	40.0	15.0	0.08	ND	74.8
25	水	21.9	12.7	1.7	7.2	16.3	22.9	44.4	16.0	0.06	ND	81.1
26	木	19.9	13.9	1.3	7.1	17.4	24.1	41.2	18.1	0.06	ND	82.5
27	金	20.9	12.7	2.5	7.1	17.7	22.9	40.0	18.3	0.09	0.01	81.3
28	土	19.6	13.2	1.8	7.4	22.5	22.3	47.6	15.6	0.04	ND	77.2
29	日	25.3	14.0	1.5	7.4	17.3	23.7	47.2	17.0	0.05	ND	81.3
30	月	21.0	14.9	1.1	7.3	17.0	23.9	42.8	15.7	0.05	ND	78.4
最大値		25.3	14.9	4.8	7.5	24.4	28.7	77.2	21.1	0.18	0.03	103.9
最小値		4.6	7.5	0.8	7.0	11.8	21.3	40.0	15.0	0.04	ND	74.8
平均値		15.1	11.0	1.9	7.3	18.7	24.8	54.1	17.9	0.07	ND	88.1

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 濁度およびpH以外の基準については参考値とする。
 本試験結果はJIS.K.0101(工業用水試験法)による。