

水質試験結果表(取水分)

2012年6月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	金	27.0	18.2	2.2	7.2	29.1	31.6	56.8	12.6	0.20	ND	85.5
2	土	24.4	19.7	1.4	7.3	31.4	33.2	54.0	11.4	0.20	ND	87.4
3	日	26.8	18.9	1.6	7.3	30.1	33.0	52.0	10.7	0.20	ND	87.5
4	月	27.5	18.9	1.7	7.2	29.5	31.8	53.2	10.7	0.22	ND	85.4
5	火	24.1	19.0	2.0	7.1	29.6	32.8	57.2	10.7	0.18	0.01	87.0
6	水	26.9	18.2	1.9	7.2	29.6	31.6	62.0	10.1	0.18	0.01	85.9
7	木	24.7	19.0	2.1	7.1	32.6	33.6	56.0	9.4	0.18	0.01	86.7
8	金	28.3	19.4	2.1	7.2	30.2	32.6	69.2	10.0	0.17	0.01	87.9
9	土	20.6	20.0	3.1	7.3	28.0	29.5	56.0	10.0	0.25	0.02	82.1
10	日	21.1	18.8	3.0	7.4	28.1	31.2	50.8	12.1	0.24	0.02	78.7
11	月	26.3	18.0	2.6	7.3	29.1	30.6	56.0	11.2	0.24	0.01	77.9
12	火	24.9	19.0	2.6	7.1	30.5	31.2	54.8	11.2	0.25	0.01	82.5
13	水	27.0	18.6	3.0	7.1	28.9	32.8	66.0	11.2	0.26	0.01	85.2
14	木	29.1	19.0	3.1	7.2	29.4	32.0	65.2	10.0	0.26	0.01	84.7
15	金	28.0	20.2	3.3	7.1	30.3	33.0	65.2	10.1	0.28	0.01	85.5
16	土	21.7	20.2	1.8	7.3	30.4	32.0	58.0	10.2	0.23	ND	88.1
17	日	22.7	19.2	3.9	7.3	30.3	31.4	56.8	13.0	0.31	0.02	80.3
18	月	25.6	19.0	6.6	7.3	26.4	32.0	46.0	10.6	0.37	0.02	64.9
19	火	21.3	19.2	4.0	7.1	24.1	25.7	60.4	10.1	0.28	0.01	69.5
20	水	21.3	18.7	11.9	7.1	20.9	24.5	56.8	9.5	0.54	0.04	59.4
21	木	23.2	17.3	5.4	7.2	20.3	23.7	54.0	9.4	0.29	0.01	61.3
22	金	21.5	17.7	5.2	7.3	23.3	26.1	52.0	9.4	0.29	0.02	66.6
23	土	22.9	17.8	4.2	7.3	25.0	27.5	52.8	9.5	0.29	0.02	70.0
24	日	24.8	18.3	3.0	7.4	26.1	27.9	56.8	10.3	0.28	0.02	71.6
25	月	28.6	19.0	3.0	7.2	27.2	29.3	52.0	9.9	0.29	0.02	72.2
26	火	25.1	19.3	3.3	7.2	25.0	27.3	50.8	9.9	0.26	0.01	71.1
27	水	26.2	19.3	5.4	7.3	24.0	25.9	54.0	8.9	0.32	0.02	69.8
28	木	27.5	19.1	3.4	7.2	27.7	26.5	50.0	9.4	0.27	0.01	71.1
29	金	29.6	20.1	2.9	7.2	29.6	27.9	56.0	8.6	0.26	0.03	72.7
30	土	28.0	20.6	2.2	7.3	27.2	28.1	54.0	8.5	0.23	0.01	73.8
最大値		29.6	20.6	11.9	7.4	32.6	33.6	69.2	13.0	0.54	0.04	88.1
最小値		20.6	17.3	1.4	7.1	20.3	23.7	46.0	8.5	0.17	ND	59.4
平均値		25.2	19.0	3.4	7.2	27.8	29.9	56.2	10.3	0.26	0.01	77.7

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

