

## 水質試験結果表(取水分)

2012年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	22.8	21.2	2.3	7.3	28.9	28.7	58.4	13.5	0.24	0.01	75.6
2	月	23.7	20.5	7.7	7.3	28.3	27.1	53.2	10.3	0.38	0.02	66.4
3	火	24.4	21.0	3.5	7.2	25.8	26.5	56.0	9.2	0.28	0.02	75.4
4	水	25.3	19.8	3.1	7.2	25.9	28.1	57.6	10.6	0.23	0.01	74.1
5	木	28.4	20.7	3.6	7.2	26.3	29.5	54.0	10.4	0.27	0.01	76.4
6	金	22.3	20.2	3.8	7.2	25.5	27.3	56.0	10.0	0.25	0.01	73.2
7	土	22.5	20.0	26.2	7.2	19.2	23.3	74.4	8.2	1.15	0.04	54.5
8	日	24.0	19.1	11.2	7.3	22.7	20.9	53.6	10.1	0.51	0.03	53.0
9	月	27.1	18.9	4.7	7.3	25.7	24.1	49.6	10.9	0.26	0.01	64.8
10	火	30.5	20.0	3.8	7.2	24.4	25.7	60.0	10.2	0.25	0.02	70.9
11	水	30.6	20.9	3.4	7.2	27.7	26.5	57.6	11.7	0.24	0.01	72.9
12	木	27.2	21.6	3.4	7.2	26.0	28.1	54.4	9.6	0.26	0.01	74.3
13	金	29.6	20.8	5.8	7.2	21.8	25.7	50.0	10.2	0.32	0.01	62.9
14	土	26.9	20.9	2.7	7.5	24.1	25.3	48.8	8.1	0.21	0.01	69.6
15	日	30.6	21.8	2.3	7.4	24.0	24.9	48.4	9.3	0.19	0.01	70.1
16	月	33.6	22.8	1.9	7.4	24.2	25.1	49.2	8.4	0.18	ND	70.8
17	火	33.6	22.9	3.0	7.1	24.8	27.1	62.0	9.5	0.25	ND	69.2
18	水	32.5	23.0	2.6	7.1	26.2	26.3	52.0	8.9	0.24	0.01	70.5
19	木	31.7	23.2	2.7	7.2	25.6	26.1	45.2	11.1	0.24	0.01	73.1
20	金	30.5	23.5	2.4	7.1	26.5	27.1	53.6	8.8	0.22	0.01	73.9
21	土	25.3	23.1	3.5	7.3	25.8	28.1	47.2	7.9	0.23	0.01	72.2
22	日	29.3	21.6	10.4	7.2	24.1	29.5	52.0	8.5	0.46	0.04	58.9
23	月	30.0	21.5	5.8	7.2	23.3	24.7	53.2	9.3	0.31	0.02	67.2
24	火	31.8	22.2	3.4	7.2	27.2	29.3	56.0	9.9	0.24	0.01	76.1
25	水	28.8	22.7	3.2	7.2	26.7	28.1	56.0	10.1	0.28	0.01	76.0
26	木	31.3	22.4	2.9	7.2	27.9	28.3	54.4	10.6	0.23	0.01	76.1
27	金	30.6	23.0	3.1	7.2	26.6	29.3	51.6	8.9	0.24	0.01	76.2
28	土	32.3	23.9	1.4	7.4	27.4	29.5	46.4	9.6	0.18	ND	79.2
29	日	30.8	24.8	1.5	7.3	30.7	33.4	54.4	10.2	0.20	ND	87.8
30	月	34.1	25.0	1.6	7.2	31.6	33.6	56.0	10.0	0.26	0.01	88.5
31	火	33.1	24.4	2.5	7.2	29.3	30.2	51.2	12.2	0.23	ND	83.0
最大値		34.1	25.0	26.2	7.5	31.6	33.6	74.4	13.5	1.15	0.04	88.5
最小値		22.3	18.9	1.4	7.1	19.2	20.9	45.2	7.9	0.18	ND	53.0
平均値		28.9	21.9	4.5	7.2	25.9	27.3	53.9	9.9	0.29	0.01	72.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2012年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	日	22.8	21.5	0.9	7.4	29.3	28.3	50.4	13.8	0.07	ND	77.1
2	月	23.7	20.7	0.7	7.2	27.3	26.5	46.0	12.7	0.02	ND	73.0
3	火	24.4	21.2	1.1	7.1	24.4	27.7	52.0	11.1	0.06	ND	76.5
4	水	25.3	19.9	1.1	7.3	28.7	29.5	52.0	12.2	0.05	ND	76.0
5	木	28.4	20.9	1.1	7.3	28.9	29.3	53.6	11.4	0.03	ND	77.9
6	金	22.3	20.3	0.8	7.1	24.5	27.5	50.0	11.2	0.04	ND	75.0
7	土	22.5	20.1	1.6	6.9	20.6	22.3	44.8	12.2	0.06	ND	63.8
8	日	24.0	19.4	1.5	7.0	23.5	24.3	40.0	13.0	0.04	ND	57.6
9	月	27.1	19.0	0.9	7.1	22.0	29.1	41.6	10.5	0.02	ND	64.3
10	火	30.5	20.4	0.7	7.1	23.6	25.3	54.8	13.1	0.03	ND	71.3
11	水	30.6	21.3	0.6	7.2	28.2	26.1	56.0	12.8	0.03	ND	73.9
12	木	27.2	21.9	0.8	7.1	27.2	28.1	48.8	11.1	0.04	ND	75.1
13	金	29.6	21.1	0.9	7.0	22.5	23.9	47.2	12.3	0.04	ND	67.3
14	土	26.9	21.2	0.9	7.3	22.0	24.5	40.4	10.2	0.04	ND	69.9
15	日	30.6	21.9	0.7	7.4	22.7	25.9	48.0	10.5	0.03	ND	71.9
16	月	33.6	22.9	0.8	7.3	23.4	25.9	41.6	10.7	0.04	ND	71.1
17	火	33.6	23.5	0.7	7.1	23.0	26.9	45.2	10.5	0.04	ND	71.0
18	水	32.5	23.6	0.7	7.1	26.8	25.9	50.0	11.0	0.05	ND	72.0
19	木	31.7	23.8	0.8	7.2	25.8	27.3	40.0	12.1	0.05	ND	75.0
20	金	30.5	23.9	1.0	7.2	26.9	26.7	52.0	11.5	0.08	ND	74.6
21	土	25.3	23.3	1.1	7.4	28.6	28.5	46.4	10.4	0.04	ND	76.3
22	日	29.3	22.0	1.4	6.8	28.8	21.9	40.0	9.6	0.04	ND	59.9
23	月	30.0	21.9	1.0	7.1	21.3	24.7	44.4	11.0	0.03	ND	68.4
24	火	31.8	22.2	0.9	7.2	26.7	27.1	48.8	11.4	0.04	ND	76.6
25	水	28.8	22.9	0.6	7.2	25.2	29.3	52.0	11.1	0.05	ND	77.4
26	木	31.3	22.6	1.0	7.2	26.6	29.9	54.0	11.5	0.06	ND	77.5
27	金	30.6	23.5	0.8	7.2	26.7	28.7	40.8	8.8	0.06	ND	77.4
28	土	32.3	23.8	0.6	7.5	27.3	29.3	48.0	10.1	0.07	ND	79.4
29	日	30.8	25.0	0.6	7.4	29.8	32.0	54.4	11.1	0.08	ND	88.2
30	月	34.1	25.5	0.5	7.3	30.3	31.4	54.0	10.9	0.07	ND	88.2
31	火	33.1	25.0	1.2	7.3	30.4	31.0	49.6	12.4	0.08	ND	83.4
最大値		34.1	25.5	1.6	7.5	30.4	32.0	56.0	13.8	0.08	ND	88.2
最小値		22.3	19.0	0.5	6.8	20.6	21.9	40.0	8.8	0.02	ND	57.6
平均値		28.9	22.1	0.9	7.2	25.9	27.3	48.0	11.4	0.05	ND	73.8

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所