

### 水質試験結果表(取水分)

2012年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	水	33.9	24.8	2.0	7.1	28.4	31.0	56.8	10.9	0.21	ND	80.9
2	木	35.9	24.9	2.1	7.1	31.4	28.3	62.0	12.9	0.20	0.01	81.9
3	金	35.3	25.3	2.1	7.1	31.2	30.8	59.2	24.7	0.21	0.01	82.2
4	土	34.2	25.9	1.1	7.3	30.6	33.4	56.0	8.9	0.17	ND	86.8
5	日	34.3	26.8	1.3	7.3	32.3	33.6	57.2	9.8	0.16	ND	91.7
6	月	32.8	26.9	1.5	7.3	31.0	31.2	57.2	9.7	0.22	ND	89.3
7	火	33.4	26.0	1.9	7.2	30.6	32.0	56.0	11.4	0.18	ND	86.7
8	水	30.8	25.4	1.6	7.2	31.7	31.2	63.2	11.2	0.18	0.01	87.1
9	木	30.2	24.5	1.8	7.2	30.2	32.8	60.0	10.1	0.17	0.01	86.6
10	金	31.4	24.7	1.9	7.1	31.6	32.6	56.0	10.4	0.21	ND	87.4
11	土	25.8	25.2	1.2	7.5	30.2	33.6	54.8	9.3	0.19	0.02	86.9
12	日	32.1	24.9	1.5	7.5	30.6	33.4	57.6	9.0	0.18	0.01	86.4
13	月	28.9	25.6	1.7	7.3	31.2	32.2	60.0	10.9	0.24	ND	87.8
14	火	26.6	25.3	3.3	7.2	27.1	30.2	53.2	9.2	0.22	0.01	79.1
15	水	30.3	24.7	7.6	7.1	24.5	26.1	54.4	10.5	0.33	0.01	70.1
16	木	31.0	24.6	3.7	7.3	30.3	31.2	64.0	10.7	0.26	0.01	84.1
17	金	33.6	24.7	3.3	7.2	31.5	32.8	66.0	8.9	0.25	0.01	87.6
18	土	33.6	25.8	1.8	7.5	32.9	33.4	62.8	10.3	0.27	ND	91.8
19	日	32.8	25.1	2.7	7.5	30.4	31.6	66.4	9.6	0.21	ND	85.7
20	月	31.9	25.2	2.9	7.3	30.6	32.4	61.2	11.3	0.21	ND	86.6
21	火	33.1	25.0	2.4	7.1	31.3	33.0	61.2	9.7	0.24	0.01	89.4
22	水	34.2	25.2	2.3	7.1	30.1	30.2	59.2	8.1	0.24	0.01	85.9
23	木	33.4	25.6	2.5	7.1	30.0	32.0	54.4	8.8	0.23	0.01	86.0
24	金	32.2	25.5	2.3	7.2	30.2	33.0	62.8	9.6	0.23	0.01	87.0
25	土	32.9	26.0	1.5	7.4	31.1	31.6	56.0	8.0	0.17	ND	88.1
26	日	32.9	26.3	1.7	7.3	29.1	33.4	56.0	9.2	0.17	ND	87.4
27	月	33.6	26.3	2.1	7.2	31.3	32.4	60.0	9.6	0.22	ND	86.4
28	火	31.4	25.6	2.0	7.2	29.4	30.6	60.0	8.7	0.21	ND	84.6
29	水	32.1	25.1	1.9	7.2	29.9	30.2	54.4	9.0	0.20	ND	86.1
30	木	31.4	25.1	2.1	7.2	30.7	32.4	51.2	8.5	0.23	0.01	86.4
31	金	33.1	25.1	5.7	7.2	33.0	30.2	52.0	9.3	0.32	0.03	78.0
最大値		35.9	26.9	7.6	7.5	33.0	33.6	66.4	24.7	0.33	0.03	91.8
最小値		25.8	24.5	1.1	7.1	24.5	26.1	51.2	8.0	0.16	ND	70.1
平均値		32.2	25.4	2.4	7.2	30.5	31.7	58.4	10.3	0.22	0.01	85.5

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2012年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	水	33.9	25.0	0.8	7.3	27.8	29.7	60.4	11.3	0.08	ND	80.8
2	木	35.9	25.2	1.1	7.2	32.6	29.3	60.4	13.1	0.09	ND	81.9
3	金	35.3	25.6	1.1	7.3	32.2	29.7	56.4	17.8	0.10	ND	82.8
4	土	34.2	26.2	0.9	7.3	30.0	32.4	52.8	9.9	0.11	ND	86.5
5	日	34.3	27.3	0.8	7.4	31.0	33.6	51.6	10.9	0.12	ND	91.0
6	月	32.8	27.7	0.9	7.4	31.6	32.6	49.2	10.1	0.12	ND	90.5
7	火	33.4	26.4	1.0	7.3	31.5	32.2	56.0	12.9	0.10	ND	87.4
8	水	30.8	26.0	0.9	7.3	31.9	31.8	60.4	11.8	0.11	ND	87.8
9	木	30.2	25.1	1.1	7.3	29.9	33.0	57.6	11.0	0.10	ND	88.5
10	金	31.4	25.0	0.9	7.3	31.6	32.0	56.4	11.3	0.09	ND	87.9
11	土	25.8	25.6	0.7	7.5	30.1	32.2	53.6	10.2	0.11	ND	88.4
12	日	32.1	25.1	0.7	7.5	30.5	32.6	55.6	9.7	0.12	ND	88.8
13	月	28.9	25.4	0.6	7.4	29.6	32.8	55.2	11.6	0.09	ND	87.2
14	火	26.6	25.8	0.7	7.3	30.0	31.2	50.0	9.7	0.08	ND	86.8
15	水	30.3	24.9	1.9	7.0	22.3	26.7	47.2	11.5	0.06	ND	71.5
16	木	31.0	25.0	0.8	7.2	28.1	31.2	60.0	10.2	0.04	ND	83.9
17	金	33.6	25.0	0.9	7.3	31.1	32.4	66.8	9.9	0.05	ND	90.0
18	土	33.6	26.3	0.6	7.5	32.0	32.2	62.4	11.2	0.05	ND	93.0
19	日	32.8	25.8	0.7	7.5	31.2	32.8	64.4	9.3	0.07	ND	89.9
20	月	31.9	26.0	0.7	7.3	28.7	31.8	57.2	9.7	0.06	ND	86.2
21	火	33.1	25.5	0.9	7.3	31.5	33.8	59.2	10.4	0.08	ND	90.0
22	水	34.2	25.6	1.0	7.2	29.5	31.4	61.2	10.9	0.08	ND	86.9
23	木	33.4	26.0	0.8	7.2	30.9	32.8	54.4	9.9	0.08	ND	87.8
24	金	32.2	26.0	0.8	7.3	31.7	35.0	56.8	10.3	0.08	ND	87.8
25	土	32.9	26.5	0.9	7.3	29.8	32.2	52.8	9.6	0.08	ND	88.6
26	日	32.9	26.7	0.8	7.5	28.3	32.4	53.2	10.4	0.09	ND	90.1
27	月	33.6	27.0	0.9	7.3	29.5	33.6	57.6	10.2	0.10	ND	87.1
28	火	31.4	26.2	0.9	7.3	32.1	30.8	62.8	9.2	0.09	ND	86.0
29	水	32.1	25.8	1.0	7.3	32.3	30.2	54.8	10.0	0.09	ND	87.1
30	木	31.4	25.7	1.1	7.3	31.9	31.2	50.0	9.2	0.08	ND	86.6
31	金	33.1	25.7	1.2	7.2	33.0	32.2	46.8	10.5	0.10	ND	83.5
最大値		35.9	27.7	1.9	7.5	33.0	35.0	66.8	17.8	0.12	ND	93.0
最小値		25.8	24.9	0.6	7.0	22.3	26.7	46.8	9.2	0.04	ND	71.5
平均値		32.2	25.8	0.9	7.3	30.5	31.9	56.2	10.8	0.09	ND	86.8

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所