

水質試験結果表(取水分)

2013年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日											
1	月	28.6	20.8	2.7	7.3	29.0	30.6	54.8	8.5	0.30	0.01	83.4
2	火	27.5	21.1	2.9	7.2	30.7	32.4	57.2	7.4	0.28	0.01	85.7
3	水	22.0	20.7	2.8	7.1	31.2	30.6	61.2	7.8	0.27	0.01	84.6
4	木	27.2	19.8	9.7	7.2	24.6	26.7	69.2	6.9	0.49	0.03	72.1
5	金	26.0	19.8	10.9	7.2	21.8	25.7	52.8	5.6	0.47	0.03	61.5
6	土	33.1	19.2	7.7	7.3	18.7	21.3	46.0	6.4	0.35	0.02	57.1
7	日	27.0	19.5	4.6	7.4	22.6	24.3	42.4	7.7	0.24	0.01	66.4
8	月	31.4	20.2	7.4	7.4	23.7	25.1	59.2	8.4	0.39	0.01	69.4
9	火	32.4	21.0	4.5	7.2	26.7	29.3	54.4	6.5	0.30	0.02	75.4
10	水	29.7	21.4	4.0	7.2	25.5	26.1	54.4	6.1	0.32	0.02	72.8
11	木	32.7	21.0	3.7	7.2	27.0	27.5	58.4	7.0	0.28	0.01	74.3
12	金	32.3	22.2	3.4	7.2	26.5	25.5	50.4	7.7	0.27	ND	73.9
13	土	29.0	23.2	1.8	7.4	27.1	28.3	50.0	7.7	0.24	ND	80.0
14	日	29.4	23.2	16.1	7.3	19.9	22.3	62.0	6.8	0.80	0.02	62.3
15	月	29.2	21.6	15.9	7.3	18.5	21.5	62.4	6.6	0.68	0.01	58.1
16	火	28.7	19.7	11.6	7.3	20.0	23.5	62.0	7.4	0.54	0.01	61.2
17	水	29.5	19.9	5.3	7.3	23.7	25.9	56.8	6.5	0.28	ND	68.6
18	木	28.6	21.0	10.6	7.3	26.1	25.1	60.8	6.4	0.48	0.03	66.1
19	金	28.2	19.8	15.0	7.3	20.3	23.5	58.4	5.9	0.37	0.03	59.2
20	土	27.8	20.0	4.6	7.5	24.4	27.9	56.0	6.1	0.30	ND	69.4
21	日	29.6	21.0	3.4	7.5	25.9	26.9	59.2	6.6	0.21	ND	70.0
22	月	28.5	21.6	3.7	7.4	25.6	26.8	55.2	7.1	0.24	ND	69.8
23	火	30.8	20.9	4.8	7.3	24.9	25.9	53.2	6.8	0.30	0.01	68.8
24	水	25.3	21.8	4.3	7.3	24.3	24.9	53.2	6.5	0.28	0.03	68.9
25	木	30.9	20.1	10.6	7.3	21.3	23.5	58.8	7.0	0.46	0.02	60.8
26	金	32.3	21.2	7.6	7.3	23.2	24.3	52.0	6.3	0.33	0.01	65.4
27	土	29.2	22.0	10.4	7.3	23.5	24.5	60.0	7.4	0.14	0.03	68.5
28	日	28.3	22.1	2.5	7.4	27.7	27.1	54.8	9.0	0.19	0.01	75.6
29	月	23.4	22.8	3.0	7.3	29.6	28.5	59.2	9.2	0.47	0.01	77.4
30	火	27.9	20.0	110.1	7.1	15.5	19.5	177.2	5.3	1.72	0.04	47.6
31	水	28.9	19.5	31.8	7.3	21.3	23.3	79.6	6.0	1.02	0.04	60.3
最大値		33.1	23.2	110.1	7.5	31.2	32.4	177.2	9.2	1.72	0.04	85.7
最小値		22.0	19.2	1.8	7.1	15.5	19.5	42.4	5.3	0.14	ND	47.6
平均値		28.9	20.9	10.9	7.3	24.2	25.8	61.0	7.0	0.42	0.02	68.9

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2013年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	28.6	21.0	0.6	7.3	27.8	31.6	54.4	8.9	0.05	ND	84.0
2	火	27.5	21.0	0.8	7.3	30.4	31.8	50.8	8.9	0.07	ND	86.3
3	水	22.0	20.7	1.3	7.2	30.0	31.0	56.0	9.4	0.09	ND	85.5
4	木	27.2	19.2	1.2	7.1	24.2	28.5	57.2	8.9	0.04	ND	77.9
5	金	26.0	19.5	1.2	7.0	19.2	25.1	43.6	7.7	0.05	ND	64.2
6	土	33.1	19.0	1.6	7.3	16.7	24.1	40.0	8.6	0.04	ND	60.4
7	日	27.0	19.3	0.8	7.3	20.1	22.7	44.0	8.1	0.02	ND	67.4
8	月	31.4	20.0	0.8	7.2	22.3	26.9	40.0	7.7	0.02	ND	72.1
9	火	32.4	21.0	0.7	7.1	24.1	28.1	47.2	7.8	0.03	ND	76.8
10	水	29.7	21.6	0.9	7.2	25.1	26.3	46.0	7.6	0.04	ND	74.8
11	木	32.7	21.0	1.1	7.2	26.7	27.5	52.0	8.1	0.07	ND	75.3
12	金	32.3	22.2	0.6	7.2	25.3	25.7	46.8	8.7	0.05	ND	74.9
13	土	29.0	23.2	0.5	7.4	26.2	29.3	55.2	8.6	0.06	ND	80.9
14	日	29.4	23.2	0.6	7.3	21.1	25.7	48.0	9.0	0.02	ND	74.0
15	月	29.2	21.8	1.2	7.1	15.5	20.3	46.0	8.5	0.04	ND	62.0
16	火	28.7	20.1	1.3	7.1	16.9	21.3	43.2	8.1	0.04	ND	63.0
17	水	29.5	20.0	1.2	7.1	22.7	25.9	52.4	7.7	0.04	ND	69.5
18	木	28.6	21.0	0.9	7.1	28.1	26.3	48.0	8.4	0.03	ND	71.6
19	金	28.2	20.0	1.6	7.2	19.4	21.9	44.0	7.4	0.03	ND	64.5
20	土	27.8	20.0	1.1	7.3	26.7	27.2	47.2	8.8	0.03	ND	70.5
21	日	29.6	21.2	0.5	7.3	23.4	26.3	47.2	8.3	0.02	ND	71.4
22	月	28.5	21.6	0.4	7.2	24.0	28.1	50.8	9.3	0.01	ND	71.6
23	火	30.8	20.9	0.9	7.3	25.0	26.9	52.0	7.7	0.04	ND	70.9
24	水	25.3	21.6	1.1	7.2	24.6	26.9	47.2	8.7	0.04	ND	72.3
25	木	30.9	20.0	1.5	7.0	19.9	21.9	46.0	8.1	0.04	ND	62.0
26	金	32.3	21.2	1.0	7.1	21.8	24.5	44.0	7.4	0.03	ND	67.0
27	土	29.2	21.8	1.1	7.0	23.2	24.5	46.0	10.9	0.02	ND	70.5
28	日	28.3	22.0	0.4	7.2	26.4	28.9	54.4	10.0	0.02	ND	76.8
29	月	23.4	22.2	0.6	7.2	28.8	30.6	54.8	9.9	0.04	0.01	81.1
30	火	27.9	20.0	2.3	6.8	13.0	15.7	36.0	9.2	0.06	ND	55.2
31	水	28.9	19.0	2.1	7.1	18.4	23.1	44.8	8.3	0.05	ND	67.8
最大値		33.1	23.2	2.3	7.4	30.4	31.8	57.2	10.9	0.09	0.01	86.3
最小値		22.0	19.0	0.4	6.8	13.0	15.7	36.0	7.4	0.01	ND	55.2
平均値		28.9	20.8	1.0	7.2	23.1	26.0	47.9	8.5	0.04	ND	71.7

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所