

水質試験結果表(取水分)

2013年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	木	26.8	19.8	19.2	7.2	21.8	24.1	69.2	6.5	0.82	0.02	63.0
2	金	28.2	19.9	19.1	7.2	20.7	21.3	69.6	6.8	0.79	0.02	58.7
3	土	30.3	20.0	6.4	7.5	23.4	23.9	56.4	7.1	0.36	0.01	67.5
4	日	26.2	20.6	5.5	7.5	23.6	25.7	52.8	7.8	0.29	0.01	69.3
5	月	29.4	20.4	8.1	7.3	23.2	23.9	58.8	6.5	0.41	0.01	66.2
6	火	28.8	21.0	6.7	7.4	24.7	24.9	49.2	5.3	0.37	0.02	67.3
7	水	30.7	21.0	10.2	7.4	24.4	27.3	46.4	5.2	0.45	0.05	67.8
8	木	30.6	21.2	5.7	7.4	27.2	28.3	54.4	7.2	0.38	0.02	70.8
9	金	31.1	21.9	4.3	7.3	27.9	26.5	50.8	7.1	0.28	ND	70.4
10	土	32.3	22.5	2.2	7.5	25.6	25.5	45.6	7.3	0.25	0.01	73.1
11	日	32.3	23.3	1.8	7.5	26.6	27.6	48.8	7.0	0.19	ND	73.8
12	月	32.8	23.3	4.6	7.3	26.3	26.1	57.6	6.4	0.47	0.01	72.0
13	火	30.3	22.8	2.4	7.3	26.2	27.3	46.4	6.3	0.26	ND	72.0
14	水	31.3	23.3	1.3	7.3	27.0	26.3	46.0	7.7	0.18	0.01	71.6
15	木	32.4	23.5	1.3	7.3	25.7	26.3	42.0	7.3	0.17	ND	71.4
16	金	32.8	24.1	2.2	7.3	28.9	26.7	48.0	7.0	0.24	ND	71.8
17	土	32.4	24.2	1.0	7.4	27.8	27.1	40.8	6.4	0.16	0.01	73.3
18	日	33.6	24.8	2.4	7.5	26.8	27.1	50.8	7.0	0.28	0.01	73.6
19	月	33.5	24.2	2.1	7.3	28.8	30.6	45.2	7.7	0.28	0.01	78.1
20	火	33.0	24.0	2.4	7.2	27.3	27.5	48.8	7.7	0.22	0.01	72.2
21	水	32.8	23.3	2.4	7.2	25.8	26.6	48.8	6.7	0.22	0.01	71.6
22	木	32.1	23.2	2.2	7.2	25.2	27.1	46.8	6.4	0.21	ND	71.6
23	金	30.8	23.6	1.9	7.3	25.9	26.5	45.6	6.5	0.19	ND	71.4
24	土	27.2	23.0	19.1	7.1	18.9	19.3	70.4	5.3	0.92	0.02	57.5
25	日	23.9	22.2	9.3	7.4	25.8	25.1	57.2	6.4	0.43	0.01	70.7
26	月	28.2	21.8	5.0	7.3	28.4	29.3	60.0	6.8	0.35	0.01	77.7
27	火	26.5	21.5	4.0	7.3	28.6	30.2	59.2	6.5	0.30	0.01	77.3
28	水	26.2	21.5	2.9	7.3	26.5	27.9	51.2	6.4	0.23	0.01	74.6
29	木	28.3	21.0	2.8	7.3	27.3	27.1	47.6	5.6	0.22	ND	72.3
30	金	31.3	21.8	2.9	7.3	26.6	27.3	54.4	7.2	0.24	ND	72.9
31	土	31.2	21.6	2.5	7.3	26.2	27.5	53.2	7.3	0.23	0.01	72.0
最大値		33.6	24.8	19.2	7.5	28.9	30.6	70.4	7.8	0.92	0.05	78.1
最小値		23.9	19.8	1.0	7.1	18.9	19.3	40.8	5.2	0.16	ND	57.5
平均値		30.2	22.3	5.3	7.3	25.8	26.4	52.3	6.7	0.34	0.01	70.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2013年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	木	26.8	19.3	1.5	7.1	22.3	25.5	46.4	9.8	0.04	ND	73.0
2	金	28.2	19.8	2.8	7.0	19.3	23.9	48.0	10.4	0.07	ND	66.3
3	土	30.3	20.0	1.5	7.3	22.3	24.5	50.8	9.8	0.04	ND	72.0
4	日	26.2	20.8	0.8	7.3	21.9	26.5	51.2	9.5	0.02	ND	72.1
5	月	29.4	20.3	0.8	7.1	21.3	25.5	44.4	8.4	0.02	ND	70.1
6	火	28.8	21.0	1.1	7.2	21.5	26.9	43.6	7.1	0.05	ND	70.2
7	水	30.7	21.0	1.5	7.1	20.8	23.7	42.8	6.2	0.05	ND	69.2
8	木	30.6	21.6	0.9	7.1	27.6	24.3	51.6	8.8	0.05	ND	72.1
9	金	31.1	22.0	0.5	7.2	29.1	24.5	47.2	8.9	0.02	ND	72.2
10	土	32.3	22.7	0.4	7.3	24.5	26.5	50.0	8.9	0.03	ND	74.0
11	日	32.3	23.3	0.3	7.4	25.5	26.1	50.8	8.5	0.03	ND	75.0
12	月	32.8	23.3	0.1	7.3	25.5	27.1	48.0	8.5	0.02	ND	73.5
13	火	30.3	23.2	0.4	7.3	26.2	27.3	45.2	7.2	0.03	ND	73.7
14	水	31.3	23.4	0.2	7.3	26.1	25.7	45.6	8.1	0.06	ND	72.8
15	木	32.4	23.6	0.6	7.3	27.7	25.5	46.8	8.0	0.04	ND	72.5
16	金	32.8	24.0	0.4	7.3	31.5	27.7	49.6	7.8	0.06	ND	73.0
17	土	32.4	24.3	0.5	7.4	28.0	26.1	46.0	8.0	0.07	ND	74.2
18	日	33.6	24.9	0.4	7.3	25.0	28.5	41.2	8.8	0.03	ND	75.0
19	月	33.5	24.5	0.4	7.3	28.0	28.9	46.4	9.2	0.04	ND	78.9
20	火	33.0	24.0	0.7	7.2	27.2	27.1	50.0	8.1	0.04	ND	73.8
21	水	32.8	23.3	1.0	7.2	26.7	26.9	42.0	8.3	0.06	ND	73.0
22	木	32.1	23.2	1.0	7.2	26.9	28.9	46.8	7.4	0.06	ND	73.7
23	金	30.8	23.5	1.0	7.2	25.8	27.9	46.8	6.9	0.07	ND	72.4
24	土	27.2	22.7	1.3	7.1	17.8	22.1	43.2	8.8	0.04	ND	65.2
25	日	23.9	22.3	1.6	7.3	22.9	28.1	44.0	8.5	0.05	ND	75.0
26	月	28.2	21.9	1.0	7.3	28.2	29.1	48.4	8.4	0.04	ND	77.9
27	火	26.5	21.5	1.1	7.2	28.9	28.7	56.0	8.7	0.05	ND	79.3
28	水	26.2	21.5	0.9	7.2	27.1	28.7	50.4	7.8	0.05	ND	76.7
29	木	28.3	20.8	0.9	7.2	26.9	27.3	47.2	7.6	0.06	ND	74.0
30	金	31.3	21.6	0.8	7.3	26.9	26.1	50.4	8.5	0.04	ND	73.6
31	土	31.2	21.4	0.7	7.2	25.6	28.1	49.6	9.4	0.05	ND	73.1
最大値		33.6	24.9	2.8	7.4	31.5	29.1	56.0	10.4	0.07	ND	79.3
最小値		23.9	19.3	0.1	7.0	17.8	22.1	41.2	6.2	0.02	ND	65.2
平均値		30.2	22.3	0.9	7.2	25.3	26.6	47.4	8.4	0.04	ND	73.1

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所