

水質試験結果表(取水分)

2013年9月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	23.4	22.3	11.1	7.2	21.4	25.9	56.4	6.4	0.48	0.06	61.8
2	月	24.6	21.3	5.7	7.2	26.0	25.7	66.8	7.2	0.34	0.02	71.8
3	火	27.1	20.5	6.5	7.3	24.7	26.7	60.4	6.4	0.36	0.03	68.9
4	水	25.7	20.1	11.7	7.2	21.0	23.1	57.6	5.1	0.62	0.06	62.0
5	木	26.6	19.0	89.9	7.2	19.5	19.5	154.8	5.2	1.64	0.14	52.5
6	金	24.3	18.7	12.5	7.3	24.5	24.7	64.4	6.7	0.52	0.02	66.4
7	土	22.9	18.8	5.9	7.4	25.5	26.1	60.4	7.9	0.36	0.03	70.5
8	日	22.8	18.7	5.7	7.4	25.6	26.3	49.2	6.9	0.30	0.03	68.8
9	月	27.2	18.6	6.6	7.3	23.6	24.9	51.6	6.5	0.32	0.03	68.3
10	火	27.4	18.6	5.4	7.3	24.5	24.9	60.0	6.8	0.31	0.01	69.4
11	水	28.0	18.6	4.9	7.3	24.6	26.1	50.4	6.6	0.27	ND	70.2
12	木	28.7	19.0	4.1	7.3	26.3	27.5	58.0	6.6	0.26	0.01	70.8
13	金	30.6	18.8	3.5	7.2	26.4	27.1	54.0	7.1	0.24	ND	72.1
14	土	30.9	19.3	2.2	7.2	26.7	27.3	52.0	6.1	0.16	ND	73.6
15	日	23.4	20.2	2.7	7.6	26.3	30.6	48.8	5.4	0.13	ND	73.7
16	月	23.0	20.8	4.8	7.3	26.4	27.1	52.8	5.2	0.19	0.01	73.6
17	火	25.2	18.0	51.0	6.0	20.4	22.9	95.2	4.3	1.82	0.06	73.5
18	水	24.8	17.3	17.3	7.3	24.3	23.7	66.4	6.9	0.70	0.04	67.0
19	木	27.6	17.3	9.5	7.4	25.1	27.5	60.8	4.5	0.43	0.03	69.2
20	金	26.8	17.9	8.9	7.3	25.0	24.7	58.0	6.2	0.38	0.01	69.2
21	土	27.3	18.2	4.8	7.5	26.7	27.9	50.8	6.5	0.29	0.01	70.3
22	日	24.3	18.7	5.2	7.4	27.3	27.7	50.4	8.1	0.27	0.01	71.7
23	月	27.7	18.9	5.8	7.3	27.6	28.9	60.4	10.6	0.35	0.01	78.0
24	火	29.1	19.4	6.2	7.2	27.3	27.5	54.0	8.9	0.35	0.01	75.9
25	水	28.8	18.9	4.1	7.3	26.0	28.5	55.2	7.9	0.26	0.01	71.2
26	木	22.0	18.9	3.7	7.3	27.0	28.3	47.2	7.0	0.23	ND	70.0
27	金	23.9	16.9	3.3	7.3	26.2	26.9	48.4	7.6	0.23	ND	69.4
28	土	24.6	17.2	1.8	7.4	27.1	26.1	47.2	7.9	0.17	ND	72.2
29	日	26.5	18.3	1.9	7.4	28.5	29.3	54.4	9.6	0.17	ND	79.4
30	月	23.8	18.8	2.6	7.3	28.7	30.2	46.4	8.8	0.28	0.01	78.4
最大値		30.9	22.3	89.9	7.6	28.7	30.6	154.8	10.6	1.82	0.14	79.4
最小値		22.0	16.9	1.8	6.0	19.5	19.5	46.4	4.3	0.13	ND	52.5
平均値		26.0	18.9	10.3	7.3	25.3	26.5	59.7	6.9	0.41	0.02	70.3

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2013年9月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	日	23.4	22.1	0.7	7.2	22.9	25.1	46.4	8.2	0.03	ND	72.0
2	月	24.6	21.1	0.9	7.1	23.4	26.5	42.4	8.0	0.04	ND	73.6
3	火	27.1	20.2	1.7	7.2	23.9	24.5	49.2	7.8	0.06	ND	72.2
4	水	25.7	20.0	1.2	7.2	20.4	24.7	38.8	6.7	0.05	ND	69.9
5	木	26.6	18.6	2.5	7.0	18.9	20.7	48.0	6.4	0.08	ND	62.8
6	金	24.3	18.3	2.3	7.1	23.0	25.1	54.0	9.0	0.07	ND	70.9
7	土	22.9	18.6	1.7	7.3	26.7	26.9	52.8	8.7	0.06	0.01	73.5
8	日	22.8	18.5	1.2	7.3	24.3	27.1	48.4	8.9	0.04	0.01	74.1
9	月	27.2	18.8	1.0	7.2	25.3	25.7	45.6	7.9	0.03	0.01	69.4
10	火	27.4	18.9	1.3	7.1	24.5	25.1	52.8	8.2	0.05	ND	71.4
11	水	28.0	18.8	1.3	7.2	23.5	25.5	54.4	8.8	0.05	ND	72.0
12	木	28.7	19.2	0.8	7.2	26.8	26.7	48.8	7.4	0.03	ND	72.0
13	金	30.6	19.0	1.2	7.1	25.3	26.5	48.8	8.6	0.05	ND	73.1
14	土	30.9	19.4	0.7	7.3	25.2	28.5	50.4	7.1	0.04	ND	73.0
15	日	23.4	20.0	1.1	7.6	24.9	28.5	49.2	7.1	0.03	ND	74.0
16	月	23.0	20.0	1.6	7.6	23.8	29.7	51.2	6.8	0.04	ND	72.9
17	火	25.2	18.0	2.2	6.8	20.0	23.9	48.0	7.6	0.08	ND	71.0
18	水	24.8	17.3	2.4	7.2	23.5	25.9	49.6	8.6	0.07	ND	73.6
19	木	27.6	17.3	1.6	7.3	23.3	26.3	49.2	6.6	0.06	ND	74.6
20	金	26.8	18.0	1.7	7.0	24.3	26.3	48.0	8.6	0.05	ND	71.8
21	土	27.3	18.0	1.4	7.3	26.3	27.9	50.0	10.0	0.05	ND	72.8
22	日	24.3	18.7	0.7	7.3	27.8	26.9	46.4	9.3	0.02	ND	72.8
23	月	27.7	18.7	0.6	7.2	25.2	29.7	50.8	11.2	0.03	ND	78.6
24	火	29.1	19.1	0.8	7.1	26.1	29.5	51.2	10.7	0.04	ND	79.7
25	水	28.8	18.9	1.5	7.1	25.2	27.5	53.2	9.3	0.06	ND	73.9
26	木	22.0	18.9	1.2	7.2	25.4	26.7	44.4	8.8	0.05	ND	71.8
27	金	23.9	17.0	1.2	7.2	24.5	26.7	46.0	8.6	0.06	ND	71.0
28	土	24.6	17.0	1.4	7.3	25.7	27.3	42.8	9.4	0.08	ND	72.6
29	日	26.5	18.1	0.8	7.4	26.7	29.7	48.0	11.1	0.06	ND	80.2
30	月	23.8	18.5	0.9	7.3	27.4	31.0	45.2	8.5	0.07	ND	79.1
最大値		30.9	22.1	2.5	7.6	27.8	31.0	54.4	11.2	0.08	0.01	80.2
最小値		22.0	17.0	0.6	6.8	18.9	20.7	38.8	6.4	0.02	ND	62.8
平均値		26.0	18.8	1.3	7.2	24.5	26.7	48.5	8.5	0.05	ND	73.0

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所