

水質試験結果表(取水分)

2013年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	火	29.4	18.1	2.6	7.2	26.6	26.5	48.0	7.0	0.20	0.01	69.9
2	水	29.2	19.1	2.4	7.3	27.3	29.7	50.4	7.3	0.22	0.01	76.8
3	木	23.9	19.0	2.1	7.3	26.7	28.7	46.8	8.1	0.18	ND	71.9
4	金	23.6	18.0	1.9	7.3	27.0	26.3	46.4	10.2	0.16	ND	72.7
5	土	21.3	18.1	1.4	7.5	26.5	28.5	52.0	6.5	0.11	ND	73.6
6	日	27.1	18.4	1.4	7.4	25.1	27.3	60.0	5.1	0.12	ND	74.0
7	月	26.3	19.4	2.8	7.2	27.3	30.8	56.8	5.4	0.20	0.01	78.1
8	火	26.9	19.7	1.5	7.3	28.0	28.9	57.2	7.2	0.15	ND	80.1
9	水	29.7	19.9	1.7	7.3	28.5	30.2	54.8	8.5	0.13	0.01	79.0
10	木	30.0	19.6	1.6	7.3	27.1	28.3	52.0	8.0	0.14	ND	77.7
11	金	26.0	20.2	1.4	7.3	27.7	28.9	57.6	7.9	0.13	ND	78.3
12	土	26.2	19.8	1.1	7.4	28.9	29.9	58.4	8.5	0.13	ND	79.0
13	日	25.0	18.2	1.1	7.4	27.0	28.5	56.4	8.5	0.16	ND	77.3
14	月	21.8	18.0	1.1	7.4	28.8	29.7	63.6	8.5	0.17	ND	80.1
15	火	21.7	18.0	1.6	7.3	29.3	33.8	59.2	9.4	0.20	ND	83.3
16	水	18.1	17.3	4.0	7.3	26.3	27.1	51.2	7.9	0.24	0.02	73.0
17	木	20.0	15.5	6.0	7.3	20.7	22.1	52.4	8.1	0.28	0.02	64.5
18	金	17.7	15.2	2.9	7.3	26.7	28.9	58.4	7.7	0.22	0.01	70.8
19	土	17.2	15.8	1.5	7.4	27.9	30.4	54.4	7.6	0.15	ND	80.3
20	日	17.2	16.4	1.0	7.5	29.9	32.4	56.0	8.2	0.14	ND	84.3
21	月	21.1	16.1	1.9	7.4	28.0	30.6	58.0	9.3	0.18	0.01	80.9
22	火	23.8	16.7	1.6	7.4	28.9	31.4	62.0	8.9	0.16	ND	82.2
23	水	18.7	16.9	1.4	7.3	27.4	30.2	53.2	8.1	0.13	ND	79.4
24	木	19.3	16.8	1.3	7.3	29.8	32.2	60.0	8.5	0.14	ND	82.7
25	金	18.3	16.9	2.8	7.3	27.8	30.6	56.4	6.5	0.18	ND	76.2
26	土	14.8	16.2	9.3	7.4	26.9	23.9	68.0	6.9	0.54	0.02	63.0
27	日	18.7	15.0	5.1	7.5	26.7	25.5	53.2	7.2	0.27	0.02	68.8
28	月	16.8	14.4	2.5	7.4	29.7	29.5	56.4	8.0	0.17	ND	76.8
29	火	15.3	14.3	2.1	7.4	29.8	30.6	62.0	8.1	0.16	0.01	84.8
30	水	20.8	14.5	2.9	7.4	28.0	28.1	58.4	8.7	0.19	0.01	76.3
31	木	17.3	14.6	2.4	7.3	28.3	30.4	56.0	8.1	0.17	ND	75.4
最大値		30.0	20.2	9.3	7.5	29.9	33.8	68.0	10.2	0.54	0.02	84.8
最小値		14.8	14.3	1.0	7.2	20.7	22.1	46.4	5.1	0.11	ND	63.0
平均値		22.0	17.3	2.4	7.3	27.6	29.0	56.0	7.9	0.18	0.01	76.5

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2013年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	火	29.4	18.0	1.1	7.2	25.0	27.3	48.4	8.4	0.06	ND	72.2
2	水	29.2	19.2	0.9	7.3	27.9	29.7	44.0	8.7	0.08	ND	80.2
3	木	23.9	19.0	1.1	7.2	27.3	27.3	48.8	9.2	0.07	ND	73.5
4	金	23.6	18.0	1.2	7.3	27.1	27.1	50.0	8.8	0.08	ND	73.6
5	土	21.3	18.0	1.0	7.4	25.0	27.7	48.0	5.7	0.06	ND	73.1
6	日	27.1	18.3	1.3	7.4	24.7	28.1	48.0	6.1	0.05	ND	75.0
7	月	26.3	19.3	0.9	7.3	27.0	29.7	55.6	5.9	0.10	ND	78.6
8	火	26.9	19.8	0.9	7.3	29.0	30.4	54.0	7.4	0.08	ND	80.3
9	水	29.7	19.6	0.9	7.3	28.7	29.5	52.0	9.9	0.06	ND	80.4
10	木	30.0	19.5	1.2	7.3	29.0	28.9	54.0	9.6	0.08	ND	79.6
11	金	26.0	20.0	1.1	7.3	27.6	29.3	56.4	9.7	0.07	ND	79.5
12	土	26.2	19.8	0.9	7.4	29.1	29.3	57.2	9.2	0.08	ND	80.7
13	日	25.0	18.3	0.6	7.4	26.8	28.3	54.0	9.4	0.06	ND	78.3
14	月	21.8	18.2	0.7	7.4	27.0	30.4	57.2	10.6	0.07	ND	79.7
15	火	21.7	18.0	0.7	7.3	29.0	31.8	54.8	10.7	0.06	ND	83.9
16	水	18.1	17.0	1.0	7.2	28.2	29.5	45.6	10.3	0.05	ND	79.2
17	木	20.0	15.4	1.9	7.0	17.4	22.9	49.6	10.3	0.07	ND	67.1
18	金	17.7	15.2	1.3	7.2	25.4	27.1	53.6	8.8	0.07	ND	71.6
19	土	17.2	15.7	0.8	7.4	26.3	28.9	58.8	9.2	0.07	ND	79.2
20	日	17.2	16.1	0.5	7.4	28.9	32.4	58.8	9.2	0.06	ND	85.3
21	月	21.1	16.0	0.6	7.4	28.2	32.8	55.6	10.0	0.05	ND	84.3
22	火	23.8	16.7	1.3	7.3	29.5	32.6	56.8	9.8	0.08	ND	84.7
23	水	18.7	16.9	1.1	7.3	28.5	32.4	54.8	8.5	0.08	ND	80.1
24	木	19.3	16.6	1.2	7.4	29.6	31.8	62.4	10.2	0.08	ND	83.8
25	金	18.3	16.7	1.0	7.3	27.0	31.4	58.8	7.0	0.06	ND	79.6
26	土	14.8	16.2	1.2	7.2	24.1	22.9	50.0	8.3	0.04	ND	65.6
27	日	18.7	15.0	1.4	7.3	25.9	24.7	51.2	7.8	0.05	ND	69.1
28	月	16.8	14.5	1.3	7.4	29.0	27.7	52.8	9.7	0.04	ND	76.4
29	火	15.3	14.1	1.1	7.4	29.0	32.0	59.2	9.2	0.07	ND	85.2
30	水	20.8	14.0	1.2	7.3	28.1	31.4	58.8	9.2	0.05	ND	80.1
31	木	17.3	14.5	1.1	7.3	27.2	29.3	54.0	8.6	0.05	ND	77.5
最大値		30.0	20.0	1.9	7.4	29.6	32.8	62.4	10.7	0.10	ND	85.3
最小値		14.8	14.0	0.5	7.0	17.4	22.9	44.0	5.7	0.04	ND	65.6
平均値		22.0	17.2	1.0	7.3	27.2	29.2	53.7	8.9	0.07	ND	78.0

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所