

水質試験結果表(取水分)

2014年3月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	土	8.8	7.4	1.9	7.3	20.6	26.9	49.6	7.6	0.16	0.02	67.0
2	日	9.7	7.5	1.8	7.3	21.7	27.1	52.8	8.2	0.13	0.01	70.5
3	月	6.5	7.3	2.4	7.2	23.0	26.1	52.4	8.5	0.14	0.01	71.8
4	火	8.0	6.5	1.7	7.4	25.1	26.9	61.6	8.1	0.12	ND	71.2
5	水	9.6	7.4	2.2	7.2	25.8	26.3	57.6	8.3	0.13	ND	70.7
6	木	7.7	7.0	2.3	7.2	22.2	25.1	47.6	8.1	0.15	ND	67.8
7	金	3.9	7.4	1.9	7.3	24.2	24.9	55.2	8.4	0.13	ND	69.7
8	土	2.6	5.6	2.6	7.5	24.2	27.1	72.8	6.7	0.08	ND	70.6
9	日	3.1	5.7	2.7	7.5	23.8	27.3	59.2	7.9	0.10	ND	71.8
10	月	5.1	6.0	3.9	7.5	25.2	28.3	56.4	6.3	0.12	ND	79.3
11	火	4.3	4.8	5.2	7.4	27.9	33.2	85.2	16.1	0.30	0.04	118.5
12	水	7.7	6.5	4.6	7.3	28.7	35.0	101.2	18.9	0.31	0.02	133.7
13	木	9.8	7.8	6.4	7.2	29.4	35.0	90.0	17.4	0.29	0.02	124.0
14	金	4.4	7.2	40.3	7.0	16.7	23.5	94.4	11.5	1.47	0.17	77.7
15	土	4.4	6.9	9.0	7.3	18.0	24.1	70.4	13.8	0.49	0.09	90.3
16	日	9.2	7.6	3.8	7.3	21.8	27.3	72.0	14.3	0.27	0.03	98.7
17	月	9.5	7.2	3.6	7.2	22.8	28.1	72.4	13.6	0.25	0.03	104.6
18	火	11.6	8.7	3.0	7.1	24.1	29.1	80.0	15.2	0.24	0.01	103.1
19	水	12.3	8.5	22.9	7.2	21.3	26.5	74.8	14.0	0.84	0.09	91.6
20	木	8.1	8.8	8.2	7.0	21.7	25.3	74.4	12.8	0.38	0.03	88.5
21	金	5.3	8.2	10.4	7.3	21.0	24.1	72.0	12.2	0.58	0.04	87.8
22	土	8.2	7.2	5.6	7.3	20.4	27.3	74.0	12.9	0.43	0.02	90.9
23	日	10.0	7.7	3.3	7.4	21.9	27.3	72.8	12.6	0.30	0.02	95.6
24	月	11.7	8.7	4.2	7.3	23.2	28.1	76.8	15.5	0.27	0.01	99.8
25	火	13.4	10.0	4.5	7.2	26.5	28.9	79.2	15.5	0.28	0.02	99.1
26	水	13.5	9.7	3.5	7.2	26.9	29.1	69.2	13.1	0.22	0.01	101.9
27	木	12.1	10.1	4.5	7.1	24.7	29.9	67.2	14.9	0.25	0.01	101.8
28	金	14.5	10.4	8.7	7.2	20.2	24.5	62.8	11.0	0.36	0.03	82.5
29	土	19.0	10.8	3.7	7.3	21.7	25.9	60.8	10.7	0.24	0.02	86.0
30	日	16.1	11.5	3.1	7.4	22.8	24.9	58.0	10.2	0.21	0.01	84.9
31	月	15.9	11.1	72.0	6.6	16.5	21.3	113.2	8.8	1.63	0.09	66.0
最大値		19.0	11.5	72.0	7.5	29.4	35.0	113.2	18.9	1.63	0.17	133.7
最小値		2.6	4.8	1.7	6.6	16.5	21.3	47.6	6.3	0.08	ND	66.0
平均値		9.2	8.0	8.2	7.2	23.0	27.2	70.5	11.7	0.35	0.03	88.3

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2014年3月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	土	8.8	7.6	1.0	7.2	18.6	23.5	50.0	10.5	0.04	ND	75.0
2	日	9.7	7.4	1.2	7.2	22.0	23.5	48.8	8.6	0.05	ND	71.8
3	月	6.5	7.4	1.0	7.1	21.3	28.1	52.0	8.8	0.06	ND	73.3
4	火	8.0	6.7	1.1	7.3	23.5	25.9	58.8	7.8	0.07	ND	71.5
5	水	9.6	7.3	1.3	7.1	25.9	24.1	57.6	8.1	0.06	ND	72.0
6	木	7.7	7.2	1.4	7.2	22.6	25.3	50.0	9.3	0.07	ND	68.7
7	金	3.9	7.5	1.4	7.2	22.0	25.1	62.0	8.9	0.08	ND	70.7
8	土	2.6	5.7	0.7	7.5	22.4	26.6	55.6	7.1	0.04	ND	69.8
9	日	3.1	5.8	0.9	7.5	23.5	26.9	52.4	7.2	0.04	ND	72.5
10	月	5.1	6.0	0.8	7.4	23.0	28.9	57.2	8.7	0.04	ND	78.4
11	火	4.3	4.9	2.0	7.2	26.9	31.6	79.2	15.3	0.10	0.01	119.4
12	水	7.7	6.1	1.7	7.2	28.0	35.0	98.0	18.1	0.09	ND	129.0
13	木	9.8	7.3	2.6	7.1	27.4	32.4	90.0	17.3	0.10	ND	124.3
14	金	4.4	7.2	4.5	6.7	14.7	22.5	73.6	14.0	0.16	0.03	88.4
15	土	4.4	6.9	2.0	7.2	16.7	24.1	67.2	15.7	0.08	0.01	96.4
16	日	9.2	7.4	1.1	7.2	18.1	26.1	59.2	15.7	0.06	0.02	99.8
17	月	9.5	7.2	1.2	7.1	19.4	28.1	68.4	15.0	0.07	ND	106.3
18	火	11.6	8.6	1.2	7.0	23.3	30.2	78.0	16.5	0.08	ND	106.6
19	水	12.3	8.7	2.4	7.2	21.5	27.3	84.8	16.6	0.08	0.01	106.2
20	木	8.1	8.8	2.1	6.9	19.4	25.5	68.8	15.4	0.08	ND	95.4
21	金	5.3	8.2	1.2	7.2	18.3	27.3	67.6	14.9	0.08	ND	99.3
22	土	8.2	7.3	1.3	7.4	19.4	24.1	68.4	15.7	0.08	ND	96.6
23	日	10.0	7.5	1.6	7.2	18.7	26.1	65.2	14.7	0.07	0.01	96.3
24	月	11.7	8.2	0.8	7.2	20.5	28.1	72.0	15.2	0.05	ND	100.2
25	火	13.4	10.0	1.4	7.1	23.5	31.0	80.8	16.5	0.08	ND	104.4
26	水	13.5	9.6	1.7	7.1	25.0	30.2	66.4	15.2	0.08	ND	102.4
27	木	12.1	10.0	1.3	7.1	23.4	29.1	69.2	16.4	0.07	ND	103.1
28	金	14.5	10.6	1.7	7.0	18.4	25.5	59.2	12.8	0.07	ND	87.6
29	土	19.0	11.0	1.1	7.2	19.4	27.3	64.0	13.3	0.07	ND	88.4
30	日	16.1	11.5	1.1	7.1	21.1	27.5	58.8	12.9	0.05	0.01	89.4
31	月	15.9	11.6	2.5	6.7	16.2	23.7	54.4	12.9	0.08	0.01	84.2
最大値		19.0	11.6	4.5	7.5	28.0	35.0	98.0	18.1	0.16	0.03	129.0
最小値		2.6	4.9	0.7	6.7	14.7	22.5	48.8	7.1	0.04	ND	68.7
平均値		9.2	8.0	1.5	7.2	21.4	27.1	65.7	13.1	0.07	ND	91.9

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所