

水質試験結果表(取水分)

2014年4月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	火	16.1	10.5	37.1	7.2	18.5	22.3	86.0	12.3	1.37	0.11	77.2
2	水	17.2	10.6	15.9	7.2	21.0	24.5	70.8	12.7	0.69	0.04	81.7
3	木	20.3	11.3	9.5	7.2	22.8	25.3	69.6	12.4	0.49	0.01	85.4
4	金	13.8	11.9	7.5	7.1	22.2	25.7	59.6	11.6	0.37	0.02	86.0
5	土	6.3	10.6	12.0	7.3	21.8	26.3	74.0	12.1	0.28	0.04	88.1
6	日	7.4	10.3	9.6	7.3	23.3	28.3	74.4	12.6	0.13	0.03	90.8
7	月	11.1	9.4	7.4	7.3	23.7	28.3	82.0	13.1	0.17	0.03	97.4
8	火	13.1	10.3	7.1	7.1	27.6	28.9	79.2	12.6	0.29	0.02	97.4
9	水	17.3	11.2	6.1	7.1	25.4	28.5	74.8	12.1	0.42	0.03	95.5
10	木	16.0	11.5	7.1	7.2	24.2	27.3	70.8	11.0	0.46	0.03	92.8
11	金	14.0	10.1	6.4	7.2	25.4	28.3	71.2	11.3	0.35	0.04	95.6
12	土	12.6	10.4	5.5	7.3	27.9	27.9	67.2	12.0	0.36	0.04	99.4
13	日	11.3	10.8	10.6	7.3	25.7	28.9	74.0	12.1	0.58	0.07	94.9
14	月	16.7	10.5	7.4	7.2	27.4	29.3	73.6	12.6	0.38	0.05	95.5
15	火	17.3	11.3	14.1	7.2	26.1	31.0	172.8	12.0	0.72	0.07	100.2
16	水	17.4	12.0	9.0	7.2	28.1	33.0	104.0	23.0	0.48	0.06	142.6
17	木	18.8	11.5	2.0	7.2	23.1	26.5	54.0	8.6	0.17	0.01	68.7
18	金	16.6	11.7	2.7	7.1	22.2	24.3	48.0	7.8	0.18	ND	63.2
19	土	15.7	11.3	2.0	7.3	20.4	22.5	51.6	6.0	0.18	0.01	61.9
20	日	11.3	11.0	2.2	7.3	21.8	23.9	49.2	8.0	0.16	0.01	65.3
21	月	15.1	11.0	3.0	7.2	23.5	27.5	56.0	8.0	0.20	0.01	69.4
22	火	17.3	11.2	5.7	7.2	21.4	22.1	49.6	7.8	0.25	0.03	62.6
23	水	17.3	11.0	4.5	7.2	21.5	22.7	48.0	9.5	0.21	0.01	62.8
24	木	17.9	11.4	4.8	7.2	23.8	23.9	51.6	9.5	0.23	0.01	63.8
25	金	19.7	12.0	4.8	7.1	23.1	24.1	48.0	8.6	0.25	0.01	67.1
26	土	20.4	11.8	3.5	7.3	24.5	25.3	58.4	8.7	0.24	0.01	70.0
27	日	22.3	13.3	3.4	7.3	26.4	25.9	52.0	9.2	0.24	0.01	71.4
28	月	19.0	13.9	5.3	7.2	24.3	26.9	56.4	8.0	0.30	0.02	71.4
29	火	17.7	13.4	6.1	7.3	24.0	26.7	60.4	8.5	0.33	0.02	73.5
30	水	19.8	13.2	6.8	7.3	23.6	26.9	56.0	8.4	0.29	0.02	69.4
最大値		22.3	13.9	37.1	7.3	28.1	33.0	172.8	23.0	1.37	0.11	142.6
最小値		6.3	9.4	2.0	7.1	18.5	22.1	48.0	6.0	0.13	ND	61.9
平均値		15.9	11.3	7.6	7.2	23.8	26.4	68.1	10.7	0.36	0.03	82.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

