

水質試験結果表(取水分)

2014年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	金	32.5	24.0	2.1	7.1	30.3	29.7	56.0	7.0	0.19	ND	80.0
2	土	31.3	24.5	1.8	7.3	29.2	30.6	53.2	5.9	0.21	0.01	81.3
3	日	30.3	24.0	2.0	7.3	29.5	30.8	54.0	6.5	0.23	0.01	84.6
4	月	29.7	23.8	2.6	7.2	31.1	32.6	57.2	7.0	0.27	0.01	86.0
5	火	31.3	23.6	2.3	7.2	31.3	32.4	57.2	6.6	0.24	0.01	84.3
6	水	32.8	23.9	2.0	7.3	29.9	33.4	46.4	6.3	0.21	0.01	83.6
7	木	30.6	23.7	2.4	7.2	28.5	30.2	48.0	7.0	0.21	0.01	80.6
8	金	26.7	23.1	4.4	7.1	27.4	28.9	52.0	6.3	0.24	0.01	76.0
9	土	22.2	22.0	3.7	7.4	21.4	23.3	48.0	5.2	0.16	0.01	62.0
10	日	26.1	21.2	9.4	7.4	23.7	24.1	64.0	6.0	0.44	0.01	67.9
11	月	26.4	20.5	175.6	7.1	18.4	21.1	224.0	4.7	1.31	0.03	50.6
12	火	25.1	19.4	103.8	7.2	22.3	25.1	140.8	6.0	0.80	0.25	60.0
13	水	29.7	19.9	51.8	7.2	23.1	25.7	95.6	6.3	0.76	0.12	64.6
14	木	27.8	20.3	22.6	7.2	24.2	25.7	70.0	7.1	0.71	0.06	67.6
15	金	29.3	21.5	15.7	7.2	25.3	26.7	58.0	5.5	0.50	0.04	69.1
16	土	24.1	22.0	14.8	7.3	21.6	31.6	68.8	8.8	0.89	0.04	59.3
17	日	25.8	21.2	20.0	7.3	19.5	23.5	74.8	7.9	0.95	0.02	53.8
18	月	28.3	20.4	26.9	7.3	18.8	20.5	87.2	5.1	1.13	0.02	53.3
19	火	32.3	21.2	17.5	7.3	22.0	21.7	60.0	5.4	0.59	0.03	57.7
20	水	33.1	22.4	18.4	7.1	25.9	29.9	86.0	13.9	0.69	0.09	103.0
21	木	32.6	23.1	13.4	7.1	28.2	32.8	88.8	16.5	0.54	0.06	119.8
22	金	32.5	23.5	10.8	7.2	29.4	33.0	88.8	16.0	0.49	0.02	119.0
23	土	29.1	22.8	6.7	7.3	28.1	34.6	80.0	14.8	0.34	0.03	116.0
24	日	28.9	23.5	6.8	7.3	26.7	34.0	62.8	13.6	0.33	0.02	109.8
25	月	26.7	22.8	9.0	7.2	28.0	34.0	81.6	17.7	0.40	0.01	117.2
26	火	25.9	22.2	7.0	7.1	29.6	33.2	83.2	15.3	0.31	0.02	115.8
27	水	26.9	22.2	17.1	7.0	26.5	27.7	75.6	10.9	0.61	0.09	90.4
28	木	28.7	22.0	8.2	7.1	28.5	31.2	78.8	11.8	0.41	0.04	105.1
29	金	24.0	21.6	6.3	7.2	29.2	32.0	76.4	14.2	0.35	0.02	115.7
30	土	27.6	21.6	5.4	7.3	28.8	32.8	79.2	14.6	0.31	0.02	118.2
31	日	27.4	21.3	5.5	7.3	28.2	32.6	79.6	14.8	0.30	0.02	119.9
最大値		33.1	24.5	175.6	7.4	31.3	34.6	224.0	17.7	1.31	0.25	119.9
最小値		22.2	19.4	1.8	7.0	18.4	20.5	46.4	4.7	0.16	ND	50.6
平均値		28.6	22.2	19.2	7.2	26.3	29.2	76.6	9.5	0.49	0.04	86.2

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2014年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	金	32.5	24.0	0.9	7.2	31.6	29.7	54.0	8.2	0.07	ND	81.2
2	土	31.3	24.2	0.7	7.4	28.3	30.8	54.0	8.8	0.08	ND	82.3
3	日	30.3	23.9	0.9	7.4	29.0	30.6	52.4	7.6	0.10	ND	85.1
4	月	29.7	23.8	0.7	7.3	29.7	31.6	55.2	7.6	0.08	ND	87.0
5	火	31.3	23.4	0.9	7.2	31.0	31.2	54.0	7.4	0.09	ND	85.8
6	水	32.8	23.7	0.9	7.3	29.6	33.0	48.0	6.9	0.07	ND	85.0
7	木	30.6	23.3	1.0	7.2	27.6	31.4	44.0	8.7	0.07	ND	83.0
8	金	26.7	22.9	0.8	7.1	26.8	29.3	50.8	8.3	0.04	ND	78.5
9	土	22.2	22.0	0.9	7.4	21.6	26.3	48.0	8.3	0.03	ND	72.4
10	日	26.1	21.0	1.2	7.1	20.2	23.3	45.2	7.6	0.04	ND	69.4
11	月	26.4	20.7	2.0	7.1	19.9	24.7	48.8	8.5	0.05	ND	73.8
12	火	25.1	19.0	2.8	7.1	21.1	24.7	46.8	9.6	0.07	ND	73.4
13	水	29.7	19.2	2.1	7.1	20.1	25.7	51.2	10.6	0.04	ND	77.6
14	木	27.8	20.0	1.0	7.1	22.2	25.3	48.0	11.5	0.01	ND	79.1
15	金	29.3	21.0	0.7	7.2	23.7	25.5	46.0	9.7	0.01	ND	80.0
16	土	24.1	21.2	0.7	7.4	23.4	25.1	45.2	11.7	0.03	ND	77.3
17	日	25.8	20.6	0.9	7.3	19.4	25.3	45.2	9.2	0.03	ND	71.4
18	月	28.3	20.5	1.0	7.1	17.2	18.9	38.8	8.1	0.05	ND	64.2
19	火	32.3	20.6	1.2	7.1	23.0	22.1	42.8	9.3	0.03	ND	67.1
20	水	33.1	22.1	1.0	7.1	25.0	27.5	63.2	16.7	0.02	ND	107.8
21	木	32.6	23.1	0.7	7.1	26.5	31.8	76.8	18.6	0.02	ND	125.4
22	金	32.5	23.2	0.9	7.2	28.4	32.8	77.2	18.3	0.03	ND	126.3
23	土	29.1	22.5	1.0	7.2	25.4	34.0	76.4	18.7	0.03	ND	125.2
24	日	28.9	23.4	0.8	7.2	23.7	31.6	67.6	16.5	0.02	ND	114.7
25	月	26.7	22.7	1.0	7.1	24.7	34.4	72.4	18.5	0.03	ND	121.9
26	火	25.9	21.8	0.9	7.0	28.9	33.4	78.8	18.6	0.04	ND	120.4
27	水	26.9	22.0	1.4	7.0	29.0	26.9	65.2	15.7	0.04	ND	105.3
28	木	28.7	21.5	1.1	7.0	27.2	31.2	72.0	16.1	0.04	ND	111.0
29	金	24.0	21.3	1.1	7.1	29.8	32.6	74.0	17.4	0.26	ND	121.1
30	土	27.6	21.3	0.7	7.3	27.0	33.4	77.2	17.1	0.04	ND	123.8
31	日	27.4	21.0	0.7	7.2	26.4	33.0	74.4	17.3	0.02	ND	124.2
最大値		33.1	24.2	2.8	7.4	31.6	34.4	78.8	18.7	0.26	ND	126.3
最小値		22.2	19.0	0.7	7.0	17.2	18.9	38.8	6.9	0.01	ND	64.2
平均値		28.6	22.0	1.1	7.2	25.4	28.9	57.9	12.2	0.05	ND	93.6

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所