

水質試験結果表(取水分)

2014年9月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	月	26.3	22.5	6.2	7.3	29.5	34.2	84.8	15.3	0.33	0.02	119.3
2	火	29.1	21.0	5.3	7.1	25.8	26.1	50.8	6.2	0.27	0.01	67.9
3	水	28.8	21.5	5.0	7.3	26.2	25.5	52.8	6.6	0.29	0.02	69.0
4	木	29.0	21.6	5.2	7.3	24.8	25.9	52.0	5.5	0.26	0.01	68.8
5	金	24.2	21.5	9.3	7.2	22.6	22.5	54.0	5.7	0.40	0.01	62.1
6	土	28.8	21.1	5.2	7.4	25.6	26.9	60.0	5.4	0.35	0.02	72.6
7	日	29.6	22.0	3.2	7.4	27.0	28.1	52.8	6.1	0.24	0.01	75.2
8	月	23.9	21.9	4.7	7.3	27.6	28.9	59.2	6.6	0.31	0.01	78.3
9	火	29.2	21.2	3.8	7.2	27.0	26.5	50.0	6.8	0.25	ND	72.4
10	水	27.3	20.4	4.0	7.3	26.7	25.9	50.0	5.9	0.23	ND	69.9
11	木	28.5	20.3	4.8	7.2	24.3	25.1	46.0	7.3	0.22	0.01	69.9
12	金	28.1	19.6	3.6	7.3	25.5	26.6	45.6	7.1	0.17	0.01	69.3
13	土	26.1	20.0	2.7	7.4	25.9	25.7	42.0	6.9	0.20	0.01	71.9
14	日	27.7	20.0	2.0	7.4	29.1	29.5	42.8	7.8	0.18	0.01	81.1
15	月	24.5	21.0	1.9	7.3	29.8	31.8	45.6	6.8	0.16	0.01	85.3
16	火	25.7	20.5	2.4	7.3	28.7	31.4	46.4	7.1	0.20	0.01	82.6
17	水	21.7	18.8	3.0	7.3	25.9	28.9	48.0	6.0	0.19	0.01	71.3
18	木	23.5	18.7	2.3	7.3	28.7	27.3	48.4	6.5	0.17	0.01	70.6
19	金	27.1	17.5	2.4	7.2	25.6	27.7	46.8	6.8	0.17	0.01	70.7
20	土	23.4	17.4	1.9	7.4	27.0	26.5	48.4	6.2	0.16	0.01	73.3
21	日	23.8	17.9	1.1	7.4	28.3	29.3	51.2	7.9	0.15	ND	81.3
22	月	26.9	18.3	2.2	7.3	28.7	29.9	56.4	7.2	0.25	ND	80.9
23	火	23.8	17.8	1.9	7.3	28.4	30.4	60.4	7.4	0.18	ND	81.8
24	水	24.0	18.1	1.9	7.2	29.1	28.9	54.0	7.9	0.16	ND	82.5
25	木	24.4	18.3	2.3	7.1	29.8	29.7	50.8	6.8	0.24	ND	81.9
26	金	27.7	17.6	5.4	7.2	25.3	26.7	54.4	5.7	0.31	0.02	70.3
27	土	27.5	19.0	1.8	7.3	29.3	29.3	56.0	6.4	0.14	ND	82.1
28	日	29.1	19.0	1.6	7.3	27.3	29.3	50.4	6.1	0.16	ND	78.3
29	月	29.1	19.0	1.9	7.2	28.2	30.6	54.8	6.8	0.19	ND	79.6
30	火	30.3	18.9	2.7	7.2	28.5	30.6	56.0	6.8	0.19	ND	80.7
最大値		30.3	22.5	9.3	7.4	29.8	34.2	84.8	15.3	0.40	0.02	119.3
最小値		21.7	17.4	1.1	7.1	22.6	22.5	42.0	5.4	0.14	ND	62.1
平均値		26.6	19.7	3.4	7.3	27.2	28.2	52.4	6.9	0.22	0.01	76.7

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

