

## 水質試験結果表(取水分)

2015年4月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
1	水	14.2	11.0	8.9	7.0	21.6	24.1	64.8	12.9	0.41	0.04	82.3
2	木	14.9	9.4	44.3	7.2	16.2	19.5	87.2	10.3	2.08	0.13	70.2
3	金	19.3	11.2	29.2	7.2	18.5	23.3	84.0	12.3	1.60	0.10	74.2
4	土	13.0	11.0	41.9	7.0	17.6	21.5	102.4	10.4	1.48	0.09	68.2
5	日	14.2	11.1	37.0	7.0	16.8	19.9	92.0	9.0	1.50	0.08	65.8
6	月	12.6	10.4	55.0	6.9	17.2	21.1	104.0	9.8	1.72	0.11	63.2
7	火	8.6	10.1	36.0	7.0	18.2	25.3	78.0	8.2	1.58	0.17	68.0
8	水	6.4	8.9	28.8	7.0	19.3	23.9	76.8	10.3	0.96	0.09	74.2
9	木	10.8	8.8	14.0	7.0	20.8	25.1	72.4	10.6	0.62	0.04	82.8
10	金	11.9	10.3	10.5	7.0	22.5	24.5	72.0	12.8	0.25	0.05	86.0
11	土	15.4	10.4	11.4	7.0	24.7	28.7	77.6	13.4	0.56	0.05	93.7
12	日	13.1	10.2	9.8	7.0	22.8	28.5	70.8	11.1	0.71	0.06	86.3
13	月	13.3	10.9	8.9	7.0	23.1	28.5	56.8	11.4	0.48	0.05	82.5
14	火	15.4	10.8	16.9	6.9	21.9	25.9	78.0	10.7	0.74	0.10	84.5
15	水	11.2	11.0	26.3	6.8	20.4	22.9	80.4	10.0	1.08	0.04	75.3
16	木	15.7	10.8	26.3	6.9	19.6	26.7	92.0	9.8	1.18	0.14	78.4
17	金	11.2	11.6	17.0	7.0	20.1	23.5	71.2	10.6	0.65	0.07	74.9
18	土	14.2	10.5	13.5	7.0	21.3	22.9	75.6	9.9	0.56	0.06	76.8
19	日	15.4	11.0	13.1	7.1	22.2	26.1	68.4	9.9	0.38	0.07	82.4
20	月	17.9	11.2	16.2	7.0	22.3	25.7	68.8	10.4	0.47	0.09	76.9
21	火	11.2	13.0	63.3	7.1	17.1	20.7	110.0	8.9	1.21	0.36	64.5
22	水	18.4	11.4	27.3	7.1	20.4	22.5	86.0	12.6	0.95	0.21	77.8
23	木	21.4	11.0	16.8	7.2	20.6	22.9	70.4	9.8	0.83	0.07	71.8
24	金	22.2	12.2	14.4	7.2	19.7	23.7	68.0	9.3	0.61	0.09	71.7
25	土	20.4	12.5	11.1	7.2	19.9	22.1	66.4	8.4	0.56	0.05	71.1
26	日	19.3	12.0	10.0	7.3	21.4	24.1	66.4	9.0	0.50	0.07	71.3
27	月	23.3	12.6	10.6	7.3	20.5	26.7	72.4	9.0	0.53	0.06	71.9
28	火	24.7	12.9	12.0	7.2	20.3	23.1	60.4	8.7	0.64	0.06	70.4
29	水	25.7	14.2	9.8	7.3	22.0	25.9	62.8	9.0	0.37	0.05	74.3
30	木	24.6	14.3	11.3	7.2	24.7	24.1	65.6	9.0	0.59	0.03	75.5
最大値		25.7	14.3	63.3	7.3	24.7	28.7	110.0	13.4	2.08	0.36	93.7
最小値		6.4	8.8	8.9	6.8	16.2	19.5	56.8	8.2	0.25	0.03	63.2
平均値		16.0	11.2	21.7	7.1	20.5	24.1	76.7	10.3	0.86	0.09	75.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

