

## 水質試験結果表(取水分)

2015年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
1	金	24.7	14.3	10.7	7.2	20.5	23.1	57.6	9.5	0.55	0.07	75.5
2	土	25.0	14.8	7.9	7.5	22.2	25.3	54.8	9.5	0.42	0.05	77.6
3	日	25.5	15.2	8.4	7.4	23.1	23.7	54.8	9.0	0.49	0.04	77.1
4	月	20.9	15.4	8.4	7.3	23.8	25.3	60.4	10.2	0.48	0.04	77.4
5	火	21.8	14.7	10.8	7.3	25.2	25.5	61.6	10.4	0.57	0.05	80.3
6	水	22.5	14.5	11.0	7.3	24.0	29.5	52.4	10.0	0.60	0.04	76.3
7	木	22.3	15.0	10.2	7.2	25.1	31.2	60.8	11.2	0.55	0.06	82.1
8	金	25.0	15.5	9.0	7.2	23.0	24.5	61.2	10.0	0.47	0.06	82.4
9	土	18.4	16.0	4.8	7.5	23.0	25.9	55.2	9.5	0.37	0.02	82.1
10	日	21.3	15.0	6.6	7.4	22.9	26.6	56.0	9.6	0.39	0.03	79.6
11	月	18.8	15.1	9.7	7.3	24.6	25.7	62.4	9.6	0.52	0.04	83.3
12	火	23.2	15.8	26.7	7.4	74.9	62.9	148.0	8.8	1.68	0.08	161.2
13	水	20.3	13.7	17.3	7.3	18.5	19.7	58.0	6.4	0.68	0.05	53.3
14	木	24.4	14.0	7.4	7.2	19.5	19.1	42.0	8.5	0.33	0.01	55.7
15	金	28.6	17.0	10.4	7.2	25.9	28.1	77.2	11.5	0.52	0.07	91.9
16	土	18.6	17.8	5.9	7.2	25.6	30.2	69.2	11.8	0.57	0.03	92.8
17	日	19.3	16.2	13.2	7.3	24.2	28.9	69.2	12.1	0.69	0.06	89.2
18	月	23.1	16.8	10.0	7.3	26.8	32.2	70.0	12.9	0.38	0.05	93.3
19	火	19.5	15.2	5.1	7.3	22.0	24.3	48.4	7.9	0.29	0.02	62.2
20	水	25.5	14.4	7.2	7.1	19.3	20.7	44.0	7.6	0.32	0.03	57.2
21	木	23.3	14.9	3.7	7.2	21.2	20.9	39.2	7.4	0.21	0.01	59.2
22	金	21.9	15.0	3.0	7.1	22.1	22.3	40.0	6.5	0.20	0.01	62.3
23	土	22.4	15.5	2.1	7.3	25.7	25.1	48.0	6.8	0.20	0.01	68.2
24	日	25.3	16.0	2.0	7.4	25.2	29.7	47.2	8.0	0.19	ND	70.9
25	月	27.6	16.9	2.2	7.4	26.6	28.5	48.8	6.7	0.26	ND	71.1
26	火	27.4	16.6	2.2	7.2	24.5	26.9	46.0	6.9	0.18	ND	68.6
27	水	25.8	17.2	2.2	7.2	25.2	25.5	50.8	7.6	0.20	0.01	73.0
28	木	26.7	17.4	2.3	7.2	25.0	27.3	50.8	7.7	0.20	0.01	72.6
29	金	30.4	17.7	2.1	7.2	25.4	26.7	49.2	7.8	0.18	ND	72.7
30	土	29.0	18.3	1.6	7.3	26.6	26.6	42.8	7.4	0.16	0.01	74.3
31	日	23.8	18.5	1.6	7.3	27.2	28.5	41.2	7.1	0.19	ND	75.6
最大値		30.4	18.5	26.7	7.5	74.9	62.9	148.0	12.9	1.68	0.08	161.2
最小値		18.4	13.7	1.6	7.1	18.5	19.1	39.2	6.4	0.16	ND	53.3
平均値		23.6	15.8	7.3	7.3	25.4	27.1	57.0	8.9	0.42	0.03	77.4

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2015年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	金	24.7	14.8	1.2	7.3	20.0	21.5	50.4	11.8	0.04	ND	81.3
2	土	25.0	15.2	0.9	7.5	24.3	24.7	49.2	11.4	0.05	ND	85.0
3	日	25.5	15.6	0.8	7.5	24.8	23.9	48.4	12.7	0.04	ND	88.7
4	月	20.9	15.8	1.0	7.5	27.8	26.3	51.2	13.4	0.04	ND	80.1
5	火	21.8	14.7	1.1	7.4	26.6	29.7	40.8	14.4	0.04	0.01	86.8
6	水	22.5	14.8	1.1	7.4	29.2	27.7	42.8	16.4	0.04	ND	91.7
7	木	22.3	14.8	1.3	7.4	24.1	32.4	44.0	14.6	0.05	0.01	89.1
8	金	25.0	15.5	1.0	7.3	23.2	26.1	59.2	13.7	0.04	0.01	95.7
9	土	18.4	16.4	0.9	7.5	24.7	27.3	56.0	14.6	0.05	ND	99.3
10	日	21.3	15.2	1.2	7.5	25.4	26.9	60.0	13.8	0.05	ND	99.4
11	月	18.8	15.2	1.0	7.4	25.6	26.1	57.2	13.9	0.04	ND	96.3
12	火	23.2	15.4	1.4	7.5	26.3	28.9	63.2	13.9	0.06	0.02	102.4
13	水	20.3	13.7	1.3	7.3	18.3	19.9	40.0	11.2	0.04	0.01	65.7
14	木	24.4	14.2	1.8	7.3	18.4	19.1	40.0	12.2	0.06	ND	59.0
15	金	28.6	16.9	1.5	7.3	23.4	29.5	66.0	13.5	0.07	0.01	94.3
16	土	18.6	17.5	1.2	7.4	24.7	27.7	61.2	15.4	0.07	ND	98.3
17	日	19.3	16.5	1.5	7.2	24.6	26.9	59.2	13.9	0.06	0.01	98.3
18	月	23.1	16.9	1.2	7.3	29.0	30.2	68.8	14.6	0.07	0.01	102.5
19	火	19.5	15.0	1.3	7.3	21.8	23.7	48.4	9.3	0.07	ND	66.2
20	水	25.5	14.7	2.1	7.1	18.8	20.3	44.0	9.6	0.08	ND	61.5
21	木	23.3	15.1	1.6	7.3	20.4	21.7	40.0	8.3	0.07	ND	62.7
22	金	21.9	15.1	1.4	7.1	20.4	23.7	39.2	8.3	0.07	ND	63.6
23	土	22.4	15.2	1.2	7.4	25.3	25.1	40.8	9.7	0.06	ND	70.1
24	日	25.3	16.0	0.8	7.3	27.4	29.7	41.2	8.3	0.06	ND	71.8
25	月	27.6	17.0	0.8	7.3	25.2	26.7	47.2	7.9	0.08	ND	71.4
26	火	27.4	16.9	1.0	7.3	24.2	24.9	46.0	8.0	0.05	ND	70.7
27	水	25.8	17.3	1.3	7.2	23.9	26.1	46.4	9.2	0.08	ND	72.8
28	木	26.7	17.7	1.5	7.3	24.2	27.1	48.8	8.4	0.08	ND	73.8
29	金	30.4	17.7	1.3	7.3	25.3	26.7	48.4	9.8	0.08	ND	74.5
30	土	29.0	18.5	0.7	7.4	26.6	29.3	41.6	8.7	0.05	ND	76.1
31	日	23.8	18.5	0.6	7.4	28.4	27.9	44.8	7.9	0.07	ND	77.4
最大値		30.4	18.5	2.1	7.5	29.2	32.4	68.8	16.4	0.08	0.02	102.5
最小値		18.4	13.7	0.6	7.1	18.3	19.1	39.2	7.9	0.04	ND	59.0
平均値		23.6	15.9	1.2	7.3	24.3	26.1	49.5	11.6	0.06	ND	81.5

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 濁度およびpH以外の基準については参考値とする。  
 本試験結果はJIS.K.0101(工業用水試験法)による。