

### 水質試験結果表(取水分)

2016年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	19.0	12.7	5.0	7.1	28.1	26.1	54.0	6.6	0.27	0.02	73.9
2	月	22.4	13.8	5.8	7.0	29.4	25.3	47.6	7.4	0.30	0.03	74.7
3	火	23.1	15.0	3.8	7.2	28.3	28.1	52.0	6.3	0.25	0.02	78.3
4	水	22.5	15.4	4.7	7.2	29.3	29.7	50.0	6.4	0.31	0.01	79.4
5	木	18.6	15.9	8.2	7.0	28.2	29.1	52.4	6.6	0.38	0.03	79.0
6	金	20.4	15.2	6.1	6.9	30.2	31.4	56.4	7.1	0.33	0.02	81.7
7	土	17.6	14.2	4.7	7.1	27.4	29.7	55.2	7.1	0.30	0.02	81.3
8	日	23.8	14.0	5.4	7.0	27.1	29.1	50.4	7.6	0.30	0.03	81.6
9	月	20.1	15.2	7.4	7.0	28.5	29.1	60.0	7.8	0.24	0.02	81.6
10	火	19.5	15.0	8.7	6.9	26.0	28.9	60.0	7.7	0.37	0.03	79.5
11	水	16.6	15.4	11.6	7.0	25.0	27.3	64.0	9.4	0.54	0.06	77.3
12	木	23.8	13.9	16.4	7.0	20.3	22.1	60.4	7.3	0.60	0.08	59.5
13	金	25.6	15.7	8.2	7.0	23.5	25.1	55.2	7.4	0.38	0.04	70.3
14	土	23.6	16.5	4.3	7.1	24.2	27.7	54.0	7.1	0.26	0.02	74.0
15	日	24.7	16.8	4.5	7.0	26.9	27.9	48.0	7.6	0.28	0.01	77.6
16	月	23.7	17.5	7.4	7.0	28.7	28.3	62.8	7.3	0.48	0.03	80.7
17	火	18.2	16.4	7.9	7.1	26.9	26.9	55.2	6.4	0.43	0.03	77.0
18	水	19.4	15.3	7.7	7.0	25.5	28.1	48.0	7.1	0.35	0.02	76.7
19	木	22.5	16.7	4.8	7.0	27.8	29.3	53.6	8.1	0.13	0.01	81.2
20	金	23.8	17.1	5.4	7.0	28.4	29.7	55.2	7.0	0.32	ND	83.8
21	土	24.9	17.8	3.1	7.2	29.2	31.0	46.8	8.0	0.24	0.01	87.8
22	日	25.2	18.0	2.9	7.2	36.4	35.0	62.8	8.2	0.24	0.02	101.8
23	月	25.3	18.8	8.0	7.0	30.3	32.6	64.0	8.5	0.59	0.02	88.5
24	火	26.0	18.5	3.5	7.1	35.2	36.4	67.2	8.1	0.27	0.01	99.1
25	水	24.6	18.5	3.5	7.0	32.1	35.6	58.8	9.9	0.26	0.01	93.2
26	木	25.5	18.0	3.9	7.1	35.0	36.4	63.2	9.5	0.28	0.01	98.3
27	金	22.8	19.3	4.7	7.1	31.5	34.4	49.6	8.6	0.32	0.02	92.2
28	土	21.4	18.9	2.7	7.1	29.6	30.6	52.0	6.3	0.25	0.01	85.2
29	日	24.8	18.0	2.2	7.1	29.2	30.4	48.8	8.1	0.22	0.01	86.6
30	月	20.8	19.4	5.0	6.9	29.2	30.6	58.4	9.0	0.44	0.04	85.6
31	火	23.4	18.1	4.3	7.0	27.7	28.7	46.8	7.1	0.31	0.01	79.9
最大値		26.0	19.4	16.4	7.2	36.4	36.4	67.2	9.9	0.60	0.08	101.8
最小値		16.6	12.7	2.2	6.9	20.3	22.1	46.8	6.3	0.13	ND	59.5
平均値		22.4	16.5	5.9	7.0	28.6	29.7	55.3	7.6	0.33	0.02	82.2

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2016年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	日	19.0	12.8	2.0	7.1	28.4	26.9	53.6	8.8	0.08	0.01	77.7
2	月	22.4	14.0	1.0	7.1	27.9	25.5	43.2	9.0	0.04	ND	78.9
3	火	23.1	15.2	0.7	7.2	28.0	27.5	52.0	7.7	0.04	ND	82.7
4	水	22.5	15.7	0.8	7.2	27.7	29.9	41.2	8.1	0.03	ND	84.0
5	木	18.6	16.3	0.9	7.0	30.7	28.9	43.2	8.4	0.03	ND	84.9
6	金	20.4	16.0	0.8	7.2	29.6	29.3	51.6	9.2	0.04	ND	86.3
7	土	17.6	14.5	1.7	7.1	27.4	29.9	57.2	8.8	0.07	0.01	86.4
8	日	23.8	14.6	1.1	7.0	27.5	28.5	51.2	8.9	0.05	ND	86.6
9	月	20.1	15.5	1.1	7.1	27.2	28.5	54.8	9.5	0.05	0.01	86.3
10	火	19.5	15.2	1.2	7.0	25.4	27.9	56.8	10.0	0.04	ND	86.0
11	水	16.6	15.7	1.4	6.9	24.9	27.3	52.0	10.9	0.04	ND	85.0
12	木	23.8	14.1	2.3	6.8	17.9	21.7	46.8	8.6	0.07	0.01	65.4
13	金	25.6	16.0	2.3	7.1	22.1	26.5	51.2	9.2	0.06	0.01	74.8
14	土	23.6	17.0	1.1	7.1	24.9	25.5	48.8	10.4	0.05	ND	78.4
15	日	24.7	17.0	0.9	7.1	26.9	27.3	42.0	8.9	0.04	ND	82.4
16	月	23.7	18.4	0.8	7.1	28.2	27.5	56.0	9.2	0.04	ND	83.7
17	火	18.2	17.1	1.4	7.0	25.3	27.5	48.0	9.6	0.06	ND	82.0
18	水	19.4	16.0	1.6	7.0	25.2	27.3	42.8	9.7	0.06	ND	81.0
19	木	22.5	17.0	1.2	7.0	26.5	27.7	54.8	9.4	0.05	ND	85.0
20	金	23.8	17.1	1.1	7.0	28.8	30.6	41.6	8.9	0.05	ND	88.2
21	土	24.9	18.0	1.0	7.1	30.2	30.6	47.2	8.7	0.05	ND	89.4
22	日	25.2	18.2	0.8	7.2	35.4	36.8	56.4	9.7	0.15	ND	104.1
23	月	25.3	19.4	0.7	7.1	29.1	31.2	52.8	10.1	0.06	ND	90.9
24	火	26.0	18.8	0.9	7.0	34.4	35.4	59.2	10.6	0.05	ND	100.7
25	水	24.6	18.5	1.0	7.0	32.3	35.0	59.2	10.2	0.06	ND	96.3
26	木	25.5	18.0	1.1	7.0	32.8	35.2	64.4	10.1	0.06	ND	100.5
27	金	22.8	19.4	0.9	7.0	31.0	33.6	50.8	11.2	0.05	ND	95.5
28	土	21.4	19.0	0.9	7.0	28.3	30.4	49.2	9.0	0.04	ND	87.8
29	日	24.8	18.2	0.8	7.0	29.6	31.2	47.2	9.7	0.07	ND	88.9
30	月	20.8	19.1	0.7	7.0	29.0	31.2	48.8	10.7	0.07	ND	88.8
31	火	23.4	18.1	0.8	6.9	26.6	28.9	43.2	9.9	0.05	ND	82.6
最大値		26.0	19.4	2.3	7.2	35.4	36.8	64.4	11.2	0.15	0.01	104.1
最小値		16.6	12.8	0.7	6.8	17.9	21.7	41.2	7.7	0.03	ND	65.4
平均値		22.4	16.8	1.1	7.0	28.0	29.4	50.6	9.5	0.05	ND	86.2

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 濁度およびpH以外の基準については参考値とする。  
 本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所