

水質試験結果表(取水分)

2016年6月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	水	25.4	19.0	3.6	6.9	28.1	29.7	44.8	7.9	0.24	0.01	82.3
2	木	22.8	17.6	4.4	7.0	28.6	28.9	52.4	6.7	0.22	0.01	80.8
3	金	21.3	17.9	2.8	6.9	28.9	31.8	52.0	8.4	0.23	ND	85.9
4	土	23.8	18.1	1.9	7.1	30.7	33.6	56.0	7.1	0.20	0.01	93.6
5	日	21.5	18.0	2.3	7.0	35.9	37.0	59.2	8.1	0.21	0.01	100.5
6	月	24.0	19.2	2.7	6.9	30.1	33.6	54.0	7.4	0.29	0.01	85.4
7	火	23.1	19.0	2.3	7.1	32.5	33.8	58.4	7.6	0.24	0.01	93.9
8	水	26.1	18.0	2.7	7.0	33.0	38.4	51.6	6.8	0.25	0.01	91.9
9	木	22.8	20.0	3.0	7.1	29.8	31.2	54.0	7.8	0.27	0.01	84.8
10	金	28.1	19.0	3.1	6.9	28.9	30.6	49.2	8.2	0.23	0.01	83.5
11	土	27.8	20.5	2.0	7.1	30.9	30.6	55.2	7.4	0.24	0.01	86.7
12	日	27.3	20.9	1.8	7.0	30.8	31.0	50.0	7.4	0.22	ND	87.0
13	月	22.1	20.6	2.6	7.0	29.8	31.8	51.2	8.6	0.28	0.01	83.8
14	火	25.7	19.4	4.3	7.1	28.3	30.6	48.0	7.7	0.32	ND	80.3
15	水	27.2	20.0	3.0	7.0	29.5	30.8	49.6	7.6	0.24	ND	87.0
16	木	26.0	20.7	2.9	7.0	30.5	33.2	52.0	7.4	0.25	ND	90.5
17	金	22.0	19.5	4.8	6.9	28.0	30.2	53.2	7.1	0.28	ND	79.8
18	土	25.5	19.5	3.1	7.0	31.0	31.2	56.8	6.4	0.28	0.02	85.6
19	日	25.6	21.0	2.6	7.0	31.2	32.2	55.2	7.9	0.26	0.01	86.8
20	月	24.2	19.9	2.9	7.1	31.6	29.3	57.6	8.4	0.26	0.01	84.7
21	火	28.2	20.9	4.0	6.9	30.3	31.6	52.0	6.4	0.29	0.01	84.3
22	水	28.1	21.7	3.3	7.1	30.5	34.8	56.0	8.2	0.24	0.01	88.7
23	木	22.8	21.3	7.6	7.1	27.1	28.7	54.4	7.1	0.41	0.03	81.2
24	金	24.3	20.5	5.2	7.1	28.1	28.9	52.8	6.5	0.32	0.01	81.9
25	土	23.3	20.0	9.0	7.2	26.6	28.3	60.0	7.2	0.56	0.02	77.5
26	日	19.7	18.7	14.6	7.1	21.0	22.7	50.8	5.4	0.57	0.04	60.4
27	月	25.5	18.2	8.7	7.0	23.7	24.5	54.0	7.0	0.43	0.03	68.2
28	火	21.6	19.1	4.7	7.2	25.8	28.3	44.4	5.9	0.25	0.04	76.0
29	水	24.6	18.1	4.4	7.2	27.4	28.1	55.6	7.1	0.32	0.03	77.0
30	木	25.1	19.2	4.6	7.2	27.6	29.7	53.2	6.8	0.29	0.01	78.7
最大値		28.2	21.7	14.6	7.2	35.9	38.4	60.0	8.6	0.57	0.04	100.5
最小値		19.7	17.6	1.8	6.9	21.0	22.7	44.4	5.4	0.20	ND	60.4
平均値		24.5	19.5	4.2	7.0	29.2	30.8	53.1	7.3	0.29	0.01	83.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

