

### 水質試験結果表(取水分)

2016年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	金	30.1	19.0	4.2	7.2	27.2	28.1	58.4	6.2	0.29	0.01	77.7
2	土	31.9	21.0	2.8	7.4	28.6	30.2	56.8	7.1	0.22	0.01	81.4
3	日	26.6	21.5	2.9	7.3	28.0	28.3	56.0	7.3	0.24	0.01	81.3
4	月	26.3	20.2	3.0	7.2	28.0	28.3	62.4	6.8	0.25	0.01	78.0
5	火	27.8	19.9	7.5	7.1	25.2	26.5	55.2	6.1	0.37	0.02	71.2
6	水	30.5	21.1	3.9	7.1	26.0	29.9	48.4	5.4	0.32	0.02	74.5
7	木	27.4	21.6	3.4	7.2	28.2	28.7	44.0	5.6	0.27	0.02	80.0
8	金	25.6	21.2	3.4	7.2	28.0	27.7	52.4	5.9	0.27	0.01	79.0
9	土	23.9	20.8	3.0	7.3	26.4	25.7	52.4	6.4	0.21	0.01	78.7
10	日	28.1	20.2	2.9	7.3	27.2	26.1	46.8	6.6	0.21	0.01	78.2
11	月	29.0	22.0	2.5	7.1	30.2	29.7	50.8	7.2	0.26	0.01	82.5
12	火	25.7	21.7	3.9	7.1	27.4	27.1	52.8	6.4	0.26	ND	75.3
13	水	27.0	21.3	3.0	7.0	26.6	27.1	46.8	6.6	0.22	ND	74.9
14	木	27.3	21.2	11.4	7.0	23.2	24.1	50.8	5.9	0.52	0.04	66.1
15	金	22.6	20.9	18.0	7.1	21.7	22.5	60.0	6.0	0.83	0.04	63.4
16	土	26.5	19.0	4.8	7.1	21.2	23.5	48.4	6.2	0.30	0.02	65.1
17	日	25.0	20.5	2.6	7.2	24.8	26.5	40.0	5.7	0.18	0.02	73.5
18	月	27.4	20.0	2.3	7.1	26.4	26.3	48.8	6.8	0.18	0.01	77.8
19	火	27.7	20.7	4.7	7.1	27.0	27.3	54.8	6.8	0.34	0.03	77.2
20	水	28.6	21.0	3.7	7.1	27.3	26.5	50.8	6.7	0.24	0.01	75.0
21	木	30.7	21.4	3.1	7.1	27.6	25.9	48.4	6.1	0.25	0.01	76.9
22	金	32.0	21.8	2.7	7.2	26.1	27.3	45.6	6.5	0.23	0.01	75.8
23	土	29.5	22.0	1.2	7.4	27.7	27.1	44.0	5.7	0.10	0.01	79.6
24	日	30.4	22.5	2.2	7.3	28.4	31.2	45.6	6.0	0.20	0.01	82.4
25	月	27.3	22.7	2.2	7.2	29.8	29.1	46.8	7.0	0.21	0.01	84.0
26	火	22.1	21.8	3.3	7.1	26.9	25.9	44.0	6.9	0.28	ND	75.1
27	水	28.3	20.7	4.4	7.1	25.4	25.3	48.8	6.7	0.28	0.01	73.6
28	木	31.6	22.2	3.1	7.1	26.6	25.9	40.0	7.0	0.20	0.01	74.5
29	金	31.1	22.3	2.5	7.1	27.5	27.5	40.0	6.7	0.20	0.01	75.3
30	土	31.7	22.9	2.1	7.3	27.0	25.3	44.0	6.4	0.16	0.01	76.0
31	日	32.2	23.3	1.9	7.3	27.3	26.5	40.8	7.4	0.15	ND	77.1
最大値		32.2	23.3	18.0	7.4	30.2	31.2	62.4	7.4	0.83	0.04	84.0
最小値		22.1	19.0	1.2	7.0	21.2	22.5	40.0	5.4	0.10	ND	63.4
平均値		28.1	21.2	4.0	7.2	26.7	27.0	49.2	6.5	0.27	0.01	76.2

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2016年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	金	30.1	19.0	0.8	7.2	26.0	27.9	47.6	8.5	0.05	ND	80.5
2	土	31.9	21.0	0.6	7.3	27.3	28.5	56.0	8.6	0.04	ND	83.8
3	日	26.6	21.7	0.5	7.3	28.6	28.7	50.8	8.7	0.04	ND	83.5
4	月	26.3	20.4	0.5	7.3	27.5	29.9	53.6	8.3	0.03	ND	80.7
5	火	27.8	19.9	0.9	7.1	25.2	26.3	48.0	8.7	0.05	ND	76.2
6	水	30.5	21.1	0.6	7.0	27.1	30.2	47.6	6.5	0.04	ND	77.2
7	木	27.4	21.7	0.5	7.1	28.1	29.5	38.4	6.7	0.05	ND	82.2
8	金	25.6	21.3	0.8	7.1	27.2	28.1	49.2	7.3	0.05	ND	80.6
9	土	23.9	20.8	0.9	7.3	26.6	27.1	50.4	7.6	0.04	ND	79.8
10	日	28.1	20.2	0.7	7.2	26.2	26.9	42.8	7.9	0.05	ND	78.2
11	月	29.0	22.0	0.8	7.1	29.5	30.6	51.2	8.8	0.09	ND	82.8
12	火	25.7	22.0	0.8	7.1	26.8	27.3	48.8	8.3	0.04	ND	77.4
13	水	27.0	21.2	0.8	7.1	26.3	26.9	44.0	8.2	0.04	ND	77.0
14	木	27.3	21.3	1.0	7.0	24.1	26.3	41.2	7.7	0.04	ND	74.7
15	金	22.6	20.9	1.2	7.0	21.9	25.3	40.4	9.5	0.04	ND	74.4
16	土	26.5	19.2	1.7	7.1	21.8	22.1	41.6	7.6	0.06	ND	68.6
17	日	25.0	20.5	0.9	7.1	23.5	25.3	40.4	7.0	0.05	ND	74.4
18	月	27.4	20.0	0.8	7.2	25.4	27.9	48.8	7.6	0.04	ND	78.7
19	火	27.7	21.0	0.7	7.0	26.2	27.1	46.0	8.0	0.06	ND	79.6
20	水	28.6	21.2	0.6	7.0	26.2	26.7	53.6	8.1	0.03	ND	78.0
21	木	30.7	21.5	0.4	7.0	26.0	26.5	44.8	8.0	0.02	ND	78.8
22	金	32.0	21.9	0.6	7.1	25.8	27.9	48.0	8.5	0.03	ND	78.2
23	土	29.5	22.1	0.6	7.4	28.0	28.7	50.4	7.7	0.02	ND	80.8
24	日	30.4	22.7	0.7	7.4	29.0	31.8	45.2	7.4	0.03	ND	83.6
25	月	27.3	23.2	0.7	7.3	28.5	28.5	46.4	8.5	0.04	ND	84.7
26	火	22.1	21.7	0.7	7.0	26.9	26.7	40.0	8.2	0.03	ND	77.9
27	水	28.3	20.8	0.7	7.0	23.9	27.3	40.8	8.1	0.04	ND	76.0
28	木	31.6	22.2	0.6	7.0	25.7	26.3	41.2	8.2	0.04	ND	76.6
29	金	31.1	22.5	0.5	7.1	26.1	26.7	40.0	8.5	0.04	ND	77.7
30	土	31.7	23.0	0.5	7.3	25.9	27.1	50.0	9.0	0.02	ND	78.3
31	日	32.2	23.5	0.4	7.2	27.0	27.5	42.4	8.7	0.01	ND	78.5
最大値		32.2	23.5	1.7	7.4	29.5	31.8	56.0	9.5	0.09	ND	84.7
最小値		22.1	19.0	0.4	7.0	21.8	22.1	38.4	6.5	0.01	ND	68.6
平均値		28.1	21.3	0.7	7.1	26.3	27.5	46.1	8.1	0.04	ND	78.7

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所