

水質試験結果表(取水分)

2016年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	月	33.2	24.5	2.8	7.1	31.5	29.3	52.0	8.1	0.24	ND	86.5
2	火	32.0	23.0	3.1	7.2	27.7	26.7	49.2	6.2	0.18	0.01	76.7
3	水	31.9	22.9	3.0	7.2	28.1	30.2	46.4	5.4	0.24	0.01	74.2
4	木	30.0	22.7	3.3	7.1	27.0	29.1	44.0	6.2	0.24	0.01	73.3
5	金	32.1	23.0	3.3	7.1	26.2	26.3	40.8	6.3	0.23	0.01	74.0
6	土	34.8	23.3	2.5	7.3	27.2	28.3	46.0	5.6	0.20	0.01	77.2
7	日	33.3	24.8	1.7	7.2	30.2	31.2	43.2	8.5	0.18	ND	83.6
8	月	35.1	25.5	2.5	7.1	31.3	30.8	48.8	8.4	0.25	ND	86.0
9	火	30.1	24.0	3.0	7.1	26.7	27.3	48.0	6.4	0.23	0.01	75.6
10	水	30.0	22.8	2.7	7.1	26.5	27.9	45.6	6.7	0.21	0.01	74.2
11	木	30.5	22.4	1.9	7.2	28.0	27.9	46.0	7.7	0.19	0.01	79.1
12	金	31.2	23.7	2.0	7.0	30.1	32.8	46.4	9.0	0.20	ND	87.9
13	土	32.0	24.7	2.0	7.2	31.4	32.6	42.4	8.3	0.13	ND	91.8
14	日	29.3	24.7	2.0	7.2	31.0	32.0	44.4	8.1	0.20	0.01	89.7
15	月	25.9	25.1	1.8	7.1	30.8	33.8	46.0	9.2	0.24	0.01	87.8
16	火	29.4	23.2	3.4	7.1	27.7	27.7	44.4	7.4	0.25	0.01	78.4
17	水	29.1	24.0	2.7	7.1	31.0	30.2	49.2	8.1	0.26	0.01	83.0
18	木	32.3	23.7	2.0	7.1	31.5	31.4	50.0	7.1	0.21	0.01	84.3
19	金	34.9	23.9	2.1	7.1	30.2	31.8	46.8	8.4	0.23	0.01	86.6
20	土	28.5	24.7	1.4	7.3	31.1	33.4	48.0	9.6	0.16	ND	88.5
21	日	31.6	24.8	5.6	7.2	26.4	26.1	46.8	8.9	0.28	0.01	74.9
22	月	34.7	25.0	3.8	7.1	29.1	33.2	53.6	9.3	0.31	ND	84.2
23	火	30.2	24.6	3.1	7.1	30.0	30.6	48.0	7.6	0.23	0.01	84.7
24	水	29.6	24.2	2.9	7.1	30.8	31.8	50.4	8.6	0.23	0.01	87.0
25	木	31.2	23.7	2.6	7.1	30.8	32.2	46.0	7.9	0.24	0.01	86.9
26	金	30.4	24.2	2.2	7.2	31.2	31.6	46.8	8.1	0.20	0.01	88.8
27	土	26.0	23.1	2.5	7.4	28.9	30.4	52.0	8.7	0.20	0.01	84.6
28	日	24.0	22.8	2.0	7.3	31.7	34.0	54.4	8.7	0.19	0.01	89.9
29	月	26.2	22.0	2.4	7.1	31.4	33.4	59.6	8.4	0.27	0.01	88.3
30	火	21.0	22.0	4.2	7.0	27.2	29.3	48.0	6.6	0.26	ND	76.6
31	水	29.0	20.4	7.4	7.1	25.3	27.5	52.4	8.0	0.37	0.02	75.1
最大値		35.1	25.5	7.4	7.4	31.7	34.0	59.6	9.6	0.37	0.02	91.8
最小値		21.0	20.4	1.4	7.0	25.3	26.1	40.8	5.4	0.13	ND	73.3
平均値		30.3	23.7	2.8	7.1	29.3	30.3	47.9	7.8	0.23	0.01	82.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2016年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	33.2	25.0	0.6	7.1	30.1	31.6	48.0	8.5	0.04	ND	87.1
2	火	32.0	23.2	0.6	7.1	27.3	26.5	48.0	8.1	0.03	ND	79.1
3	水	31.9	23.0	0.5	7.1	26.2	29.5	38.0	6.0	0.04	ND	76.9
4	木	30.0	23.0	0.5	7.1	25.8	29.7	40.8	8.3	0.02	ND	75.7
5	金	32.1	23.2	0.6	7.2	28.5	29.3	44.0	8.4	0.04	ND	76.1
6	土	34.8	23.5	0.7	7.2	27.7	28.7	42.4	8.6	0.04	ND	77.7
7	日	33.3	25.0	0.6	7.2	30.5	31.6	43.2	8.9	0.05	ND	83.7
8	月	35.1	26.2	0.7	7.2	30.7	31.0	48.4	10.2	0.05	ND	87.0
9	火	30.1	24.3	0.8	7.1	26.8	28.5	46.0	8.5	0.04	ND	78.4
10	水	30.0	23.2	0.5	7.1	26.2	27.7	41.6	8.6	0.03	ND	76.5
11	木	30.5	22.7	0.6	7.3	27.2	27.5	49.6	9.6	0.05	ND	80.0
12	金	31.2	23.9	0.6	7.1	32.6	31.6	50.8	8.9	0.07	ND	88.0
13	土	32.0	25.0	0.7	7.3	30.6	31.6	42.4	9.2	0.08	ND	90.0
14	日	29.3	25.1	0.7	7.2	30.9	32.4	39.6	10.0	0.07	ND	90.1
15	月	25.9	25.3	0.7	7.2	31.3	32.4	42.4	9.3	0.10	ND	88.3
16	火	29.4	23.7	0.9	7.1	27.8	29.5	44.4	8.6	0.08	ND	82.6
17	水	29.1	24.0	0.9	7.1	29.5	32.2	42.4	8.8	0.08	ND	83.8
18	木	32.3	24.0	0.6	7.1	29.6	30.2	48.0	9.2	0.05	ND	85.7
19	金	34.9	24.0	0.7	7.0	30.3	31.8	47.6	10.0	0.07	ND	88.4
20	土	28.5	24.8	0.7	7.3	31.4	33.6	42.8	9.9	0.05	ND	90.5
21	日	31.6	25.0	0.7	7.2	26.0	27.9	44.0	9.3	0.03	ND	81.4
22	月	34.7	25.2	1.4	7.1	27.6	30.4	50.4	10.0	0.11	ND	84.0
23	火	30.2	24.7	0.8	7.1	28.9	30.6	48.0	9.4	0.06	ND	86.0
24	水	29.6	24.3	0.7	7.0	29.9	32.4	42.4	9.9	0.04	ND	89.6
25	木	31.2	23.7	0.7	7.0	30.4	31.8	40.8	9.8	0.04	ND	89.8
26	金	30.4	24.3	0.4	7.1	30.0	32.6	45.6	9.9	0.04	ND	90.8
27	土	26.0	23.2	0.7	7.3	28.9	31.2	54.4	8.8	0.04	ND	87.9
28	日	24.0	22.9	0.8	7.3	30.8	35.4	54.4	9.2	0.06	ND	90.8
29	月	26.2	22.2	0.8	7.2	31.5	35.2	58.8	9.6	0.09	ND	89.8
30	火	21.0	21.9	0.5	6.9	27.5	29.5	42.8	9.7	0.02	ND	83.6
31	水	29.0	20.4	1.4	7.0	23.5	29.3	48.0	10.2	0.06	ND	79.5
最大値		35.1	26.2	1.4	7.3	32.6	35.4	58.8	10.2	0.11	ND	90.8
最小値		21.0	20.4	0.4	6.9	23.5	26.5	38.0	6.0	0.02	ND	75.7
平均値		30.3	23.9	0.7	7.1	28.9	30.7	45.8	9.1	0.05	ND	84.5

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 濁度およびpH以外の基準については参考値とする。
 本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所